



Enriching Life

NAKURU WATER AND SANITATION SERVICES CO. LTD

Nakuru Water & Sanitation Services Co. Ltd.
Government Rd, Nawassco Plaza

Tel: 051- 2212269

Nakuru Water and Sanitation
Services Company Ltd

P.O. Box 16314-20100 Nakuru.

Toll Free Line 0800-720036

@Nakuru Water

infor@nakuruwater.co.ke
custcare@nakuruwater.co.ke

www.nakuruwater.co.ke

Laboratory Test Report

Test Report No: NAWASSCO/TES/363/25

Page...1...of....1

Report date: August 14, 2025

1. Description of Sample: **Waste Water (GIANLUCA LOTH)**
2. Sample Submitted by: **Mr. Gianluca Loth**
3. Contact Person: **Mr. Gianluca Loth**
4. Customer's Ref. No: **Private**
5. NAWASSCO Sample Ref. No: **502-504/25**
6. Date of Receipt: **August 04, 2025**
7. Date Analysis Started: **August 04, 2025**
8. Sample Analysis Request Form No: **_**
9. Customer Address: **+41799297087**
10. Parameters tested and method of test as listed below.

TEST	TEST METHOD	UNITS	RESULTS		
			RAW 01/08/25	TREATED 01/08/25	TREATED 03/08/25
Chloride	APHA-4500 Cl ⁻	mg/l	351.99	—	332.99
*Ammonia	APHA-4500	mg/l	244.65	—	214.74
*Total Coliform	NLTM19_Bacteriological	No/100ml	460,000	0	100
*E.Coli	NLTM19_Bacteriological	No/100ml	140,000	0	0

KEY: LLD=Lowest Limit of Detection; KS EAS =Kenya (East Africa) Standard; *parameters not accredited

COMMENTS/REMARKS

Results are as shown above.

Ngatia Waweru- Technical Signatory

Eliud Rotich- Technical Signatory

"This document is issued by the Company Subject to its Conditions of Service printed on sample submission form. Attention is drawn for the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only within the limits of the Client's instruction, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without a prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content of appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law."

"Unless otherwise stated, the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 90 days only (If not perishable) Note that all details in respect of the source and test results of similar samples are not verified or confirmed."



KENAS 17025 Accredited Reg. No: KENAS/TL/15