


# ***SYSTEM ID: Hanoi System***

---

## **NARRATIVE DESCRIPTION**

The Hanoi system was first presented by Fujiwara and Khang (1990) and is based on the planned trunk network of Hanoi, Vietnam. There are 34 pipes to be sized with a total length of 38.61 km. Possible new pipe sizes range between 12 and 40 inches and the total system demand is 126.5 MGD.

## **NETWORK SCHEMATIC:**



## **HISTORY OF THE NETWORK FILE**

The Network was first optimized by Fujiwara and Khang (1990) using a two phase non-linear programming method. It has subsequently been used as a case study for a number of optimization techniques including genetic algorithms (Savic and Walters, 1997; Marchi et al, 2014), simulated annealing (Cunha and Sousa, 1999), the shuffled frog-leaping algorithm (Eusuff and Lansey, 2003), ant colony optimization (Zecchin et al, 2005), harmony search (Geem, 2006) and differential evolution (Vasan and Simonovich, 2010). A more complete summary of studies aimed at optimizing this network is given by De Corte and Sorensen (2013).

## AVAILABLE INFORMATION

Physical attributes	Yes
Schematic diagram	Yes
Network geometry data	Yes
GIS data file	No
Background map	No
Elevation data	Yes
Pipe data	Yes
<i>Pipe material</i>	No
<i>Pipe age</i>	No
<i>Pipe pressure class</i>	No
<i>Nominal or actual diameters</i>	Actual
Pump data	N.A.
<i>Useful horsepower</i>	
<i>Pump operating curves</i>	
Tank data	N.A.
<i>Elevation data</i>	
<i>Stage storage curves</i>	
<i>Water quality information</i>	
Valve data	N.A.
<i>PRV/FCV data</i>	
<i>Isolation valve data</i>	
<i>Hydrant data</i>	
Demand data	Yes
<i>Total system demand</i>	Yes
<i>Nodal demand data</i>	Yes
<i>Temporal data demands</i>	No
<i>System leakage</i>	No
Hydraulic data	Yes
<i>Hydraulically calibrated model</i>	
<i>Field hydraulic calibration data</i>	
Water quality data	No
<i>Disinfection method</i>	No
<i>Chlorine residual data</i>	No
<i>Booster station data</i>	No
<i>Fluoride/Chloride field data</i>	No
<i>Water quality calibrated model</i>	No
Operational data	No
<i>SCADA datasets</i>	No
<i>Operational rules</i>	No

## **REFERENCES:**

- Cunha, M., Sousa, J., 1999. Water distribution network design optimization: simulated annealing approach. *J. of Water Resources Plan. and Man.*, 125 (4).
- De Corte, A. and Sorensen, K. (2013) Optimisation of gravity-fed water distribution network design: A critical review, *European Journal of Operational Research*, 228, 1 - 10.
- Eusuff, M.M., Lansey, K.E., 2003. Optimization of water distribution network design using the shuffled frog leaping algorithm. *J. of Water Resources Plan. and Man.*, 129 (3).
- Fujiwara, O. and Khang, D.B. (1990), A two-phase decomposition method for optimal design of looped water distribution networks, *Water Resour. Res.*, 26(4), 539-549.
- Geem, Z.W., 2006. Optimal cost design of water distribution networks using harmony search. *Engineering Optimization* 38 (3), 259–280.
- Marchi, A, Dandy, G., Wilkins, A and Rohrlach, H (2014) A methodology for comparing evolutionary algorithms for the optimization of water distribution systems, *J. of Water Resources Plan. and Man.* 140 (1), 22-31.
- Savic, D., Walters, G., 1997. Genetic algorithms for least-cost design of water distribution networks. *J. of Water Resources Plan. and Man.*, 123 (2), 67–77.
- Vasan, A., Simonovic, S.P., 2010. Optimization of water distribution network design using differential evolution. *J. of Water Resources Plan. And Man. ASCE*, 136 (2), 279–287.
- Zecchin, A.C., Simpson, A.R., Maier, H.R., Nixon, J.B., 2005. Parametric study for an ant algorithm applied to water distribution system optimization. *IEEE Transactions on Evolutionary Computation* 9 (2), 175–191.

## **DETAILED DATA SUMMARIES**

### **PHYSICAL ASSETS:**

<b>Asset Type:</b>	<b># of Assets</b>
Master Meters	0
Tanks	0
Pumps	0
Pump Stations	0
Water Treatment Plants	0

### **NETWORK CHARACTERISTICS:**

# Total Pipes:	34
# Branch Pipes:	7
Ratio (Branch Pipes / Total Pipes):	0.21
# Nodes	31
# Reservoirs	1
# Tanks	0
# Regulating Valves	Unknown
# Isolation Values	Unknown
# Hydrants	Unknown
Elevation Data	YES

### **PIPE DATA:**

<b>Diameter (in)</b>	<b>Length (ft)</b>
12	To be determined
16	To be determined
24	To be determined
30	To be determined
40	To be determined

### **PUMP DATA:**

Pump Horsepower	NO
Pump Curves:	NO

**DEMAND STATISTICS:**

<b>Demographic Type</b>	<b>Population</b>	<b>Households</b>
Directly Serviceable:	Unknown	Unknown
Indirectly Serviceable:	Unknown	Unknown
Total Serviceable:	Unknown	Unknown

<b>Production Statistics</b>	
Total Annual Volume Produced (MG):	126.5
Total Annual Volume Purchased (MG):	126.5
Total Annual Volume Provided (MG):	126.5
Estimated Annual Water Loss:	Unknown

<b>Water Costs</b>	
<b>Customer Type</b>	<b>Cost per 1000 gallons</b>
Customers within the municipality	Unknown
Customers outside the municipality	Unknown

**CUSTOMERS AND USAGE:**

<b>Customer Type</b>	<b>Customer Count</b>	<b>Average Daily Demand (MGD)</b>
Wholesale:		
Residential:		
Commercial:		
Institutional:		
Industrial:		
Other:		
Total Customers:		
Flushing, Maintenance & Fire Protection:		
Total Water Usage:		126.5

**DATA FILE ATTRIBUTES:**

<b>ATTRIBUTE</b>		<b>UNITS</b>
Pipe Length & Diameter	X	Metres
Pipe Age		
Node Elevation	X	Metres
Node Demand	X	Cubic metres per hour
Valves		
Hydrants		
Tank Levels		
Tank Volume		
PRVs		
WTP		
WTP Capacity		
Pump Data		