

A New MAF based $\alpha\beta$ EPMAFPLL for Grid Connected RES with Improved Performance under Grid Faults

Zunaib Ali, Nicholas Christofides
 Department of Electrical Engineering Department
 Frederick University,
 Nicosia, Cyprus
 zunaib.ali@stud.frederick.ac.cy,
 n.christofides@frederick.ac.cy

Lenos Hadjidemetriou and Elias Kyriakides
 Department of Electrical and Computer Engineering,
 KIOS Research and Innovation Center of Excellence,
 University of Cyprus
 Nicosia, Cyprus
 [hadjidemetriou.lenos, elias]@ucy.ac.cy

Abstract- Diversifying the role of renewable energy sources (RES) and in particular, the role of the grid side converter (GSC) has gained a lot of attention recently. This is a result of the need for more advanced built-in control systems that facilitate support of the grid during abnormal conditions. Distributed renewable generation can provide auxiliary support if GSC controllers are suitably developed and designed. To this end, the control of GSC relies significantly on the fast and accurate extraction of grid voltage phase angle. In addition, the control system must respond fast, be accurate during transient events and present low computational burden to the GSC which must perform a lot of other peripheral tasks. The phase angle extraction is done using phase-locked loop (PLL) algorithm and its response is critical under off-nominal grid conditions such as grid faults, frequency variations etc. Moving average filter (MAF) based PLL techniques provide a better option, however, in some cases these techniques are inaccurate. The work presents a new MAF based PLL that is faster, accurate under any grid disturbances and with significantly improved transient response. The improved performance of proposed $\alpha\beta$ EPMAFPLL is validated through simulation and experimental results.

Keywords- Moving average filter, phase-locked Loop, grid phase angle, faults, grid side converter.

1. INTRODUCTION

The continuous growth and large scale integration of distributed renewable energy sources (RES), Fig. 1, made necessary the modification and amendment of grid regulations. Recently revised grid codes require appropriate control techniques that can work efficiently under normal and faulty grid conditions. An example of such grid codes is shown in Fig. 2, depicting the normal operating voltage zone at the point of common coupling (PCC). The figure also shows the off-nominal voltage limits and RES grid-connection time requirements, as imposed by some countries, whereby it is necessary to keep injecting during this period high quality power in order to support the grid [1-3]. In addition, RES must accordingly operate in order to support the grid in the presence of harmonics and off-nominal grid conditions (such as, off-nominal frequency variations, variation in nominal voltage magnitude, asymmetrical grid faults etc.). As a result, in order for proper operation of RES, the control system must be designed so as to operate within acceptable

grid-imposed limits. Energy generated from RES is efficiently transferred to the utility grid via power electronic based Grid Side Converter (GSC) [4, 5]. Consequently, the control of RES mainly involves the control of GSC. Hence for meeting the modern grid regulations, appropriate control techniques with improved performance and reduced complexity are needed for GSC [6, 7]. The control topology of GSC consists of the inner and outer current and voltage control loops, respectively used for controlling the currents and voltages, thereby controlling the transfer of desired active/reactive power to the grid [8].




Fig. 1: Worldwide total installed capacity for wind power and solar Photovoltaic (PV) systems [9-11].




Fig. 2: Grid Code FRT requirement under faulty grid conditions.

The GSC control can be developed either in the stationary $\alpha\beta$ reference frame or dq synchronous reference frame (SRF). The stationary $\alpha\beta$ control is implemented by converting the three phase signals into corresponding two phase domain. It utilizes proportional integral controller in each control loop and the frequency of the grid voltage is main parameter that may affect the PR controller. For estimating the grid frequency, when the frequency is not constant, frequency locked loop (FLL) is used. Control operation in SRF is achieved by utilizing the phase angle of grid voltage as a reference parameter. The phase angle is estimated from the point of common coupling (PCC) and used for controlling the converter by converting all the variables (currents/voltages) in corresponding DC magnitudes. For the control of DC quantities, a simple transfer function with pole at zero can be used, hence SRF employs a PI controller [6]. The performance of controller in SRF frame is mainly dependent on the efficient extraction of phase angle under all the normal (balanced) and off-normal (unbalanced faults, harmonic distortion, off nominal frequencies) conditions. Consequently, a phase-locked loop (PLL) algorithm is used for acquiring the phase angle of grid voltage. The work herein presented relates to GSC control in SRF, as shown in Fig. 3.




Fig. 3: Control of grid connected RES in SRF frame.

In the literature, many PLL techniques have been presented for estimating the phase angle at PCC. The simplest and most conventional techniques are the dqPLL (or SRFPLL) [12] and the $\alpha\beta$ PLL [13-15]. Both techniques utilize the fundamental positive sequence of grid voltage and can work efficiently under balanced grid conditions including balanced faults. However, under unbalanced conditions, the positive sequence component is accompanied by undesired double frequency oscillations caused by the existence of negative sequence component. Furthermore, dqPLL and $\alpha\beta$ PLL do not respond as desired in the presence of harmonic distortion in the grid voltage. The only advantage of $\alpha\beta$ PLL over the conventional dqPLL is that it offers significantly less overshoot in estimated frequency and phase at the time of unbalanced fault [16, 17]. In order to alleviate the problem of oscillations under unbalanced conditions, the SRFPLL and $\alpha\beta$ PLL are modified by adding a decoupling network and the new PLLs are referred to as decoupled SRFPLL (dsrfPLL) [18] and decoupled $\alpha\beta$ PLL (d $\alpha\beta$ PLL) [16, 17]. Unlike dqPLL, the dsrfPLL suffers from high overshoot at the instant of fault occurrence. The only disadvantage of dsrfPLL and d $\alpha\beta$ PLL is inaccurate estimation

of phase and frequency in the presence of grid harmonics. For compensating the effect of grid harmonics, two new techniques are proposed in [19] and [20], known as MSHDCPLL and DN $\alpha\beta$ PLL, in which the existing decoupling network of [18] and [16, 17] is expanded to incorporate the decoupling of oscillatory effects in transformed dq variable caused by the presence of harmonic frequencies. The MSHDCPLL and DN $\alpha\beta$ PLL respond accurately under harmonic distortion and unbalanced grid conditions, and result in smooth angle estimation. However, the decoupling network employs significantly large number of Park's transformation, due to which the computational complexity of these two PLLs is high. Furthermore, the two PLLs eliminate selected low-order harmonics and prior knowledge of which harmonics to be compensated is required. Consequently, the performance capability under any uncompensated harmonics will be poor. Considering therefore that MSHDCPLL and DN $\alpha\beta$ PLL are computationally complex and restricted in compensating harmonics, the PLL algorithms based on moving average filter (MAF) present significant attraction [21-23]. The unbalanced faults and harmonic distortion of any order is compensated by MAF with less computational resources. This characteristic is an essential feature for real time implementation in limited size digital signal processors. The performance of MAFPLL is highly dependent on grid frequency nominal value (50 Hz for the scope of this paper). The simplest type of MAFPLL are developed in [22] by modifying the conventional dqPLL and dsrfPLL. They are referred to as MAFPLL and MRFPLL, respectively. The problem with MAF based PLL is that it suffers from significant offset error under the condition of off-nominal frequency (other than 50 Hz) [22, 24-26]. The problem of off-nominal error can be reduced by introducing a variable sampling rate for MAF window length in accordance with the varied frequency [22, 26, 27]. Variable sampling rate however is not considered practically possible as it restricts the operation of GSC controller. Furthermore, even if the offset error is eliminated, the presence of MAF in the control path results in slow dynamic response [26]. In addition, the presence of MAF in transfer function restricts the calculation of straightforward tuning parameter and stability analysis. The problem of offset error, slow dynamic response and complicated tuning procedure was recently overcome by EPMAFPLL, proposed in [24]. In EPMAFPLL, a pre-filtering stage is added to shift the MAF from phase detector part, thereby removing it from main control loop and improving the dynamic response. In addition, a modification is done to the rotating speed of SRF in PD for compensating the offset errors and the tuning calculation of controller comes out to be similar to that of a simple second order transfer function. The EPMAFPLL uses the dqPLL phase extraction algorithm in addition to other schematic. The only problem of EPMAFPLL is that it offers high frequency and phase overshoot at the time of fault because dqPLL algorithm is used for phase extraction.

The aforesaid problem motivated the development of new $\alpha\beta$ EPMAFPLL, which is the combination of EPMAFPLL and the conventional $\alpha\beta$ PLL. The proposed $\alpha\beta$ EPMAFPLL minimizes the overshoot in frequency by inheriting the lower frequency overshoot property of conventional $\alpha\beta$ PLL. In addition, the proposed PLL results in accurate phase extraction due to a modification incorporated for phase offset errors, similar to that of EPMAFPLL. Hence, the proposed $\alpha\beta$ -EPMAFPLL enables the fast operation of GSC under grid faults by keeping the frequency within the assigned limits of grid regulations. It is worth mentioning that the harmonic compensation proposed in this paper is able to compensate any harmonic present in the grid. Prior knowledge of what harmonics are present in the grid voltage is not needed and all the harmonics are eliminated with lower computational complexity. A detailed comparison for various PLLs is presented in appendix Table A.1.

Section II discusses the existing MAF PLLs and the associated problems. The proposed $\alpha\beta$ EPMAFPLL is discussed in section III and section IV presents the tuning procedure for proposed PLL. The performance comparison of proposed PLL with existing EPMAFPLL is presented in the results and discussion section V.

2. ANALYSIS OF EXISTING MAF AND EPMAF PLLs

2.1 Conventional MAFPLL

The structure of conventional MAFPLL is shown in Fig. 4. The MAFPLL exhibits slow dynamic response due to the presence of MAF in the control path. In addition, the closed loop transfer function of MAFPLL results in 4th order system, for which tuning process is complicated and is based on symmetrical optimum method. The slow dynamic response of MAFPLL is mainly due to the fact that there is a lower limit on the settling time (ST) that can be selected [22]. According to [22], for MAF window length of 0.01 sec, the ST of MAFPLL cannot be less than 0.028 sec (28 msec). If this occurs, a reduction in phase margin (PM) is observed (PM falls below 30°), thereby making the system unstable. Furthermore, the MAFPLL offers significant offset error in the estimated phase angle under off-nominal frequency, which is the main disadvantage.




Fig. 4: MAFPLL Schematic diagram

2.2 EPMAFPLL

Recently in [24], a new MAF based PLL algorithm has been proposed for improving the problems of slow dynamic

response, complicated tuning process and phase drift under off-nominal grid frequencies. In EPMAFPLL, two modifications are employed respectively for overcoming the problem of slow dynamics (simpler tuning) and compensation of offset phase error under off-nominal frequencies. The pre-filtering stage modification is introduced by making the control path free of moving average filter, shown in Fig. 5. Herein, MAF is inserted to pre-filtering stage and the input/output of MAF is rotated with an angle obtained from nominal frequency. However, for compensating the problem of offset error a simple modification incorporated to the speed of SRF in phase detector part. The transfer function of MAF and its phase and magnitude response are given by (1) and (2), respectively. It is important to notice that the speed of SRF frames in pre-filtering stage and phase detector stage are different from each other.

$$F_{MAF}(z) = \frac{1}{N} \frac{1 - z^{-N}}{1 - z^{-1}} \quad (1)$$

$$F_{MAF}(e^{j\omega T_s}) = \left| \frac{\sin(\omega N T_s / 2)}{N \sin(\omega T_s / 2)} \right| \angle -\frac{\omega(N-1)T_s}{2} \quad (2)$$




Fig. 5: The pre-filtering stage based EPMAFPLL

Where, T_s is the sampling time and $T_M = NT_s$ is the MAF window length. The offset error experienced under frequencies other than the nominal value is because the nominal frequency fundamental component behaves as a component of $\Delta\omega = \omega_{gd} - \omega_{no}$, where ω_{gd} and ω_{no} are the actual and nominal grid frequencies. The amount of phase error experienced by simple MAFPLL under off-nominal frequencies is calculated using (2) and is given by (3).

$$\angle H_{MAF}(z = e^{j\Delta\omega T_s}) = -\Delta\omega \underbrace{(T_M - T_s)}_{k_{\phi}} / 2 \quad (3)$$

The EPMAFPLL accurately compensates the error caused under off-nominal frequency with fast dynamic response. However, in case of unbalanced grid fault EPMAFPLL suffers from large value of frequency overshoot, which is observed at the instant when the fault occurs.

3. PROPOSED $\alpha\beta$ EPMAFPLL

The offset phase error of MAFPLL under off-nominal grid frequencies is overcome by EPMAFPLL [24]. However, the high frequency overshoot of EPMAFPLL at the time of fault may result in violation of frequency limits.

The problem of high frequency overshoot is alleviated by the proposed $\alpha\beta$ PMAFPLL which incorporates the $\alpha\beta$ PLL in the phase detector part of EPMAFPLL. The lower frequency overshoot characteristic of $\alpha\beta$ PLL helps in reducing the frequency/phase overshoot significantly. The phase angle in $\alpha\beta$ PLL is estimated using a trigonometric equation (4) and is valid for small values of $\Delta\theta$.

$$\begin{aligned} \Delta\theta &= \theta_{grid} - \theta_{\alpha\beta PLL} \\ \Leftrightarrow \Delta\theta &\approx \sin(\theta_{grid})\cos(\theta_{\alpha\beta PLL}) \\ &\quad - \sin(\theta_{\alpha\beta PLL})\cos(\theta_{grid}) \quad (4) \end{aligned}$$

To incorporate the phase error caused under off nominal frequencies $(-\Delta\omega(T_\omega - T_{sp})/2)$, it is added to the output of $\alpha\beta$ PLL phase detector. The resulting angle is being fed back to the sine and cosine part of extraction algorithm. This proposed modification to $\alpha\beta$ PLL results in compensation of phase error that appeared due to off nominal frequencies. The structure of proposed $\alpha\beta$ PMAFPLL is shown in Fig. 6.




Fig. 6: The proposed $\alpha\beta$ EPMAFPLL

As mentioned, the proposed $\alpha\beta$ EPMAFPLL minimizes the overshoot in phase and frequency estimation by incorporating the lower frequency overshoot property of conventional $\alpha\beta$ PLL and also results in accurate phase extraction due to a modification incorporated for off-nominal frequency phase offset errors. Hence, the proposed $\alpha\beta$ EPMAFPLL enables the fast and accurate operation of GSC under grid faults and also under off-nominal grid frequencies, by remaining within the assigned limits of frequency grid regulations.

4. TUNING PROCEDURE

The stability analysis and tuning of proposed $\alpha\beta$ EPMAFPLL is similar to EPMAFPLL. The small signal model for EPMAFPLL and $\alpha\beta$ -EPMAFPLL is shown in Fig. 7. The derived closed loop transfer function is given by (5).

$$H(s) = \frac{k_p s + k_i}{s^2 + \underbrace{(k_p - k_i k_\phi)}_{2\xi\omega_n} s + \underbrace{k_i}_{\omega_n^2}} \quad (5)$$

According to [24], the transfer function is stable under the constraint $0 < k_i k_\phi < k_p$. The tuning of (5) is very simple and straightforward, as it is a second order transfer function. Following the control theory, the calculated PI controller's

tuning parameters in terms of desired settling time (T_{st}) are given by (6), where ξ is damping factor and for optimal response it is selected to be 0.707.

$$k_p = 2\xi\sqrt{k_i} + k_i k_\phi \quad \text{and} \quad k_i = (4.6/\xi T_{st})^2 \quad (6)$$




Fig. 7: Small Signal Model of $\alpha\beta$ /EPMAFPLL

5. RESULTS AND DISCUSSION

The performance of proposed $\alpha\beta$ EPMAFPLL is verified through simulations and experiments. The simulation based analysis is done using SimPowerSystem toolbox of *MATLAB*[®]. For experimental verification, a model equivalent to simulation setup is developed in the laboratory.

5.1 Simulation Results

The performance of proposed PLL is analyzed by comparing it with EPMAFPLL under different value of settling time, that is, slow (4T, T=20 msec), medium (3T) and fast (2T). During this analysis, the type of fault is fixed and only the effect of different settling times is observed. The tuning parameters for both PLLs are slightly modified for the purpose of this work due to the fact that the PLLs are investigated under grid voltage fault. However, the tuning parameters in (6) are in accordance to a step change in phase angle. In this paper, the parameters are tuned in such a way that the frequency responses of both PLLs achieves same settling time when an unbalance fault occurs. The calculated values of tuning parameters are presented in appendix Table C.1.

The performance comparison of proposed $\alpha\beta$ PMAFPLL and EPMAFPLL is developed in the presence of unbalanced grid faults, voltage swell, voltage sag with phase jump, frequency variation and in addition, the performance of proposed PLL is tested in FRT operation of GSC. For all the cases, the frequency overshoot analysis is performed by maintaining the same settling time for both PLLs. For same settling time, the frequency overshoot of proposed PLL is lower, implying that it can be tuned for even faster response while maintaining the frequency limits. For all the plots the time of fault is at 1 sec. The voltage is measured from PCC which is the point between GSC and y/ Δ transformer (connected between GSC and grid for isolation). The pattern in which fault propagates after y/ Δ is considered according to [28].

5.1.1 Response under Single Phase to Ground Fault

The grid voltage is subjected to one phase to ground fault and the response of both the PLLs are analyzed under fast (Fig. 8), slow (Fig. 9) and medium (Fig. 10). Under all the cases of settling time, the overshoot of proposed $\alpha\beta$ PMAFPLL is less than the overshoot experienced by EPMAFPLL. The EPMAFPLL overshoot under the fast response is 2.4 Hz, under medium response 1.1 Hz and under slow response 0.66Hz. The highest value of overshoot for the proposed PLL is 0.75 Hz. The V^+ and V^- in Fig. 8 are the estimated positive (v_{dq}^{*+1}) and negative sequence (v_{dq}^{*-1}) magnitudes respectively obtained from the PLL. These components are used as feedforward terms for GSC control. The settling time Vs frequency overshoot is depicted in Fig. 11, validating the improved performance of proposed technique.




Fig. 8: One phase to ground fault (Fast Response 2T)




Fig. 9: One phase to ground fault (Medium Response 3T)




Fig. 10: One phase to ground fault (Slow Response 4T)




Fig. 11: Frequency overshoot Vs settling time analysis for one-phase to ground fault.

5.1.2 Response under Grid Voltage Swell

The responses of PLLs are compared under a voltage swell event. In this case, the grid voltage is subjected to a step change of 4pu at 1 sec. The response of both PLLs is depicted in Fig. 12, where lower frequency overshoot is observed for the proposed PLL.

5.1.3 Response under Voltage Sag with phase jump

In the event of a voltage sag with phase jump, the proposed PLL is also seen to have better transient response, Fig. 13. An unbalanced fault with a phase jump of 30° simulates this event and as observed, the frequency overshoot of proposed PLL is lower than the one of EPMAFPLL which reaches a value of 6 Hz.




Fig. 12: Overshoot under voltage swell of 4 pu.

5.1.4 Response under Grid Frequency Variation

The response of PLLs to a step change of -2 Hz in grid frequency is shown in Fig. 14. In this case, both PLLs are tracking the reference accurately without any overshoot.




Fig. 13: One phase to ground fault (With 30° Phase Jump)




Fig. 14: Frequency Estimation under -2 Hz Step Change

5.1.5 Two Phase to Ground Fault

The responses of EPMAFPLL and proposed $\alpha\beta$ PMAFPLL are also compared for two phase to ground fault under various settling times, as shown in Fig. 15. Similar to one phase faults, the overshoot of proposed $\alpha\beta$ PMAFPLL is lower than the existing EPMAFPLL.




Fig. 15: Frequency overshoot Vs settling time analysis for Two-phase to ground fault.

5.1.6 FRT operation of GSC with Advanced PQ Controller

The FRT operation of GSC is enabled by an advanced PQ controller capable of providing clean current references to the current controller. The advanced control technique enables the accurate injection of symmetrical and harmonic free pure sinusoidal current under grid faults and disturbances. In addition, the proposed control technique can be used for FRT operation of grid connected RES. The preconditions for FRT operation of GSC is that the converter should not disconnect in the event of grid faults and provide required amount of reactive power in order to support the grid [13, 29]. The current references are generated according to [30] and are given by (6).

$$\begin{bmatrix} I_d^* \\ I_q^* \end{bmatrix} = \begin{bmatrix} i_d^{**+1} \\ i_q^{**+1} \end{bmatrix} = \frac{2}{3} \frac{1}{(v_d^{**+1})^2 + (v_q^{**+1})^2} \begin{bmatrix} v_d^{**+1} & v_q^{**+1} \\ v_q^{**+1} & -v_d^{**+1} \end{bmatrix} \begin{bmatrix} P^* \\ Q^* \end{bmatrix} \quad (6)$$

where the v_{dq}^{**+1} are the estimated d and q axis voltages, obtained from proposed $\alpha\beta$ EPMAFPLL. $I_d^* = i_d^{**+1}$ and $I_q^* = i_q^{**+1}$ are the reference currents generated by PQ controller according to desired active P^* and reactive Q^* powers, respectively.

According to instantaneous power theory [20, 28, 30] the relation for active/reactive power delivered by GSC under unbalanced harmonically distorted grid voltage is given by (7) and (8), respectively.

$$p = \frac{3}{2} \left\{ \underbrace{\left[v_{dq}^{+1} \cdot I_{dq}^{+1} + v_{dq}^{-1} \cdot I_{dq}^{-1} + v_{dq}^h \cdot i_{dq}^h \right]}_{P \rightarrow \text{Non-Oscillating}} + \underbrace{\left[\begin{aligned} (v_{dq}^{-1} + v_{dq}^h) \cdot I_{dq}^{+1} + (v_{dq}^{+1} + v_{dq}^h) \cdot I_{dq}^{-1} \\ + (v_{dq}^{+1} + v_{dq}^{-1}) \cdot I_{dq}^h \end{aligned} \right]}_{\tilde{p} \rightarrow \text{Oscillating}} \right\} \quad (7)$$

$$q = \frac{3}{2} \left\{ \underbrace{\left[v_{dq\perp}^{+1} \cdot I_{dq}^{+1} + v_{dq\perp}^{-1} \cdot I_{dq}^{-1} + v_{dq\perp}^h \cdot I_{dq}^h \right]}_{q \rightarrow \text{Non-Oscillating}} + \underbrace{\left[\begin{aligned} (v_{dq\perp}^{-1} + v_{dq\perp}^h) \cdot I_{dq}^{+1} + (v_{dq\perp}^{+1} + v_{dq\perp}^h) \cdot I_{dq}^{-1} \\ + (v_{dq\perp}^{+1} + v_{dq\perp}^{-1}) \cdot I_{dq}^h \end{aligned} \right]}_{\tilde{q} \rightarrow \text{Oscillating}} \right\} \quad (8)$$

where, v_{dq}^{+1} is the positive sequence grid voltage, v_{dq}^{-1} and v_{dq}^h are negative and harmonic components, respectively. Similarly, I_{dq}^{+1} , I_{dq}^{-1} and I_{dq}^h are respectively positive, negative and harmonic component of currents.

However, by using the current references given by (6), the oscillations in active and reactive powers are reduced, as shown by (9) and (10). The vectors I_{dq}^{-1} and I_{dq}^h become zero when (6) is used for reference generation.

$$p = \frac{3}{2} \left\{ \underbrace{\left[v_{dq}^{+1} \cdot i_{dq}^{+1} \right]}_P + \underbrace{\left[(v_{dq}^{-1} + v_{dq}^h) \cdot i_{dq}^{+1} \right]}_{\tilde{p}} \right\} \quad (9)$$

$$q = \frac{3}{2} \left\{ \underbrace{\left[v_{dq\perp}^{+1} \cdot i_{dq}^{+1} \right]}_Q + \underbrace{\left[(v_{dq\perp}^{-1} + v_{dq\perp}^h) \cdot i_{dq}^{+1} \right]}_{\tilde{q}} \right\} \quad (10)$$

The FRT control necessitates that the converter should not disconnect and provide reactive power support to the grid in the event of a fault. In some cases, the fault event may violate the converter's injected current limits. As a result, it might be necessary to limit the maximum assigned converter's current I_{dq}^{max} , by limiting the injected current to I_{dq}^* / i_{dq}^{max} to ensure safe operation of GSC converter. Furthermore, the injection of active power is reduced based on the amount of voltage sag and a certain Q/P ratio is calculated. Consequently, the resulting amount of reactive power is supplied for improving the stability of grid. The amount of reactive power under fault must be greater than the active power.

As mentioned earlier, the fast and accurate response of PLL affects the performance of GSC. The performance of PLL

directly affects the response of current and voltage controller, implemented in dq SRF frame. Therefore, the proposed $\alpha\beta$ EPMAFPLL is tested for fault ride through operation, as shown in Fig. 16.

Initially, the GSC is injecting a 2 kW of active power. However, at 0.9 sec, the active power is increased to a value of 2.5 kW. In addition, at 1 sec an unbalanced fault is applied and FRT mode of GSC is turned ON with a Q/P ratio of 3/1. The selection of Q/P=3/1 is an arbitrary ratio selected to justify the FRT operation (a more accurate value according to fault type can be obtained according to [7] or from reactive power profile). As can be seen from Fig. 16, after 1 sec the GSC injects reactive power to provide reactive power support and at the same time the grid current limits are maintained. The reactive to active power ratio as can be inferred from Fig. 16 is 1845/613. The GSC controller is responding efficiently to all the variations and disturbances due to accurate and fast estimation of phase angle.




Fig. 16: Performance of proposed PLL in FRT operation of GSC.

5.2 Experimental Results

The performance improvement of $\alpha\beta$ EPMAFPLL in terms of frequency overshoot compared to existing EPMAFPLL is also verified experimentally. The experimental setup is shown in Fig. 17. The experimental setup contains the real time controller, the programmable AC/DC sources and isolation transformer. The real time digital signal processor dSPACE DS1104 together with Matlab/Simulink Real Time Interface and dSPACE ControlDesk is employed for implementing the control algorithm of two PLLs. The California Instrument 2253iX programmable AC source is used to emulate the behavior of electrical grid. The renewable energy is emulated

as a DC source by employing the power supply (EA-PS-9750-20) of ELEKTRO-AUTOMATIK. The isolation transformer is used to provide real time isolation between the grid and RES system. The tuning parameters used for experimental verification are similar to those used for simulation results.




Fig. 17: Laboratory experimental setup.

For analyzing the behavior of PLLs, two experimental case studies under different working conditions are presented. In the first case study, the two PLLs are compared for a same settling time of 60 ms when a Type B fault with 50% voltage sag is applied. The initial value of all the three phases is equal in magnitude, however, a type B fault is initiated by producing 50% voltage dip in phase ‘a’ (point of disturbance marked in Fig. 18, subplot a). The three phase voltage waveform with 50% voltage sag and corresponding variations in estimated phase and frequency are depicted in Fig. 18 (b) and (c), respectively. It can be seen from Fig. 18 that the proposed $\alpha\beta$ EPMAFPLL suffers from lower frequency overshoot compared to conventional EPMAFPLL. The amount of frequency overshoot experienced by EPMAFPLL is 0.64 Hz, whereas the proposed PLL’s overshoot is only 0.072 Hz. Hence, the proposed $\alpha\beta$ EPMAFPLL is offering 9 times less frequency overshoot compared to existing EPMAFPLL. Furthermore, small oscillations are observed in the estimated phase of EPMAFPLL at the time of fault. On the other hand, the proposed PLL is free of such undesired oscillations.




Fig. 18: Experimental results comparing the performance of EPMAFPLL and $\alpha\beta$ EPMAFPLL under Type B fault.

The second case study analyses the behavior of both PLLs under grid voltage harmonic distortion. The grid voltage initially is a pure sinusoidal signal with zero Total Harmonic Distortion (THD). The grid voltage is injected with a +5th harmonic with a magnitude of 10% of fundamental frequency component, Fig. 19 (a) (disturbance indicated by red arrow). The three phase voltage waveform and corresponding responses of both PLLs are shown in Fig. 19. The MAF based PLLs are very efficient in terms of harmonic mitigation and the harmonic compensation capability of both PLLs are equivalent. The equivalent performance is due to the reason that both PLLs use

MAF at the same point in the topology, that is, right after the first SRF transformation. Thus, by introducing $\alpha\beta$ PLL in the phase detector part of PLL does not affect the harmonic mitigation performance of MAF based PLL.




Fig. 19: Experimental results comparing the performance of EPMAFPLL and $\alpha\beta$ EPMAFPLL under grid voltage harmonics.

6. CONCLUSION

The proposed $\alpha\beta$ EPMAFPLL presents significant improvement to the response of PLL in terms of low frequency overshoot under various kinds of faults, as verified through simulations and experiments. The harmonic mitigation capability of EPMAFPLL is not affected by the addition of $\alpha\beta$ PLL in the phase detector part, as proved from experiments. Furthermore,

the FRT control of GSC using the proposed PLL verified its accurate performance in a grid connected operation. Therefore, the proposed $\alpha\beta$ EPMAFPLL is considered the most favorable synchronization algorithm compared to the other PLLs. Consequently, the use of $\alpha\beta$ EPMAFPLL in the control of grid connected RES is an appropriate solution.

7. APPENDICIES

Appendix-A: Comparison of Various state-of-the-art PLLs

Various state-of-the-art PLLs are compared against the proposed PLL in terms of processing time, computational complexity, frequency overshoot and performance capabilities under abnormal grid conditions. The processing time analysis is performed in MATLAB using Matlab profiler report.

Table A.1: Comparison of various state-of-the-art PLLs.

PLL Algorithm	Processing time (ms)	Computational Complexity	Frequency Overshoot	Performance Capabilities		
				Unbalanced Faults	Harmonics	DC Offset
dqPLL	3.168	Very Low	High	No	No	No
$\alpha\beta$ PLL	3.132	Very Low	Low	No	No	No
ddsrfPLL	8.878	High	High	Yes	No	No
$d\alpha\beta$ PLL	9.694	High	Low	Yes	No	No
MAFPLL	2.981	Very Low	Low	Yes	Yes	Yes
EPMAF PLL	4.573	Low	High	Yes	Yes	Yes
MSHDC PLL	91.04	Very High	High	Yes	Yes*	No
DN $\alpha\beta$ PLL	29.41	Very High	Low	Yes	Yes*	No
Proposed PLL	4.532	Low	Low	Yes	Yes	Yes

*Eliminates specific selected low-order harmonics.

Appendix-B: Discrete Implementation of MAF

The discrete time implementation of MAF is based on (1) and is shown in Fig. B. 1, which requires only one subtraction, one addition and one multiplication. Hence it implies that MAF is computationally less complex. The lower complexity of MAF makes it most suitable candidate for real time implementation in the control algorithms.




Fig. B. 1: MAF discrete implementation.

Appendix-C: Tuning Parameters Table

The tuning parameters used in this paper are listed in Table C. 1. The tuning parameters are modified to present identical settling time under fault for enabling the frequency overshoot evaluation of two PLLs under same dynamic response. These tuning parameters are valid for per unit of the input voltage.

Table C.1: Tuning Parameters for both PLLs

Response Type	EPMAFPLL		$\alpha\beta$ EPMAFPLL	
	k_p	T	k_p	T_i
Fast	5132.1	0.00000236	3207.5	0.0000060
Medium	1041.9	0.00001476	694.60	0.0000369
Slow	850.67	0.00002126	531.674	0.0000531

8. ACKNOWLEDGEMENT

The authors Zunaib Ali and Nicholas Christofides are highly grateful to the Erasmus Mundus Leaders (EM-Leaders) mobility program for providing PhD fellowship. Authors Hadjidemetriou and Kyriakides acknowledge the financial support by the Cyprus Research Promotion Foundation, Project KOINA/SOLARERA. NET/0114/02, through the SOLAR-ERA.NET instrument (EU FP7).

9. REFERENCES

- [1] Transmission System Operator (TSO) Cyprus, Transmission and distribution rules - Issue 4.0.0 (in Greek), in, July 2013.
- [2] Technical Regulation TF 3.2.5 Eltra and Elkraft System, Technical regulations for the properties and the regulation of wind turbines. Wind turbines connected to grids with voltages above 100 kV, in, December 2004.
- [3] Transmission Code 2007, Networks and system rules of the German transmission system operators, in, VDN-e.v.beim VDEW, August, 2007.
- [4] J. Rocabert, A. Luna, F. Blaabjerg, P. Rodríguez, Control of Power Converters in AC Microgrids, *IEEE Trans. Power Electronics*, 27 (2012) 4734-4749.
- [5] Z. Ali, N. Christofides, L. Hadjidemetriou, E. Kyriakides, A Computationally Efficient Current Controller for Simultaneous Injection of both Positive and Negative Sequences, in: *Proc. IEEE ECCE Europe (EPE)*, 2017, pp. 1-6.
- [6] Z. Ali, N. Christofides, L. Hadjidemetriou, E. Kyriakides, Diversifying the role of distributed generation grid side converters for improving the power quality of distribution networks using advanced control techniques, in: *Proc. IEEE ECCE USA*, 2017, pp. 1-6.
- [7] L. Hadjidemetriou, P. Demetriou, E. Kyriakides, Investigation of different Fault Ride Through strategies for renewable energy sources, in: *PowerTech*, 2015 IEEE Eindhoven, 2015, pp. 1-6.
- [8] F. Blaabjerg, M. Liserre, K. Ma, Power electronics converters for wind turbine systems, *IEEE Transactions on Industry Applications*, 48 (2012) 708-719.
- [9] REN 21, Renewables 2015: Global Status Report (GSR), in, 2015.
- [10] REN 21, Renewables 2016: Global Status Report (GSR), in, 2016.
- [11] R. 21.. Renewables 2014: Global Status Report (GSR), in, 2014.
- [12] V. Kaura, V. Blasko, Operation of a phase locked loop system under distorted utility conditions, *IEEE Transactions on Industry Applications*, 33 (1997) 58-63.
- [13] R. Teodorescu, F. Blaabjerg, Flexible control of small wind turbines with grid failure detection operating in stand-alone and grid-connected mode, *IEEE Transactions on Power Electronics*, 19 (2004) 1323-1332.
- [14] S.K. Chung, Phase-locked loop for grid-connected three-phase power conversion systems, *IEEE Proceedings - Electric Power Applications*, 147 (2000) 213-219.
- [15] H. Guan-Chyun, J.C. Hung, Phase-locked loop techniques. A survey, *IEEE Transactions on Industrial Electronics*, 43 (1996) 609-615.
- [16] L. Hadjidemetriou, E. Kyriakides, F. Blaabjerg, A new hybrid PLL for interconnecting Renewable Energy Systems to the grid, in: *2012 IEEE Energy Conversion Congress and Exposition (ECCE)*, 2012, pp. 2075-2082.
- [17] L. Hadjidemetriou, E. Kyriakides, F. Blaabjerg, A New Hybrid PLL for Interconnecting Renewable Energy Systems to the Grid, *IEEE Transactions on Industry Applications*, 49 (2013) 2709-2719.
- [18] P. Rodriguez, J. Pou, J. Bergas, J.I. Candela, R.P. Burgos, D. Boroyevich, Decoupled Double Synchronous Reference Frame PLL for Power Converters Control, *IEEE Transactions on Power Electronics*, 22 (2007) 584-592.
- [19] L. Hadjidemetriou, E. Kyriakides, F. Blaabjerg, Synchronization of grid-connected renewable energy sources under highly distorted voltages and unbalanced grid faults, in: *Industrial Electronics Society, IECON 2013 - 39th Annual Conference of the IEEE*, 2013, pp. 1887-1892.
- [20] L. Hadjidemetriou, E. Kyriakides, F. Blaabjerg, A Robust Synchronization to Enhance the Power Quality of Renewable Energy Systems, *IEEE Transactions on Industrial Electronics*, 62 (2015) 4858-4868.
- [21] L. Shi, M.L. Crow, A novel phase-locked-loop and its application in STATCOM system, in: *North American Power Symposium (NAPS)*, 2010, 2010, pp. 1-5.
- [22] S. Golestan, M. Ramezani, J.M. Guerrero, F.D. Freijedo, M. Monfared, Moving Average Filter Based Phase-Locked Loops: Performance Analysis and Design Guidelines, *IEEE Transactions on Power Electronics*, 29 (2014) 2750-2763.
- [23] F.D. Freijedo, J. Doval-Gandoy, O. Lopez, E. Acha, Tuning of Phase-Locked Loops for Power Converters Under Distorted Utility Conditions, *IEEE Transactions on Industry Applications*, 45 (2009) 2039-2047.
- [24] S. Golestan, J.M. Guerrero, A. Vidal, A.G. Yepes, J. Doval-Gandoy, PLL with MAF-based prefiltering stage: small-signal modeling and performance enhancement, *IEEE Transactions on Power Electronics*, 31 (2016) 4013-4019.
- [25] M.A. Perez, J.R. Espinoza, M.A. Torres, E.A. Araya, A Robust PLL Algorithm to Synchronize Static Power Converters with Polluted AC Systems, in: *IECON 2006 - 32nd Annual Conference on IEEE Industrial Electronics*, 2006, pp. 2821-2826.
- [26] M.A. Perez, J.R. Espinoza, L.A. Moran, M.A. Torres, E.A. Araya, A Robust Phase-Locked Loop Algorithm to Synchronize Static-Power Converters With Polluted AC Systems, *IEEE Transactions on Industrial Electronics*, 55 (2008) 2185-2192.

- [27] I. Carugati, S. Maestri, P.G. Donato, D. Carrica, M. Benedetti, Variable Sampling Period Filter PLL for Distorted Three-Phase Systems, *IEEE Transactions on Power Electronics*, 27 (2012) 321-330.
- [28] M.L. R. Teodorescu, and P. Rodriguez, *Grid Converters for Photovoltaic and Wind Power Systems*, Wiley-IEEE Press, Hoboken, NJ, USA, 2011.
- [29] P. Rodr, guez, A. Timbus, R. Teodorescu, M. Liserre, F. Blaabjerg, Reactive Power Control for Improving Wind Turbine System Behavior Under Grid Faults, *IEEE Transactions on Power Electronics*, 24 (2009) 1798-1801.
- [30] Z. Ali, N. Christofides, L. Hadjidemetriou, E. Kyriakides, An Advanced Current Controller with Reduced Complexity and Improved Performance under Abnormal Grid Conditions in: *Proc. IEEE PowerTech*, Manchester, 2017, pp. 1-6.