of persons stripped to the waist and doing no work; and when once started this rise continues until symptoms of heat stroke arise, unless the person leaves the warm air. In the case of persons doing muscular work, the rise of body temperature is much more rapid and begins at a much lower wet-bulb temperature. It will, for instance, begin (in persons stripped to the waist) at a wet-bulb temperature of about 80° F. [= 26.7° C.] in still air with moderately hard muscular work, so that hard and continuous work is impracticable at wet-bulb temperatures of over 80° in still air. There is no doubt that when ordinary clothes are worn, serious rise of body temperature occurs at a still lower wet-bulb temperature. Soldiers marching in uniform are, for instance, liable to heat stroke at wet-bulb temperatures of under 70° F. [= 21° C.]."

Thus, while the problem of ventilation seems clearly to resolve itself into the problem of supplying to the individual moving air of such a temperature and such a content in aqueous vapor as to enable him to maintain his body in its best physiological condition, there still remain many physiological problems related to ventilation which press for solution. At what temperatures and what degrees of moisture do the really evil effects of bad air begin to appear? In what ways other than the rise of bodily temperature and the obvious symptoms do these evil effects manifest themselves? Here there are many possibilities: alterations of respiratory exchange, of relations of the oxygen to the haemoglobin of the blood, of the action of the heart, of the pressure of the blood in the arteries, of the course of fatigue, of the working power of the brain. It must be believed that the normal course of the body's metabolism is altered, but no one knows with any degree of exactness what the alterations are. Do a high temperature and a high humidity bear any relation to bacterial infection? What are the differences between temporary and prolonged exposure to these unfavorable conditions? Most of the experiments heretofore conducted have been of short duration, and few have extended for so long a period as even a whole working day. Still fewer have related to the exposure, day after day, for weeks or months, to an atmosphere that is only slightly unfavorable; yet it is probable that the evil effects of such an environment are cumulative. How are the effects of a high temperature and a high humidity altered by performing physical or mental work? At what temperatures and humidities can physical work and can mental work best be performed—in other words, under what conditions of ventilation can the highest physiological efficiency of the individual be secured? Ought these conditions to be varied, and if so in what way, according to the occupation of the individual concerned? Should, for example, the home, the schoolroom, the hospital, and the work shop have each its own ventilation standard and in what terms should these standards be expressed? These are some of the physiological questions to be answered by the investigation of the future. What we already know about ventilation and what we hope to know in the future, combine to make it clear, I trust, that, as was stated in my introduction, the problem of ventilation is fundamentally a physiological problem.

COLLEGE OF PHYSICIANS AND SURGEONS
NEW YORK CITY

MECHANICAL PROBLEMS OF VENTILATION

By D. D. KIMBALL

It is not my understanding that the subject assigned me refers to the details of the problem of working out a design for the ventilation of any building for any use, for such problems have become those of details only.

So far as this subject refers to the present wide-spread atmosphere of investigation into the general problem of ventilation it might almost be said that there are no mechanical problems unsolved in the field of ventilation; which is to say, the engineer

can provide any chemical or physical condition of the atmosphere of an enclosed space which may be required. The composition of the air may be maintained with any reasonable proportions of oxygen and CO₂ (and ozone too, if desired) and the air may be kept freer of dust and bacteria than the outside air. It may be maintained at any temperature or any degree of relative humidity, and it may be given any degree of movement or diffusion desired. Odors and dust of any kind and of any amount can be removed.

These are matters fully understood by the engineer, and practice and formulae are at hand for guidance along correct lines.

The chemical and physical properties of the air may be varied at will and within short periods of time. And all of this may be accomplished by the artificial ventilating system. It cannot be accomplished by natural ventilation.

But nevertheless, someone will rise to insist that these things are not accomplished and that, therefore, these statements must be those of theory and not those of accomplished fact. And on the surface it appears as though such a person would not be far from right.

Therefore, let us briefly consider the reason or reasons. It will not be contended that there are not a great many ventilating systems in use which are justly the subject of criticism, even serious criticism, nor that there are relatively few systems in use for which entire satisfaction may be claimed.

But again, let it be stated that this condition results, not because of the mechanical problems involved but for other reasons, serious and fundamental.

There is now no agreement as to which constitutes proper ventilation. Information is seriously lacking as to both the chemical and physical properties of the air which are most desirable. There are many chemical and physical phases of this problem which are of undoubted importance, such as oxygen, carbon dioxide, ozone, temperature, humidity, air movement, dust and bacteria, but in the case of no one of these elements is there entire accord among the Physiologists or medical men as to the effect of different conditions, except in so far as the trend of recent opinion seems to indicate that the physical, rather than the chemical, conditions of the air are of the greater importance, which is a reversal of earlier opinions. That is, temperature, humidity and movement of the air, and its freedom from dust, bacteria and odor are the first essentials of ventilation. Therefore, let the physiologist and medical men determine, by a continuance of the splendid studies and experimentation now going on, what are the most desirable atmospheric conditions. The engineer may then be counted upon to provide such conditions.

But decisions on these important matters must be well founded and may not be based upon insufficient investigations and inconclusive tests as have been so many of the recently announced views as, for instance, the oft reiterated pronouncements in favor of window ventilation. In the tests of this important phase of the ventilation problem, as recorded to date, the subjects have been in small classes under the care of specially selected teachers and nurses, with special diets, short study periods, exercise and rest periods, investigations and instructions regarding home conditions and with other details, all at variance with regular school practices, all of which doubtless materially affect the result, and yet the entire credit is given to the effect of the window ventilation. No consideration is given to the fact that proper window ventilation may be had upon but one or two sides of the building, and then only on the sides of the building which are favorably exposed, nor is any mention made of the enormous increase in the cost of maintaining the school system if such a system of school administration were applied to an entire city, such as New York.

In this reference to window, or natural, ventilation there is no intention to decry its use within proper limitations, nor as

an adjunct to the artificial ventilation system, which leads to the remark that a properly designed system of ventilation is not put "out of balance" by the opening of a window, the popular impression to the contrary notwithstanding.

Therefore, let the physiologists and medical men but come to an agreement as to the optimum atmospheric conditions and the engineer may be depended upon to produce just those conditions, IF, and herein lies the real problem of mechanical ventilation from the standpoint of the engineer, IF but a reasonable appropriation is made for the design and installation of the heating and ventilating system, and for its operation.

In the first place, not more than one plant in ten is designed, or laid out, by a consulting engineer. There may be, unfortunately, some practising engineers incapable of designing a system to meet modern requirements, but there are plenty of competent engineers. If a continuance of the unfortunate experiences of the past is to be avoided the owner must be made to realize that the design of a heating and ventilating system is no part of a plumber's work or an architect's work or training, for unfortunately some architects do not yet realize this fact and many architects prefer to entrust the design of the heating and ventilating plant to a friendly and willing contractor rather than to themselves pay the engineer's fee or to ask the owner to pay it. Result—the contractor lays out the work for his own benefit, is indeed glad to do so for the advantage which he may thus obtain over other bidders, the owner is without the expert services which he should have, and in the end he pays much more than enough extra for his plant and its operation than would have been required to pay directly for engineering services.

It is this class of engineering, also, which produces the most failures in ventilation work, the blame for which the engineer carries.

The cost of the best engineering services for the design and supervision of the heating and ventilating plant will vary from one-half to three-quarters of one per cent of the cost of the building.

A first-class engineer will produce savings in cost of installation and operation vastly exceeding this, and yet, but relatively few owners avail themselves of such services, while the wall against the inefficiency of the ventilating system goes on.

In the second place, in the case of nearly every building, the appropriation for the installation of the heating and ventilating system is reduced to the very minimum. Take, for instance, a school building. Usually a certain amount is appropriated for the building, then the committee selects its architect. If by competition, each architect strives to outdo the others in the size or ornamentation of the building which he offers to build for the amount appropriated. In any case the architect is usually confronted with the requirements of the committee, which requirements are from ten to twenty-five per cent in excess of what may be reasonably expected for the sum appropriated. And then begins the process of trimming, and the heating and ventilating plant, being the biggest single item of equipment, invariably comes in for the most attention and with the worst results. And this, too, despite the fact that the ventilating plant is really the lungs of the building and counts most for the comfort and efficiency of the building and its occupants. But, of course, there must be so many rooms, just so many gargoyles, and just so much marble. For these things are seen and read of all men. And thus the committee can point with pride to the size and beauty of its building and compare it with what a neighboring city secured for a similar sum.

Only recently an instance occurred where an expenditure of \$1,000 additional in the installation of the ventilating plant would have saved twice this sum in the annual operating costs but this could not be permitted because the money was needed by the architect for additional space in, or ornamentation of, the building.

The air washer, a most desirable adjunct to the school ventilating system, desirable because it eliminates dust, bacteria and odors and makes possible any degree of humidification, costing but approximately five per cent of the cost of the heating and ventilating plant, is rarely found in newly built school buildings, and solely because the school, or building, committee does not provide the means, or the architect, being forced to satisfy the committee as to the size or appearance of the building, cannot spare the money.

One of the most frequent complaints offered against the artificial ventilating system is that air of the same temperature is supplied to all of the rooms of the building, regardless of their exposure to sun and wind. Often a room on the sunny sheltered side of a building should have its entering air supplied at a temperature of from five to ten degrees less than the temperature of the air entering a room on the side of the building which is in the shade and exposed to a severe wind. But the common ventilating duct supplies the same air at the same temperature to all rooms. And this system is usually enforced because an extra expenditure of two to four per cent of the cost of the heating and ventilating system may not be permitted for the installation of a double duct system or an individual duct system, by means of which the temperature of the air may be regulated for each room according to its needs.

In the single, or common, duct system one duct leaves the heating chamber and branches to the vertical flue to each room. The double duct system has a second duct, carrying cooler air, directly under the above mentioned duct, also branching to the vertical flue to each room. Mixing dampers are provided at the base of each flue by means of which the mixture of warm and cool air entering the flue, and thus the room, is regulated by a thermostat in the room, according to its individual needs. In the case of the individual duct system, the most desirable but the most expensive, the duct for each room is carried back separately from the base of the flue to the heating chamber, which is, in this case, divided into upper and lower chambers, the air in the upper chamber having passed through all of the heating coils, and the air in the lower chamber having passed through but a portion of the heating coils. Connections are made from both chambers to each individual duct, with dampers in both connections arranged to operate in conjunction with each other, as controlled by the thermostat in the room, thus giving to each room air of a temperature suited to its needs, and without reference to the needs of any other room, either as to temperature or volume.

In the third place the difficulty of obtaining sufficient space for the installation of necessary apparatus and in obtaining suitable locations for ducts, flues, air openings, heating units and other details of the plant, places serious limitations upon the efficiency of the ventilating system, for diffusion of air and the resulting air movement are most important. The co-operation of the owner, architect and engineer are essential to the best results in this matter.

A further problem has to do with the standard of the janitorial service usually found in charge of the operation of heating and ventilating plants. Many well installed plants are rendered wholly inefficient by unskilled attention, and this despite the fact that the employment of a better class of operating engineers would result in a fuel saving more than sufficient to cover the extra cost of first-class and experienced men.

What has been said of the ventilation of schools applies with

equal force to hospitals, auditoriums, stores, factories and all other types of buildings.

In conclusion be it said that given authoritative standards, the employment of capable consulting engineers, a proper appropriation for the installation of the heating and ventilating system, a reasonable freedom to the engineer in the working out and in the application of his design, and skillful operation, and the engineer's problems in mechanical ventilation will have been overcome.

Without the consummation of these ends the splendid efforts now being made to solve the chemical, physical, physiological, psychological, efficiency and comfort problems of ventilation will have been wasted.

15 WEST 38TH STREET, NEW YORK CITY

INVESTIGATION OF SCHOOL AIR IN NEW YORK CITY

By CHARLES BASKERVILLE

The Public School System of Greater New York has to do with over 700,000 children requiring the services of about 18,000 teachers with an annual expenditure of approximately \$40,000,000. The Board of Estimate and Apportionment approves all appropriations, which to be available must subsequently be passed upon by the Board of Aldermen. A special Committee on School Inquiry was appointed by the Board of Estimate and Apportionment to look into the problem of efficiency of the entire school system, involving the child, its instruction, and physical environment.

The Committee desiring to utilize the equipment and services of some of the staff of the College of the City invited me to undertake the study of the air of the New York City Schools. The invitation was accepted after I had succeeded in securing the co-operation of my colleague, Professor C.-E. A. Winslow, who subsequently was selected as chairman of the New York State Commission on Ventilation.

Our work constituted a part of the investigation assigned to Mr. Chas. G. Armstrong, the engineer to the School Inquiry Committee.

A preliminary investigation was made during the spring of 1912 after the ventilating plants in those schools having them had been shut down. For this work \$750 was allowed. The work was continued, on our recommendation, in the fall of 1912 and winter of 1913, when the various ventilating systems were in operation, with a further expenditure of about \$7,500. Neither Professor Winslow nor I accepted compensation for our services in connection with the investigation. The money was spent for the services of assistants and special apparatus. Space admits only a very brief summary of our work, the full report of which is now in press by order of the School Inquiry Committee referred to.

Our problem was to determine the quality of New York air and if possible express an opinion upon the efficiency of the several systems of ventilation in operation in the schools, which might serve as a guide in making recommendations looking toward the re-construction of some of the school buildings, or, better operation of the systems already installed, and to advise as to future construction. We were able to meet these demands in part only, some reasons for which will be clear in what Professor Winslow will say in the last paper to be presented this evening. Other reasons are presented herewith.

The systems studied were (1), window system (designated the "open window" method by the lay press); (2), the natural system, where ducts were provided, but no mechanical means for insuring a flow of air in a desired direction or regulating the speed of the flow; (3), mechanical ventilation by means of fans with heating coils in the main duct; and (4), the last mentioned provided further with a washer, which also acted as a humidifier. In some, in fact practically all, schools investigated, where mechanical ventilation was the method used, the air was taken

in at or near the street level and not filtered, except in so far as in special cases, we may regard passing through a spray of water as filtration, which it undoubtedly is. In this connection, however, it is important to note that after it became known that we had begun the preliminary investigation—or perhaps it was coincident with our beginning—the Board of Education appointed a committee headed by Hon. John Martin, to study the matter of ventilation in the schools, which committee made a very common sense report, whereupon the Superintendent of Schools, Dr. Maxwell, not only authorized, but ordered, the teachers in the schools to open the windows in whatever school they might be, at any time they deemed it desirable, it mattered not what system was in operation or how efficient it might be operating, thus placing another duty upon the teacher already overloaded with responsibility. Our field squads encountered these and many other conditions in their work. Acting under orders they made their observations of existing conditions as they found them. Of necessity, the comparative value of our investigation from a refined point of view was materially lessened. However, what we did learn proved of no little value as will become apparent to one who studies the report.

Two fundamental facts presented themselves to us at the outset; first, the quality of the air of the city itself, and second, the quality of the air in different localities of the city.

When it is considered that the children are in school $5/24$ of a day for 5 days in a week for 8 months, that is to say, about 1000 hours of the total 8760 hours of the year, approximately $3/24$ of their existence, while the remaining $21/24$ of their time is spent in the streets, where the air is superior in certain ways and far inferior in others, and in their homes, where different features are better, but others worse, it becomes a matter of no small moment to recommend the expenditure of many millions of dollars for the installation of elaborate systems of ventilation involving the cost of maintaining them in operation when the heating plants are not going, as desirable as they may be, for the actual benefit derived.

The examination of all the 600 schools in New York was obviously out of the question, so under the advice of Mr. Armstrong, we selected 32 typical examples, ranging from modern and well managed fan-ventilated schools to older buildings in congested tenement districts, ventilated without fans, and including buildings of various sizes from one of the largest high schools to a four-room country school in Richmond Borough.

Ten of these schools were studied intensively, being visited once a week between December 2, 1912 and February 14, 1913, while the other twenty-two were visited on one or more occasions between February 14 and March 15, 1913. The latter group included some night schools.

The work was organized under three major heads, *viz.*:

- I. A study of the physical and chemical condition of the air.
- II. A study of the air distribution within rooms.
- III. A physiological study of "crowd poison."

I. *Physical and Chemical Condition of the Air*—Those factors known to possess more or less physiological significance only were considered. They were (a) Temperature, (b) Relative Humidity, (c) Carbon Dioxide, (d) Dust, and (e) Bacteria.

(a) *Temperature*—Over 1800 determinations were made, besides some 340 daily thermograph records obtained with 12 Tycos instruments located for various lengths of time, in different schools. The general results obtained by the sling psychrometer are shown in Fig. 1. The thermograph records will be referred to under "operation."

The data are expressed in the form of distribution curves, the abscissae representing the observed values in each case and the ordinates the percentage of all observations falling within the limits of values indicated below. It is evident that these records as a whole indicate very good conditions. The temperature curve centers closely, as it should, about $+68^{\circ}$ F. On the whole, this result must be considered highly creditable and an