NOTES ON THE BACTERIAL TREATMENT OF SEWAGE.

By STUART H. DAVIES.

ABSTRACT.

THE Author points out a growing tendency towards uniformity of opinion in some important directions, and indicates modifications in methods of working which seem to be demanded.

The points to which particular attention is drawn are (a) Residence in tanks, as a means of equalizing sewage, or as preparation for further treatment; (b) sludge reduction; (c) arrestment of suspended or irreducible matters.

(a) Prolonged residence in tanks is not generally necessary, either as arising from variation in the character of sewage or as productive of a change facilitating treatment in beds.

(b) While opinions as to the possible amount of sludge reduction have not been realised, such matter may be rendered inoffensive by the action of organisms under aerobic or anaerobic conditions.

(c) Beds must be effectually protected by the more complete removal of matters in suspension in the initial stages of treatment.

The great variety usually associated with sewage, together with the tendency which such variation may have in lessening bacterial efficiency are points which have been frequently insisted upon, but the success of attempts at purification in cases in which variation in character has been ignored or but little considered compel attention, as the results appear to show that failure has more frequently arisen from variation in flow than from variation in the nature of the liquid treated; and if we except towns where the sewage is frequently characterised by a strongly acid reaction, and bacterial life and development is of necessity small, so that equalisation or neutralisation *must* be resorted to, probably the question of large tank accommodation (with a view to equalising the sewage or as productive of a necessary change) will receive decreasing attention. In ordinary cases the organisms upon which we rely have shown themselves sufficiently elastic in their powers of adjustment and digestion, to deal with variations common to sewage. A purification of from 80 to 90 per cent. was effected in a few minutes on dissolved impurities at Leeds. The best effluents obtained on the works were those

from a Ducat bed, and good effluents were also assured by the triple filtration of more or less crude sewage.

Septic tanks have proved of great practical value in the finer division of suspended matter as discharged on to beds, and the better maintenance of capacity as contrasted with a process of simple sedimentation.

Sludge reduction may be materially aided by certain conditions. Concentration, temperature, and the provision of surfaces influence the result.

As to the more effectual arrestment of suspended matter, simpler and less costly means of attainment than those suggested appear necessary.

It appears necessary to keep the following aims in view:—(a) collection and concentration of sludge without undue interruptions to the flow of sewage; (b) more effectual arrestment of suspended matters and avoidance of clogging by improved methods of working rather than by elaboration in design; (c) resolution of sludge under an aerobic condition as productive of less offence and more rapid treatment.

For rapidity of treatment, the value of trickling-beds is evident; by this system a working capacity may be maintained for a considerable period, which may apparently be prolonged by systematic drying and washing out, as evinced by matter removed from beds of this character after resting. It is doubtful if the full value of surfaces in this respect can be realised apart from a period of stagnation; and despite the fact that contact-beds and trickling-filters have in the past been regarded somewhat in the light of rival methods of treatment, an approach towards a system of combined action seems possible. The difficulty of arresting matter which may cause clogging, in sedimentation or septic tanks, arising either from the weight of such matter, increased velocity, or evolution of gases, appears to point to an arrangement whereby suspended matter is arrested and resolved by a system of contact, leaving impurities in solution to be dealt with by a continuous flow; but in any system of contact preliminary to continuous treatment, the beds must be filled with a medium which can be readily washed, and provision must be made for the careful drawing off of the effluent by floating arms or telescopic weirs, and for the ample aeration of the beds.

To avoid unnecessary interruption to the flow of sewage, and to insure the more complete resolution of arrested matter, it seems desirable to curtail the period of contact as far as possible, and to prolong that of rest. This seems to be justified by the facts that the purity of an effluent resulting from a system of contact (in freedom from suspended matter) is largely effected during early residence; while the period of maximum activity in the destruction of solid organic matter in a contact-bed is that following on the drawing off of the liquid.

Under such a system deposited matter will probably show a lessened tendency to adhere to the medium in the beds owing to increased aeration, and the process of washing out will be facilitated. The indestructibility of the medium, the careful drawing off of the effluent, and facilities for washing out during times of storm, would become of importance.

Analyses of sludge taken from beds have frequently shown that matter has been carried forward (by accelerated flow and by the activity taking place in tanks) which should have been deposited, and removed from grit chambers.

Variation in flow is objectionable in connection with detritus tanks designed to retain the maximum amount of inorganic matter and the minimum amount of organic, and departure from a rate of flow which will secure this object must result in the release of insoluble matters with consequent loss of water capacity in tanks or beds, or the deposition of reducible matters which should be dealt with later.

Rules in the design of detritus tanks (such as a flow of 40 feet per minute irrespective of length of flow, or a capacity of 2 gallons per head irrespective of the form of tank) are of little value. A uniform rate of flow under varying discharges can be attained by adaptation of the form of tank. A tank to fulfil this purpose would be wide and shallow, and would need a stepped weir at the outlet-end, but the height of flow would afford an indication of the quantity of sewage to be dealt with on beds, the greatest possible head would at all times be available, and while the cost of construction and labour in cleaning must be greater than in some forms of tank, the advantages gained would justify it, the ill-effects of imperfect design in this particular being felt more or less throughout the process of treatment.

In large tanks the author suggests the possibility of emptying from below, screw-down valves being placed at intervals in the floor.

[*For Discussion on this Paper, see page 486.*]