STEAM BOILERS AND CHIMNEYS.*

THE RELATIONS OF GRATE SURFACE TO THE HORSE POWER AND
CHIMNEY DIMENSION OF STATIONARY STEAM BOILERS.

By ROBERT BRIGGS, C.E.

Some years since a Committee of the Franklin Institute, in a preliminary report upon the horse power of steam boilers, attached the largest importance to the extent of grate and adequacy of the chimney and flues, to burn the fuel; with a minor estimation of the value or effect of heating surface, only insisting that such surface should, by right, be capable of producing a certain economy of evaporation. These propositions were obvious, at least to one of the members of the committee, and were generally conceded by the others; so that no demonstration was then thought necessary; but it appearing at this time that these opinions should be supported by data, the following examination of the subject is offered:

Let it be supposed that there are taken, for examples, two plain cylindrical boilers, the first 42 ft. $\times$ 4 ft. diameter, and the second 22 ft. $\times$ 4 ft. diameter; each of these boilers are to have 4 ft. $\times$ 4 ft. = 16 square feet of grate, and the settings are to be so made as to take off 1 ft. at each end, so that 40 ft. long of the first, and 20 ft. of the second, will be exposed as heating surface, either directly

* JOURNAL FRANKLIN INSTITUTE, new series, Vol. xcii, (July, 1871), page 91.

to the fire, or to the gases of combustion. Let it be further supposed that each of these boilers have chimneys 70 feet in height, and $1\frac{1}{2}$ feet of cross area, and that baffling bridge walls be suitably built to insure contact of gases, and that in every respect, except the heating surface, the boilers be placed upon equality of arrangement.

The longer of these two boilers will then be a fair specimen of a plain cylinder boiler, of approved proportions, in all regards (except possibly the chimney section, the size of which will be qualified hereafter). The ratio of heating surface to grate surface will thus be 15 or 16 to 1, which is that usually adopted for boilers of this kind; it can, therefore, be confidently assumed that the grate of this boiler will burn with ease, *by good firing*, 12 pounds of egg or steamboat anthracite coal, exclusive of any ashes or cinders, per square foot of grate per hour; and that the heat proceeding from the combustion, will be absorbed to the extent, that the gases of combustion will escape up the chimney at about 450° Fah., when steam of 60 lbs. pressure, or 305° Fah., is generated from the water in the boiler.

In estimating the effects of combustion under this boiler, the total heat from a pound of the fuel may be taken at 15,000 units, less 10 per cent. for imperfect combustion, or 13,500 units, and the proportion of 24 pounds of air to each pound of combustible, will be accepted; and it will then be seen, after making up the figures, that the gases of combustion at 450° , air being taken at 60° , will carry off 2300 units of heat, leaving 11,200 units as the available quantity imparted to the boiler; or the equivalent to 11.6 lbs. of water evaporated for each pound of coal burnt upon the grate, supposing that no heat is lost in heating up the setting, or given out (lost) from boiler or setting.

If now it be admitted that one-fourth of the heat proceeding from the fire, is given out in the fire place by immediate radiation and conduction, to the boiler over the fire, it will be found by calculation that the temperature of the twenty-four pounds of gases of combustion, when passing over the bridge wall of the furnace, will be 1765° Fah. This supposition of the giving out of one-fourth of the heat by radiation is probably very close upon the existing fact for *under-fired boilers*, when the grate is far enough removed from the boiler for the proper ignition of the coal, and also of the evolved combustible gases between the surface of the coal and the boiler. For fire-box boilers, probably one-third the heat is dispersed in the fire box.

Taking, therefore, 1765° as the temperature of the gases passing the firebridge, and 450° as the temperature of the gases escaping into the chimney, and 305° as the temperature of the boiler, it results that the loss, or giving out of heat at any intermediate points in the length of the boiler (36 feet), will be proportionate to the differences of temperature at those points, giving the temperature of the flames or gases as follows :

At the fire-bridge,	1765° ,	20 ft. away,	711° ,
2 ft. away,	1589° ,	22 "	662° ,
4 "	1425° ,	24 "	619° ,
6 "	1300° ,	26 "	581° ,
8 "	1179° ,	28 "	548° ,
10 "	1073° ,	30 "	519° ,
12 "	980° ,	32 "	494° ,
14 "	900° ,	34 "	470° ,
16 "	828° ,	At the chimney,	450° .
18 "	766° ,		

It now remains to be shown what will be the effect of removing one-half of the convective surface of the boiler, or in other words, what happens, if the same grate, setting, chimney, etc., and equal *care* in firing, is applied to a boiler ; with 16 ft. length of shell, behind the bridge wall, in place of 36 ft.;—with a total length of exposed fire surface of 20 ft., in lieu of 40 ft. It is at once obvious that, without noticing any other effect of the change upon the process of operation, the escaping gases would enter the chimney at 828° , instead of 450° , causing a loss of 378° of heat at this point, which corresponds to the loss of 2255 units of heat above what before occurred, or about 20 per cent. of the total heat available for making steam from the fuel. But the effect of thus heating the chimney will be to increase the draft, and to accelerate the combustion ; and as the loss here stated, will appertain to any increased quantity of coal which may be burned, as well as to the normal quantity assumed for the 40 ft. boiler ; it will be requisite to demonstrate that 24 per cent. more coal will be induced to burn upon the grate by such increased draft, to provide the *same* quantity of heat to the water of the 20 ft. boiler, as was assumed for the 40 ft. boiler.

An examination into the conditions of the draft of chimneys shows some curious anomalies of figures. The source of power for the draft of a chimney is the difference of weight of the column of heated gases, as compared to that of the same column of atmospheric air,

(which is here assumed at the temperature of 60°). Between 450° and 900° , the velocity of efflux of gases of combustion, under the inducement of the pressure given by the difference of weight of the column, compared with that of air, is such that, in consequence of the increase of volumes at different heats, a very nearly constant *weight* of gases will be expelled for any given interval of time. The combustion of 12 lbs. of coal per hour, with a ratio of one-twelfth of a square foot of chimney to the square foot of grate, and with the supply of 24 lbs. of air to the lb. of coal, is equal to the passage of one pound of gases per second through a square foot of chimney. But a computation gives the time for the passage of one pound of gases, by the inducement of a 70 ft. high chimney :

At the temp. of	450°	500°	600°	700°	800°	900°
Time in secs., dec.,	0.401	0.397	0.393	0.394	0.397	0.401.

This gives the effective force of the chimney for passage of gases, neglecting all frictions or sources of resistance, as a constant of $2\frac{1}{2}$ times what is needed, [height $4\frac{1}{2}$ times greater than requisite].

Although the chimney is the source of draft, and its proper dimensions for the passage of the gases an essential element in the calculation, the resistances to be taken into account are : first, that of the entrance of air through the grate and coal ; next, that of the passage of gases over bridge walls, and around corners ; and finally, that of the chimney flue. Of these three the resistance of air supply to the grate and through the coal is much the largest.

It has been shown that for the supposed chimney and rate of combustion, two-fifths of the effective power of the levity of the gases will have been absorbed in giving motion to the gases themselves ; leaving three-fifths to overcome the other resistances. The rate of passage of the air through the grate, can also be estimated by the effect of the difference of the weight of columns, and the result proceeding therefrom, under differences of temperature, will be found quite different from that of the passage of the gases, as the density and volume of the air is constant, while the weight of the chimney columns vary. Upon the same grounds of combustion, chimney, etc., and with the assumption that the interstices of the coal are equivalent to the area of the chimney, (that is one-twelfth the area of the grate—a low estimate), the time of passage through the coal of the

24-25ths pounds of air, needed each second to burn the 1-25th pound of coal, is

For chimney temp. of	450°	500°	600°	700°	800°	900°.
Time in secs., decimals,	0·297	0·287	0·270	0·259	0·251	0·243.

This gives the effective force of the chimney, for the passage of air through the interstices of coal, when all frictions or sources of resistance are neglected, as a variable quantity, of from three to four times what is needed, [or an excess of height of this chimney of from 8 to 15 parts].

The proportions of chimney to grate, and combustion assumed, are those which have resulted from practice, *where the proper constant for resistance of passage of gases in the chimney or flues is not added*. If the cross area of the chimney is taken at 0·7 the area of the grate, divided by the square root of the height of the chimney, and a half square foot of area be added to equalize the frictions of the sides; an approximate rule for the least area desirable, will be obtained, for square or round chimneys, sufficiently accurate for practice. In treating of the capacity of such a chimney, for the flow of gases, or for inducing the entrance of air, the *constant* area should be neglected.

The rate of combustion, and the relations of temperature, all refer to the example here offered, and the excess of power of the chimney, both for passage of gases, and for entrance of air, is expended in the various resistances. It has been shown that at 450°, the gases formed in one second would pass, if free to do so, in 0·401 seconds, and the air enter in 0·297 seconds; while at 872° the gases would pass in 0·399 seconds, and the air enter in 0·247 seconds; it can, therefore, be safely assumed, that at 872°, more air could be made to enter and more gases pass away, in a ratio compounded from these figures; that is, as $0·401 + 0·297 : 0·399 + 0·248 :: 1·08 : 1·00$. In other words, about 8 per cent. more coal would be burned upon the grate if the chimney were heated to 872°, than if it were heated to 450°. Making a little allowance for the friction upon the reduced length of the boiler, the rate of combustion would be 13 lbs. of coal per square foot of grate per hour, in place of 12 lbs. This rate of combustion would, of course, increase the volume and velocity of flow of the gases, and each two feet length of boiler, at which the table of temperatures has been estimated, would become two and one-twelfth feet, and the gases would then, at the distance of sixteen feet

from the fire bridge, have the same temperature as they would have had with the primary velocity at the distance of fourteen and three-fourths feet. By interpolation, it will be found that this new temperature for the chimney will be 872° , as has been assumed.

The combustion of 13 lbs. of fuel, at 13,500 units, will give 175,500 units, the loss of heat up the chimney from the escaping gases at 872° ($= 812^{\circ}$, above original temperature of 60°) $= 10,556^{\circ}$, lbs. of coal $\times 5.94$ ($=$ specific heat of the 25 lbs. of gases to each pound of combustible) $= 62.703$ units; leaving 112.797 units as the result from the 13 lbs. of fuel. On the other side the combustion of 12 lbs. of fuel, at 13,500 units, will give 162,000 units; the loss of heat from escaping gases at 450° ($= 390^{\circ}$ above original temperature of 60°) $= 4680^{\circ}$, lbs. of coal $\times 5.94 = 27,799$ units; leaving 134,201 units. From this it appears that the removal of 20 feet from this boiler would impair its heating capabilities, *per square foot of grate*, a little less than 16 per cent.; and that thus the reduction of the total heating surface to 50 per cent. would be accompanied by the reduction of capability to 84 per cent.

The two suppositions, which produce this result, are: first, the giving out of one-fourth the entire heat, at the fire place; and second, the acceleration of maximum rate of combustion from 12 to 13 pounds per square foot of grate per hour. As to the first of these, no positive authority exists. Peclet ("*Traité de la Chaleur*") estimates one-half the heat of a fire, from some kinds of fuel, as what is given out by immediate radiation, when surrounded by surfaces of absorption, but his experimental furnace was a toy. Many imperfect experiments on a larger scale, have given for fire box boilers a temperature, for the gases back of the bridge, which would be equivalent by calculation, to the abstraction of rather over one-third of the heat of the fuel for this kind of surface; and it is thought by the writer that the assumption of one-fourth, is certainly *within* the actual dispersion of heat, for under-fired boiler furnaces. While the writer concludes, therefore, to adopt this ratio, he calls attention to it, that any reader may, for himself, value the effect of either increase or decrease in this proportion. As to the acceleration of rate of combustion by increased draft, the figures taken are unquestionably within the rate of actual occurrence. The largest resistance to the draft, is the passage of air through the coals upon the grate; and the assumption that there exists an equality of *resistance* between the coal passage and

the flue passage, on which this increase of coal burned from 12 to 13 pounds is founded, is as favorable to the *least* rate of combustion (or 13 pounds) as possible. [If the rate of combustion for the short boiler were taken at 14 lbs. (which would presume that about two-thirds of the surplus of velocity of the entrance of air was expended in meeting resistance of the coal passage), the heating capabilities of a square foot of grate of the short boiler, would become about 12 per cent. less than what belonged to the long boiler.]

The relative capabilities here estimated will not be materially changed if the heat proceeding from each pound of fuel is varied ; that is, if in place of 13,500 units, (12,000 units), or a less number be taken as the bases ; nor would a less rate of consumption than 12 lbs. materially change the result, after the same course of figures is gone through ; and in the same way the adoption of a smaller supply of air than 25 pounds to each pound of fuel, will only alter the calculations, without materially affecting the final ratios.

Recurring to the figures again : there are found 3375 units to each pound of coal, as given out in the fire box in any case ; and with the short boiler, where the escaping gases pass off at 872° , there is left 5302 units to be taken up by the 16 feet length (behind the grate) of heating surface ; while for the long boiler, with the escaping gases at 450° , there is left 7808 units to be taken up by its 36 feet of length ; and for the 13 pounds of combustion, on a square foot of grate, there is 64,285 units expended on 16 ft. long, in one case ; and 93,700 units on 36 feet long in the other.

With this data it will be possible to tabulate the result for boilers of other proportions of grate to heating surface ; noticing the following qualifications : first, the quantity of coal burned per square foot of grate is taken at 12 lbs. This quantity is a proper assumption for the given chimney for the amount consumed in the middle part of a grate surface (as a maximum) ; but it can be taken as a practical constant of allowance, that a deduction of two square feet of surface, from any total dimension of rectangular grates (of ordinary grate bars) should be made, to compensate for imperfection of cleaning out at the sides and corners. Thus the 4 ft. square grate, supposed as the basis of this inquiry, becomes practically but 14 square feet of efficient area, in lieu of 16 square feet ; or to make the combustion equal to the quantity taken, the grate should be increased in width (or length) to 4 ft. 6 in., giving a total of 18 square feet of surface, of which only 16 square feet

come into general average use. This last proportion (of 4 ft. 6 in. width) is, in fact, that generally used in setting a four feet plain cylinder boiler, although open to the grave defect of vertical sides for the fire place. It may be well to observe also that the efficiency of a grate falls off rapidly with increase of length, when over 5 ft. long; and in some degree, when over 4 ft. long. A second qualification is to be made in the chimney or flues cross area. The resistance of passage of the gases in the chimney and flues, is mainly that of the elbows and alterations of section, while it is partly that of friction against the sides. The efforts of writers upon the subject of dimensions of chimneys, have been directed towards *estimating* the value of these resistances, and reducing them to some ratio of the force of draft induced by the heated gases. Owing to the variety of conditions and the divergencies of arrangement and construction, no satisfactory figures have resulted from this course of investigation; and the method offered in this paper is confidently presented as a general one, avoiding much abstruseness of calculation, which can be founded solely upon several assumptions with little basis. But the frictional resistance of long passages is a definite one, and bears a relation to length and to perimeter, and can, therefore, be approximately compensated for or equaled by some ratio or proportion of increase of area. It is proposed to do this by a *constant*, for all areas and heights of chimneys; and an investigation could be made to demonstrate the approximate correctness of the procedure, within the limits of the usual proportions of flues and chimneys for boilers; but such an inquiry would scarcely be interesting reading. If there be added to the cross sectional area of a square chimney of any size or height, one-half a square foot, the resistance of friction will have been reduced to a practical equality of ratio, and the *effect* of the draft due to the height, may be taken as independent of the different surface frictions. The actual area of chimney flue then appertaining to the 40 and 20 ft. boilers, which have been made examples, becomes 1.83 square feet, in place of the 1.33 square feet, on which the figures were based. These two corrections are both in the same direction, and in one way the constant of half of a square foot of chimney may be said to supply the area needed for the constant of two square feet of grate. The effect of the constants upon the final ratios is, however, very different.

TABLE

of evaporative capability of one square foot of grate surface of, and of evaporative efficiency of the fuel burned, under plain cylinder boilers; with surfaces in different proportions to their grates and chimneys—example of 70 ft. high chimney with chimney section = one-twelfth grate area—13,500 units of heat, assumed to be produced by the combustion of one pound of anthracite coal, (= 15,000 total, less 10 per cent. for imperfect combustion).

Whole length of boiler exposed to the fire.	Length of boiler behind the fire bridge.	Quantity of coal burned per square foot of grate.	Temperature of gases escaping up the chimney.	Units of heat imparted to the boiler	Ratio of capability of one sq. ft. of grate, taking the capability of the 40 ft. boiler as unity.	Ratio of efficiency of one pound of coal burned upon the grate, taking the efficiency of the 40 ft. boiler as unity.	Ratio of total heating surface per sq. ft. of grate, assuming 1' 6" diameter of shell exposed. Grate = to unity.
40	36	12.0	450°	134,200	1.00	1.00	16.0
38	34	12.1	470°	133,180	0.99	0.98	15.2
36	32	12.2	511°	131,960	0.98	0.97	14.4
34	30	12.3	546°	130,520	0.97	0.95	13.6
32	28	12.4	583°	128,840	0.96	0.93	12.8
30	26	12.5	623°	126,900	0.95	0.91	12.0
28	24	12.6	666°	124,680	0.93	0.89	11.2
26	22	12.7	712°	122,160	0.91	0.86	10.4
24	20	12.8	761°	119,320	0.89	0.84	9.6
22	18	12.9	815°	116,240	0.87	0.81	8.8
20	16	13.0	872°	112,700*	0.84	0.78	8.0
18	14	13.1	934°	108,780	0.81	0.74	7.2
16	12	13.2	1000°	104,460	0.78	0.71	6.4

* Reduced 97 units in preparation of table.

Although the investigation contemplated by the title of this article is finished by this table, the relation of cross area of chimney to grate has been shown to be involved in the discussion; and from the data given and accepted as the basis of the calculations, it is easy to tabulate results of even more general value than those pertaining to the relations of heating to grate surface, etc.; and the following table gives the area of cross sections of chimneys, for stationary boilers of from 6 to 40 square ft. surface, with square, or nearly square, grates; and with chimneys from 25 to 140 ft. in height; with the maximum quantity of coal the grates will burn, under best conditions, with such chimneys; and the nominal horse power of the grates calculated for 0.55 square foot of grate per horse power (after deducting 2 square feet of grate surface as inoperative).

TABLE.*

			PROPER SECTIONAL AREAS OF CHIMNEYS										
			for grates of various surfaces.										
Actual surface of grate.	Maximum quantity of coal burned per hour, at 12 lbs. per foot (less 2 feet of actual area).†	Horse power at 0.55 sq. ft. grate (less 2 ft.)‡	Height of chimney in feet.										
			25	30	40	50	60	70	80	90	100	120	140
6	48	7.07	1.06										
7	60	9.09	1.20	1.14									
8	72	10.91	1.34	1.27	1.16								
9	84	12.73	1.48	1.39	1.27	1.2							
10	96	14.54	1.62	1.52	1.39	1.3	1.23						
12	120	18.18	1.90	1.88	1.61	1.5	1.41	1.34					
14	144	21.81		2.03	1.82	1.7	1.59	1.50	1.44				
16	168	25.45			1.93	1.9	1.77	1.67	1.60	1.53			
18	192	29.09				2.1	1.96	1.84	1.75	1.68	1.62		
20	216	32.72					2.14	2.00	1.91	1.83	1.76	1.65	
22	240	36.36						2.17	2.07	1.98	1.90	1.78	1.66
24	264	40.00							2.22	2.12	2.04	1.91	1.78
28	312	47.27								2.27	.32	2.16	2.01
32	360	54.54									2.60	2.42	2.25
36	408	61.81										2.67	2.47
40	456	79.08											2.71
1 ft. grate without constants.			0.1400	0.1278	0.1107	0.0990	0.0911	0.0837	0.0783	0.0738	0.0700	0.0639	0.0582

* The figures given in this table can be referred to coal burned, when less quantities than 12 lbs. per square foot are burned, by taking the actual quantity burned in the second column, and finding the corresponding area of chimney, independent of the grate altogether.

† The quantity of coal *shoveled upon the grate*, in yielding the nominal horse power assumed, will have been 10-12ths that given as maximum in this column.

‡ This ratio of 0.55 square foot of grate is supposed to represent the evaporation of one cubic foot (59.48 lbs.) of water from and at 212° per hour, or 57,458 units of heat, and consequently only 104,447 units of heat are assumed to result from the fuel burned on each square foot of grate. The maximum figures given in the table for the 40 ft. long boiler, burning 12 pounds of coal per hour, is 134,200 units, a figure 22.2 per cent. in excess of this assumption as data for horse power. This difference can proceed either from less perfect combustion or less active firing—probably the latter; and if so, the average combustion will have been taken at 9½ lbs. of coal burned per square foot of grate, or about 10 lbs. of coal shoveled into the fire per hour—a supposition not far removed from the desirable rate, from which should be estimated the production of a horse power, with certainty and ease, with the use of any kind of coal.