light may be completely diffused I make use of frosted glass only.)

The selection of a lamp by no means completed the solution of the problem, since no reflector on the market would focus its rays as desired. Experience had shown an illuminated field of 18-inch diameter, 7 feet from the source of light, to be highly useful. With these data in mind, Professor Waldo, head of mathematics at Washington University, was good enough to plot the curve of an ellipsoidal reflector which permits one to use in the desired manner about five-sixths (some 300 degrees) of the rays emanating from this lamp. Mr. Edwin F. Guth's enthusiasm led him to "spin" these reflectors for me, purely as an experiment; and thus

Fig. 2.—Eight lights grouped at a distance of 7 feet from the operating-table.

the cooperation of several workers resulted in a solution of the problem.

These ellipsoidal mirrors are 12 inches in diameter by 9 inches deep, dimensions which render them unwieldy, when taking the number used into consideration; hence a depth of but 6 inches is now advised. The slight loss in illumination is of no consequence since the supply that remains is more than abundant.

The accompanying illustrations will give a better idea than can any verbal description of the way in which light from eight sources, in a 6-foot circle, may be made to meet at an angle of 45 degrees on the field of operation. A group of eight other 40-watt lamps set in

the ceiling plate takes care of the general room illumination.

The apparatus made up in white enameled steel tubing harmonizes perfectly with other operating-room furniture. Two sets, somewhat modified to surround rectangular mirrors, may be seen at the Mayo clinic, Rochester, Minn., at the present time.

I cannot better state the demonstrated advantages of the contrivance than by quoting from the article mentioned in my opening sentence, naming some of the desirable features which it seemed to possess when installed as an experiment:

When six automobile head-lights, situated at different points, are focused on a given field, it stands to reason that the illumination is intense and that in this manner shadows are practically done away with. The source of the light is so near the ceiling that no heat from it is noticeable at the level of the operator's head. The globes are frosted and a soft, diffuse glow results. The satisfaction of having a known quality and constant quantity of light at all times is one which will not be fully appreciated by the operator who has not been in possession of it. The fact that beams of light from six sources meet at an angle of more than 45 degrees naturally cuts out all the shadows which obscure the depths of certain wounds. This will be especially appreciated in certain common-duct operations, pelvic procedures, attempts to reach the root of the gasserian ganglion, and others of like nature.

400 Metropolitan Building.

OPERATING DEPARTMENTS FOR MODERN HOSPITALS

WHICH PROVIDE FOR SPECTATORS WITHOUT DISTURBING THE HOSPITAL SERVICE AND PERSONNEL

JOHN R. McDILL, M.D.

Associate Professor of Surgery, Rush Medical College, University of Chicago

MILWAUKEE, WIS.

Clinical surgeons owe to their results as well as to their students, visitors and guests, facilities for observing their work that do not conflict or interfere with the operating-room technic. These advantages, when provision for them is attempted at all, are usually annulled by a mixing of all parties, to the discomfort of most of those concerned and the detriment of the patient. Since the custom of visiting the work of other surgeons has become so well established, this glaring defect is strange in these days of striving for perfection in operating arrangements when it can be so easily remedied.

The new operating departments which are being added to old hospitals, and all of the new institutions, should provide the best possible facilities for visitors, so arranged that they may come and go in the clinics without friction of any sort, and without being gowned.

This can be accomplished by a separate and preferably outside entrance and exit for all not connected with the hospital. This entrance and exit should lead into a room provided with water cooler, telephone, closet, and lavatory conveniences, which serves as a cloak-room and lounging-room; here the visitor should find a bulletin of the operations scheduled for the day, and each case should show the hospital number, so that one can write afterward and ascertain the result in cases in which one is specially interested. This room should connect with the space reserved for spectators,

TRANSVERSE SECTION

LONGITUDINAL SECTION.

Fig. 1.—Operating pavilion of the Philippine General Hospital, Manila, P. I., of which Dr. McDill was formerly chief surgeon. Plan drawn by William E. Parsons, consulting architect, under the direction of Dr. McDill.

FIRST FLOOR PLAN

SECOND FLOOR PLAN

SCALE 1/4"=100'

0 1 2 3 4 5 6 7 8 Meters

Figs. 2 and 3.—Floor plans of operating pavilion.

and each such space should connect with every other operating-room in the building by bridges (Fig. 6) or galleries several feet above the operating-room floor, and by stairs to those below or above. The seating arrangements for these amphitheatres should never resemble the old type, with its enormous waste of space, designed for spectacular performances and modeled after a Roman coliseum or a Spanish *plaza de toros*. Each visitor up to 100 ought to be provided with a seat from 6 to 25 feet from the operating-table. The accom-

on the seat of and between the two men immediately below him. This breaks straight rows so that the head of the person below and in front does not interrupt the view of the one just behind and above him. Although the seats are hard and there is no pretense at comfortable backs the positions are not found to be irksome, and the level space above allows the spectator to stretch a bit and move about.

For small hospitals a four-foot space railed off along the outside walls of the operating-rooms and leading across the sterilizing or other intervening rooms will be ample in which to place observation stands, which will accommodate about fifteen persons each. These

GALLERY PLAN

Figure 4.

panying tracings (Figs. 1 to 4) are from a plan which has proved very satisfactory, and the vertical section shows how each spectator is provided with a seat close to the operator. From this seat, which can be reached through a special outside entrance, the visitor can retire at any time without disturbing the hospital service in the slightest, as can be seen on the floor plans. No chairs are provided, the visitors sit on the bare painted concrete benches or steps which are projected forward in such manner as to tier the rows of spectators almost vertically above each other. When these rows are filled, the feet of each man from the second row upward rests

Fig. 5.—View of one operating amphitheater showing the target of the Zeiss illuminating device containing eight distributing mirrors, each of which catches part of the shaft of light from the 30-ampere search-light, and reflects it to a corresponding mirror attached to the ceiling; thence they converge to the desired spot on the operating-table; only five of them show in this illustration, and the horizontal light distributing mirror for perineal work is concealed by the anesthetist.

stands are 30 inches wide, 66 inches high and 114 inches long.

Another feature which will commend itself to the clinic visitor is the entire absence of drop lights, cranes, and other apparatus, carrying reflectors, wires, head lights, etc., to block his view. The illumination, arranged particularly for teaching, is by the use of eight converging shafts of clear white electric light (Fig. 5), filtered through water and devoid of heat, which floods the operating field and its depths from as many angles, giving an intensive illumination, without shadows, and revealing to the man on the top seat

the smallest anatomic and technical details that formerly were visible only to the operator. We used the Zeiss device, which was kept in order by the agent under contract, and there was no noise, no heat, no eye-strain and no dust. This arrangement is for use during the day and makes the clinic independent of the weather and light conditions.

The plan here illustrated shows a special operating unit in a pavilion hospital with the outside entrance for visitors in a spiral stairway which is connected with the corridors uniting the pavilions on each floor level. One corner of the operating-room was cut off in order to place the operating-table so that the spectators would be near to both sides and to the end of the table. As recovery-rooms were provided in each surgical ward building, no space for this purpose was set aside in the

FRACTURE AND ORTHOPEDIC TABLE*

GEORGE W. HAWLEY, M.D.

BRIDGEPORT, CONN.

This table has been designed to provide for the suspension and immobilization of the lower extremities and trunk, without moving or lifting the patient in any way, and to afford reliable support and traction of the lower limbs in the treatment of fractures.

As the illustrations show, this table (Fig. 1) has a flat top, in the center of which is placed a hip-rest, *D*, set practically flush with the surface of the table. The top is made in two sections. The smaller one, *A*, for the support of the head and chest, is mounted on four small wheels, so that it can be moved along the bars, *C*.

The longer section, *B*, rests on four short legs, which act as levers so that it can be lowered, leaving Section *A* and the hip-rest projecting (Fig. 2). A slot cut in the center of Section *B* provides for the passage of the hip-rest post through the folding top. Hanging downward from the foot of the table is a lever, *F*, which automatically locks the top when it is up. Pressing upward on this lever releases the lock. Close to this lever is a handle, *H*, by which the top is lowered and raised. The hip-rest is fitted with two perineal traction posts, a short one, *I*, and a longer one, *L*, with swinging arms from which a sling can be hung to support the knee or thigh and prevent sagging (Fig. 3). To the sides of the table frame are attached extension bars, *J* (Fig. 3), which can be placed at any degree of abduction. On the bars are foot-pieces to which the feet can be bandaged and traction applied.

It will be seen that this table is simple in principle and in construction. There are no gears, cranks or other complicated parts. Its operation requires no practice or instruction. The patient is placed on the table as for any operation or manipulation of the lower extremity requiring immobilization. After the manipulative or operative work has been completed, the legs are placed in the desired position and held there, either by assistants or by the extension foot-pieces (with or without traction). The top is then

lowered, leaving the patient securely suspended in convenient position for immobilization in plaster of Paris. It is only necessary before lowering the top to see that the patient rests properly on the hip-rest and head-rest. The latter, being movable, can be adjusted to suit different subjects. After the plaster has been applied the top is raised again to its original position. The feet may be fastened to the traction apparatus, if it is desired, for the purpose of steadying the legs or procuring extension.

USES AND ADVANTAGES

The uses to which this table is fitted are:

The application of plaster of Paris in the treatment of joint diseases, etc.

The treatment of fractures of the lower extremity by the closed or open methods as a means of obtaining strong, uniform traction, maintaining reduction and preventing displacement.

* Presented at the New York Academy of Medicine, Orthopedic Section, April 18, 1913.

Fig. 6.—Sterilizing and instrument-room between the two operating-rooms showing the high bridge by which visitors can pass quietly from one room to the other without conflicting in any way with the operating-room personnel.

operating pavilion. It was necessary to provide the large number of waiting-rooms because the patients who came to the clinics were of so many different nationalities.

470 Jackson Street.

What a High Infant Mortality Means.—A high infant mortality-rate is of grave moment not only on account of the pain, suffering, worry and economic loss it entails, but particularly because it is an evidence of the antenatal and postnatal environments to which those that survive are also exposed. The physical resistance and mental capacity of childhood, the moral stamina of adolescents, are directly influenced by the health and nutrition of the first two years of life. If we believe that the most valuable asset of this community is the health and character of its youth, we cannot longer question the urgency of making the conservation of infant life a special function of our municipality in a department of child hygiene in the city, county or state.—Julius Levy in Report of the Public Welfare Committee of Essex County, N. J.