SECTION II.

ENGINEERING AND ARCHITECTURE.

PAPERS AND DISCUSSIONS.

"The Treatment of Sewage by Chemicals in Perfect Solution,"
by HERBERT HENRY LAW, Assoc.M.Inst.C.E., F.R.Met.Soc.

(MEMBER.)

It has been long known to chemists that to ensure the most rapid and complete chemical reaction substances should be presented to each other in a perfect state of solution.

In the case, however, of the treatment of sewage by means of chemical reagents it is only recently that an endeavour has been made to carry out this principle in practice.

Lime is one of the substances most generally used for the treatment of sewage, and owing probably to its requiring seven hundred times its weight of water to perfectly dissolve it, it has been customary to add to the lime only sufficient water to form a thin paste, known as "cream of lime."

The disadvantages attending this mode of dealing with the lime, however, are manifold, namely:—

First. The lime, after being burnt, always contains foreign substances and portions imperfectly burnt, which are perfectly inert as far as chemical action on the sewage is concerned, and which are simply deposited with the sludge and add to its bulk.

Secondly. The consistency of the "cream of lime" is constantly varying, so that it requires the continuous attention of an attendant to endeavour as far as possible to regulate the quantity added to the sewage from time to time, but even with the best attention it is quite impossible to determine the actual quantity of lime being added at any given moment; sometimes it will be in excess of that required and sometimes the quantity added will be insufficient.

Thirdly. Owing to both the sewage and the cream of lime being more or less viscid the mixture between them is very imperfect, and it is certain that after even considerable trouble has been taken by agitation to promote a thorough admixture, much of the sewage will escape without having been brought into sufficiently intimate contact with the lime to produce any chemical reaction upon it.

There are two circumstances which make it very difficult if not impossible to insure the quantity of the chemicals bearing always the due proportion required to produce the same amount of purification in the sewage, namely, in the first place the difficulty of measuring the quantity of chemicals added: and in the second place the varying quantity and quality of the sewage.

The first of these difficulties is at once removed by adding the chemicals to the sewage in a state of perfect solution.

As regards the second difficulty so far as relates to the variation in the *quantity* of the sewage, this may be removed by the adoption of automatic means of so regulating the quantity of the chemicals added that they should always bear the same proportion to the quantity of sewage flowing. The variation in the *quality* of the sewage will depend upon several circumstances, some more or less regular in their incidence, and some entirely fortuitous. It is quite possible as regards the first of these to devise mechanical means for so automatically regulating the supply of the chemicals as to preserve a more or less constant proportion between them and the polluting matter in the sewage. But it is obviously impossible by self-acting means to provide for these fortuitous circumstances, such as sudden discharges of manufacturing refuse or heavy falls of rain which may occur at any moment unexpectedly.

At Oldham it has been determined to treat the sewage by chemicals in the state of saturated solutions, and an apparatus has been designed which will so regulate the quantity of the chemicals added to the sewage that under normal conditions it shall at all times bear the same proportion to the volume of the sewage arriving at the outfall works. And the means are also provided of altering this proportion at different times of the day and night should the difference in the composition of the sewage render it expedient to do so.

It is proposed to treat the sewage by the addition of lime and aluminio-ferric. After the sewage has passed through a screening chamber a portion of it is lifted by a centrifugal pump into one of two tanks, each capable of holding 300,000 gallons. The lime is first mixed with water in one of Michele's lime mixing machines, in which the insoluble matter which the rough lime may contain is separated and falls to the bottom while the lime passes out between two rubbing surfaces, which reduce it to the state of smooth cream. This cream of lime is injected into the suction-pipe of the pump in a proportion slightly in excess of that required to form a saturated solution. In its passage through the centrifugal pump the lime becomes thoroughly mixed with the water. The tanks being in duplicate.

als applied to Sewage.

Apparatus for Automatically regu

A. WELL IN CONNECTION WITH SEWER.

B. SEWER.

C. LIME WATER TANK.

D. ALUMINO-FERRIC TANK.

E. RECORDING DRUM.

GRAM OF

; the quantity of Chemicals applied to

while one is being filled, the other, in which the excess of lime has fallen to the bottom of the tank leaving a clear saturated solution of lime water, is supplying the same by gravity to the sewage as it arrives at the outfall works.

The alumino-ferric is used in the form of slabs or cakes, 21 inches by 10 inches by 4 inches, each weighing 56 lbs. A tank is provided sufficiently large to contain two balanced cages, each capable of holding 12 cakes, and so arranged that while one cage is immersed in the tank the cakes which it contains being in process of being dissolved, while the other cage is above the tank so as to be refilled with fresh cakes.

The alumino-ferric being very soluble, the solution in the tank is always maintained as a *saturated* solution.

The apparatus for automatically regulating the respective quantities of the solutions of lime and alumino-ferric is as follows:—

A well on the side of the main outfall sewer is connected with it in such a manner, that the water rises and falls in the well according to the varying depth flowing in the sewer, carrying with it a copper float three feet in diameter, to which is attached a copper band, the other end of which is wound round a drum, which consequently revolves in either direction as the sewage rises and falls in the main sewer, and the position of which at any moment depends upon the quantity then flowing.

The lime solution is conveyed by gravity to a tank on the side of the main outfall sewer, its flow being regulated by a floating valve. A vertical cylinder, eighteen inches in diameter, is connected with the tank, and within this cylinder a second cylinder fifteen inches in diameter is introduced, the space between the two cylinders being occupied by an india rubber ring, which permits the inner cylinder to rise and fall within the fixed cylinder, while it prevents the escape of the lime water. The upper part of the inner cylinder on the side next the sewer is formed as a weir, twelve inches in width. The inner cylinder is attached to a pulley, which is supported by a copper band which passes over a fixed pulley, and is then wound round a helical drum, fixed on to the same shaft as the drum which revolves with the rise and fall of the sewage in the outfall sewer.

The radius of the helical drum at any given point is so adjusted, that the quantity of lime water flowing over the weir at all times bears the same proportion to the quantity of sewage flowing at such times through the outfall sewer. To ensure this adjustment it is necessary that the relative positions of the level of the water in the tank, and the level of the lip of the weir should not be affected by any variation in the former,

which obviously must vary in accordance with the quantity of lime water passing through it at any given moment.

This object is effected by connecting the shorter arm of a lever with the float of the valve which regulates the admission of lime water to the tank, and by the connection of the other end of the copper band which passes under the pulley attached to the top of the weir cylinder with the longer arm of the lever. The respective lengths of the arms of the lever being in the ratio of one to two it will be seen that the rise or fall in the level of the water in the tank will cause an equal rise or fall in the level of the weir, and will not therefore affect the quantity of lime water flowing over the same.

The aluminino-ferric being very soluble, requiring less than twice its weight of water to form a saturated solution, the regulation of its flow is managed as follows. A copper band is wound round a small drum upon the same shaft as the helical drum, the other end of the band being attached to a conical spindle which passes through a circular hole in a thin plate in the bottom of a small tank which is fed from the larger tank containing the saturated solution of the alumino-ferric, and which is always maintained at the same level in the smaller tank by a ball valve. The quantity of the alumino-ferric discharged with any given position of the spindle is regulated by the diameter of the spindle at the point which is then level with the thin plate and so reducing or enlarging the area of the hole through which the solution is discharged.

The apparatus is also made to record continuously upon a paper diagram the height of the sewage flowing at any given moment through the outfall sewer. A band wound round a small drum on the same shaft as the drum, actuated by the float in the sewage well, is attached to a recording apparatus similar to an ordinary self-recording tide gauge.

The ends of the copper bands are so attached to the floats and levers as to afford the means of perfect adjustment.

The excess of lime which is deposited in the lime water tanks is run off into the chamber which receives the sludge from the precipitation tanks, and being mixed with the same, facilitates the process of pressing it.

In times of heavy rain, when the amount of rain water exceeds a certain limit, an adjustable stop prevents the further rise of the regulating float in the sewage well, and so limits the supply of the chemical solutions.

The variations in the quality of the sewage under normal conditions at different hours of the day depend upon the habits of the population, the extent to which manufacturing industries influence the sewage, and the leakage into the sewers. And

when these have been ascertained by careful observation it will be quite possible to arrange an automatic adjustment regulated by clock-work which shall approximately insure that the quantity of chemicals added shall be proportional to the quality as well as to the quantity of the sewage.

All that would be required would be that the intermediate pulley between the lever and the weir should be raised or lowered by a properly shaped cam revolving once in every twenty-four hours.

[*For discussion on this paper see page 495.*]

On "*The Purification of Sewage by Filtration*," by HENRY LAW,
M.Inst.C.E., F.R.Met.Soc.

(FELLOW.)

THE object of the present paper is rather to elicit than to impart information as to the conditions most favourable to the successful purification of sewage by filtration; and as to the means by which those conditions can be most perfectly fulfilled in practice.

The desiderata are—the permanence of the filter—the greatest possible removal of polluting matter—and effecting this removal in the least possible time.

Formerly it was supposed that filters acted simply *mechanically*, by only straining out of the water those foreign substances which were contained in it in a state of *suspension*.

It is, however, now fully established that the process of *filtration*, or the passing of impure water through a porous bed, not only arrests those foreign substances which are held by it in *suspension*; but that in those cases in which the polluting organic substances in *solution* have an affinity for oxygen, they are acted upon by chemical decomposition, and new products formed of an innocuous character.

And, yet more recently, it has become known that the agents through which this chemical decomposition and oxidation is effected are minute living organisms to which the name of *nitrifying organisms* has been applied while the process itself is termed *nitrification*.

The impurities contained in sewage always consist of matter both in a state of suspension and in solution.

So far as the substances held in suspension are insoluble the

process of filtration will be purely *mechanical*, and will consist in the detention within the pores of the filtering medium of the solid particles removed from the liquid which has passed through the filter. As this process is continued the pores must gradually become filled or choked up, and as this takes place the power of the filter to allow the passage of the liquid through it will gradually decrease until the time will arrive when it will cease altogether.

It is therefore evident that for a filter to possess *permanently* the power to purify sewage, it is necessary that the insoluble matters in suspension shall have been removed previous to its being passed through the filters.

This leads to the conclusion that liquid sewage should be deprived by precipitation of the insoluble matters held in suspension previous to its being passed through a filter.

If by previous precipitation the insoluble solid matters have been removed from the sewage, its subsequent purification by filtration will be effected by *oxidation* promoted by the *nitrifying organisms* existent in the filter, and it is the filtration of sewage under these conditions that it is proposed in this paper to consider.

Now the natural forces which are brought into action in the process of chemical filtration are in some respects antagonistic to each other.

In the first place we have the *attractive* forces, which may be divided into the *homogeneous* and the *heterogeneous* attractive forces.

The *homogeneous* attractive forces are those which exist between the particles of the same matter, and consist of the attraction of *gravitation*, and the attraction of *cohesion*. The attraction of *gravitation* being the force by which the particles of bodies not in contact tend to approach or gravitate towards each other; and the attraction of *cohesion* that by which particles in contact resist the effort to separate them.

The *heterogeneous* attractive forces are those which exist between the particles of dissimilar substances, and consist of the attraction of *gravitation*, the attraction of *adhesion*, *capillary* attraction, and *elective chemical* attraction or *elective affinity*. The attraction of *gravitation* is universal and exists equally between particles of dissimilar matter as between particles of similar matter. The attraction of *adhesion* is the force which resists the separation of two dissimilar substances which are in close contact, and can subsist between two solid substances, or between a solid and either a liquid or gas. *Capillary* attraction subsists between a solid and a liquid or gaseous substance. And *elective chemical* attraction or *elective affinity* is a force existing

between the ultimate atoms of dissimilar substances which causes them to intermix and results in a compound substance usually possessing properties entirely dissimilar from those of the substances from the union of which it has resulted.

In the second place we have the *expansive* force of the atmospheric air, which increases or lessens its bulk or density according to the pressure to which it is exposed.

When a liquid is subjected to the process of filtration these several forces are brought into action in the following manner.

The filter consists of a bed of greater or less thickness, more or less porous, and more or less pervious to the liquid to be filtered.

Owing to the force of *heterogeneous adhesion* each of the minute particles of which the filtering medium is composed has become *enfilmed* or surrounded by a film of atmospheric air, and by *capillary* attraction the small vacuities or pores existing between the several particles absorb and condense the atmospheric air in quantities dependent upon the amount of porosity and the nature of the substance of which the filter is composed. In the case of newly burnt animal charcoal the volume of air thus absorbed and condensed is equal to eight times the bulk of the charcoal.

The liquid to be filtered being passed on to the filter is caused, by the *attraction of gravitation*, or, in other words, by its *weight*, to pass through the filter; if *downwards*, the rapidity of flow will be proportional to the square root of the height of the column of the liquid, and if *upwards*, it will be proportional to the square root of the difference in the heights of the two columns; and consequently by varying the height of this column, or the difference between the two columns, the time occupied by the liquid in passing through the filter can be regulated.

As the liquid permeates the filter it is brought into close contact with the air which had been absorbed in the pores of the filtering medium, and through the intervention of the *nitrifying organisms* the organic matter is decomposed, and by *elective chemical attraction* is converted into new compound products which are innocuous, and being soluble are carried out of the filter in solution in the filtrate.

This process is continued until the air imprisoned in the pores of the filter is exhausted, when the further flow of liquid on to the filter is stopped, and that contained in the filter is suffered to drain away, making room for the absorption of fresh air. It is here that the *capillary* attraction comes into action as an antagonistic force, tending to retain the liquid in the minute pores of the filter.

The process of filtration is then suspended for a sufficient length of time to enable fresh air to be absorbed into the filter, and when this has been effected the operation is repeated.

The above is the method of filtration usually adopted, but Mr. Dibdin, the chemist to the London County Council, gives preference to a different mode of procedure. He considers that when the liquid is passed continuously through the filter sufficient time is not afforded for the *nitrifying organisms* to do their work, and he prefers to fill the filter with the liquid to be filtered until it just appears upon the surface of the filter, the channels for the escape of the filtrate having been closed. He allows the filter to remain in this state for an hour, and then runs off the filtrate, leaving the filter empty for about another hour.

The conditions which he lays down as those essential for the successful filtration of sewage or other foul liquid containing in solution but little free oxygen, and a large quantity of oxidisable organic matter are as follows, namely :—

“1. That the filter by cautious increments in the quantity of effluent, which in itself contains the necessary organisms, must be gradually brought to a state of high efficiency. This condition will be shown by the existence in the filtrate of a constantly increasing proportion of nitric acid.

“2. That the contact of the micro-organisms with the effluent to be purified must be effected by leaving such effluent at rest in the filter for a greater or less time according to the degree of purification required, the process being analogous to that of fermentation. The system employed in many places is to run the water straight through the filter and thus allow insufficient time for the work, with the result that the filtrate is soon in an unsatisfactory condition.

“3. That after each quantity of effluent has been dealt with the micro-organisms must be supplied with air, which is readily effected by emptying the filter from below, whereby air is drawn into the interstices. The filter must stand empty for an hour or more previous to another filling and a longer period of aëration, say twenty-four hours, must be allowed every seven or eight days.

“The life of a coke breeze filter worked in this manner is practically without a limit.”

One inconvenience attending the use of either of these systems of filtration is the length of time occupied in the draining off of the filtrate, and in the aëration of the filter. In practice it may be considered that the filter is only actually at work for something like six hours out of the twenty-four; and consequently that the area of filter beds which has to be pro-

vided is four times that which would suffice if the process could be carried on continuously.

A method has been suggested by Mr. Lowcock of continuously supplying the filter bed with air under pressure, and this system has been tried in America by Col. Waring, who has communicated the results of his experiments in a paper which has been published in the Journal of the Sanitary Institute.

If this system is successful and the time occupied by the liquid in passing through the filter is sufficient to allow of the perfect nitrification of the organic matter contained in the same, the process of filtration might be carried on continuously.

But there are many points upon which further information is required, amongst which the following may be enumerated:—

The best material for the filtering medium.

The size to which this material should be reduced.

Whether the filtering medium should be the same material, and of uniform size throughout its entire depth.

The thickness of filtering material which gives the best results.

The best method of distributing the liquid to be filtered, and of collecting the filtrate.

The best rate for passing the liquid through the filter.

The chemical treatment which would produce the best effluent for subsequent nitrification.

The best methods to be pursued for the cultivation of the nitrifying organisms.

The best method of precipitation for freeing the effluent from matter in suspension.

The best way of supplying air to the filter on Mr. Lowcock's system.

How far the variation of temperature affects the efficiency of the filtering process.

[*For discussion on this paper see page 495.*]

"The present status of Sewage Irrigation in Europe and America,"
by H. ALFRED ROECHLING.

(MEMBER.)

ALTHOUGH the question of sewage irrigation has been again and again before the scientific public and especially the members of the Sanitary Institute, yet the author ventures to think that that aspect of it with which he intends to deal may be new to some of his hearers. But apart from this the subject is of such

importance that it needs hardly an apology for introducing it again to-day.

What has perhaps more than anything else influenced the author in this decision is the attack that is more or less continuously carried on by all sorts of people against the application of sewage to land and which has recently been somewhat revived by the plea that sewage farms were capable of propagating infectious diseases.

The author, therefore, considers it might not be out of place to put on record the present status of sewage irrigation and the opinion held concerning it by those capable of forming independent and reliable opinions.

If such a review were, however, limited to this country only a restriction would be placed upon the subject, which appears quite unjustifiable, as this question is one of international importance. Every community, no matter in what state it may be, is confronted with practically the same difficulties, and it is, therefore, absolutely necessary, with a view to forming a correct opinion, to extend the range of observation as much as ever possible beyond this country. This the author purposes to do and he has endeavoured to obtain reliable information concerning other countries.

So far as this paper is concerned the term "sewage irrigation" includes all forms of applying sewage to land, as although the modes of application may differ the laws by which the purification in the pores of the soil proceeds are the same.

In passing it might be remarked, that sewage irrigation has been employed since the middle of last century. No doubt, originally an imitation of water irrigation—a method employed since very early times in countries like Egypt—sewage has been applied to land in Edinburgh, on the Craighentinn meadows, since 1760, and in Bunzlau, in Prussian Silesia, since 1740. Being, therefore, of such ancient date it is clear that this subject cannot afford a happy hunting ground for the ever active brain of patentees, and it has been suggested that perhaps the absence of strong capitalistic support has allowed the opposition voices to become stronger and louder in the same proportion as this treatment curtailed the usefulness of other patented methods probably thus proving the truth of the saying:—

"Early to bed and early to rise
Is of no earthly use, if you don't advertise."

These attacks have been carried out with such bitterness that people who had no means of critically examining the remarks of condemnation have been almost obliged to look upon the application of sewage to land as a thing to be avoided at any

cost. To throw some light into this conflicting mass of statements and to put some well established facts before his hearers and the public generally will be the author's endeavour, so that those who are called upon to study this question may have no difficulty of finding out for themselves the true state of the case.

GENERAL CONSIDERATIONS.

Broadly speaking the constituents of sewage were formerly divided into two main classes, viz.:—the organic and the inorganic matters, which were said either to be dissolved or suspended according to the state in which they were held in the liquid. Since the ever memorable researches of Pasteur and Koch, however, which have been continued and further extended by a host of other scientific observers, it has been established that sewage contains another constituent which is, perhaps, the most important one, viz., the germs, which are the lowest form of living matter.

We must, therefore, now adopt the following division of the constituents of sewage, viz. :—

1. The organized matter or germs.—Pathogenic and non-pathogenic germs, germs of putrefaction, &c.
2. The inorganised matter.
 - (a) The organic matter in suspension or solution.
 - (b) The inorganic matter in suspension or solution.

The germs, micro-organisms, microbes, bacteria, or whatever other name we may give to them, are suspended in sewage and their number generally reaches into so many millions in one cubic centimetre (c.cm). They are not all of one and the same species; on the contrary, the number of species represented is often as bewildering as the number of germs themselves, and up to the present time we have only been able to examine a very few of them, the life history of which we are endeavouring to trace. Very much more remains to be done in this respect, indeed we cannot even yet be said to have established a proper system of identification or classification of microbes. Be that, however, as it may, we know now for certain that the germs of such infectious diseases as typhoid fever and cholera may be found in sewage, and this is sufficient to make the proper treatment of sewage a subject of the greatest importance.

As to cholera, fortunately we may dismiss it from our considerations, as the germ of Asiatic cholera will be but a very rare inhabitant of sewage owing to the absence of this disease from our shores, but with the bacillus typhosus the case stands somewhat differently, as practically speaking isolated cases of this

disease occur in every large town throughout the year. The question, therefore, may well be asked, what becomes of the typhoid germ on sewage farms, has it been known to exert a baneful influence upon the health of those working and living on them?

It is, perhaps, well known that the late M. Pasteur up to about the year 1889 held opinions unfavourable to sewage farms as he was afraid they might act as propagators of the germs of infectious diseases.

The germs of typhoid fever, for instance, being as it were sown broadcast year after year over the land, the sewage fields might act as breeding places for them whence passing into the air they could be carried away by the currents to any distance.

Fortunately, these fears of Pasteur, based as they were on scientific observation, have never proved true in actual experience, and it is generally believed that towards the end of his life this great observer somewhat modified his views on the subject of sewage farms.

The author knows of no recorded case in which it has been proved in an unmistakeable manner, that a well managed sewage farm has acted as the focus of a typhoid fever epidemic.

Let us take the case of the Berlin Sewage Farms, which are the largest in the world, having now an area of 22,881 acres (31st March, 1895), and where one might fairly expect any evil results would show themselves in a more marked degree than elsewhere. Nearly every yearly report mentions that it has not been possible to establish a connection between a recorded case of death and the application of sewage to land, and the report for 1888-89 contains this remarkable passage:—"Especial stress must be laid upon the fact, that not one case of typhoid fever (typhus abdominalis), has been recorded during the year upon any of the farms, though the eastern and northern portions of the city were visited at the commencement of the year with a severe attack of this fever, this being the first epidemic of any extent since the establishment of the farms."

In the year 1891, some severe cases of typhoid fever in the neighbourhood of one of the northern sewage farms were said by a medical practitioner to have been contracted on the irrigated fields, and as this report caused some stir, the City authorities, under the guidance of Professor Virchow carefully investigated the complaints, with this result, that it was not possible to produce conclusive evidence in their favour.

Again, it was asserted that the typhoid germ had been washed off the land and conveyed through the effluent streams into the water supplied to the City of Berlin, there causing an outbreak of typhoid fever. It is needless to say it was not attempted to

support this theory by proof, as no trace of this germ was found in the water.

Further, a fear was expressed that typhoid germs might pass in a healthy condition out of the subsoil into the subsoil water, and then pollute the wells in the neighbourhood of the farms. With a view to ascertain the correctness of this surmise, the City authorities, and partly also the German Imperial Board of Health, investigated every suspicious case of disease most carefully, but were not able to identify the bacillus typhosus in any of the examined well waters.

Bearing all this in mind, one is forced to the conclusion, that the possibility of pathogenic germs doing further harm after systematic treatment on land is an exceedingly remote one, and probably some of the following causes are at work to bring about this fortunate state of things. Pathogenic germs appear to be more delicate than other germs, and probably perish very quickly in the struggle for existence with the countless host of other sewage germs; it is further stated that sewage is no favourable medium for this kind of micro-organism, so that it is not improbable that before their arrival on the farm, pathogenic germs are in a dying condition. On the surface of the land they are exposed to the decidedly injurious influences of the inclemency of the weather, and the bactericidal action of sunlight. On the whole, therefore, the chances of pathogenic microbes doing further mischief appear very small.

The foregoing remarks must be taken to refer to well-managed sewage farms, as the author is quite aware, there are a few sewage farms in existence on which the sewage is not purified. To single out, however, these farms and condemn in consequence the system itself appears on the face of it very absurd and very much after the fashion of the bad workman who complains of his tools. A good workman can do fair work even with indifferent tools, but when the workman is bad he will not be able to produce good work even with the best of tools. The author has seen sewage farms, where an intelligent management was capable of producing a fair effluent even under very unfavourable conditions, he has also seen farms where a good effluent might easily have been obtained, but where under a management deserving the name of gross mismanagement—everything being in a most neglected condition—the sewage ran off the land in almost a worse state than it went on and the pollution of the stream that took the effluent was the only possible consequence.

The first condition for a successful sewage farm is a suitable subsoil and the second, on which almost greater stress must be laid, is a careful and intelligent management. Every farmer

knows that an ordinary farm in order to prove successful must be well managed, much more so is this the case with a sewage farm on which the sewage must be purified all the year round independent of seasons and crops. It has often happened that after a sewage farm has been well laid out it has been handed over to the authorities, who not in the least understanding the difficulties of the case, and not wishing to trouble much about it themselves have appointed a very second-rate man, who had attempted to manage it after some rule of thumb fashion. The result could not be otherwise than disastrous, and the wonder is not that some sewage farms have failed, but that a far greater number of them have not failed. A sewage farm must be likened to a piece of complicated machinery that requires great care and skill in handling, otherwise it is sure to break down.

It is sincerely to be hoped, that in future more importance may be attached to the management of sewage farms, and to the proper and systematic education of sewage farm managers. In this respect the matter is well worth the attention of County Councils as they can adopt no better means of ensuring success than by taking the education of the future managers in hand themselves, and by closely watching the operations of the sewage farms in their counties. Indeed it has been stated and very properly too, that this matter is a question of national concern, and that the Board of Agriculture should through its inspectors exercise a close surveillance over all sewage farms. This appears all the more necessary in times when year after year vast tracts of land are passing out of cultivation.

PRESENT STATUS OF SEWAGE IRRIGATION.

In this country the importance which the Local Government Board attaches to sewage irrigation may be gathered from the fact, that it does not sanction, as a rule, a loan for the chemical treatment of sewage, without a sufficient quantity of land being obtained and laid out for the treatment of the effluent. In its opinion the chemical treatment does not remove a sufficient quantity of the dissolved organic matters, and as they must be abstracted, so as to prevent the pollution of streams, further treatment on land is necessary.

But perhaps in no other country have sewage farms made more progress than in Germany.

The largest of all the German sewage farms, and indeed of all the sewage farms of the world, are the Berlin sewage farms. Berlin had on the 31st March, 1893, a population of 1,662,114, and the sewage farms, which were commenced in January, 1876, with an area of 2,026 acres, have without interruption been

extended to meet the requirements of the City, until they have now reached (31st March, 1895) the huge total of 22,881 acres. Since the 1st day of January, 1876, there have been treated on these farms 143,809 million gallons of sewage,* and the City Authorities have spent on the farms alone, up to the present time, a little over £1,700,000, of which sum a portion has already been repaid.

It is interesting to note that four convalescent homes, (two for general patients and two for tuberculous patients) with 276 beds have been established on the Berlin farms, in which, according to the reports of the respective medical officers for the district, 2,077 persons were treated in 1895. The use of these homes increases from year to year, and the results obtained are very encouraging.

Besides the remarks already made as to the prevalence of typhoid fever, it should be stated that during the twelve months ending 31st March, 1895, only one death from this disease was recorded on the farms.

Before Berlin decided in favour of sewage irrigation, a system of chemical treatment had been proposed, but as this met with considerable opposition, the City Authorities decided to carry out a series of most elaborate investigations with a view to settle the question, which treatment ought to be adopted for the purification of the Berlin sewage. These investigations which extended over about fifteen years, were carefully reported upon in thirteen volumes, and were concluded in 1872 by a general report of Professor Virchow, in which, after carefully reviewing the then state of the question, sewage irrigation was recommended. His report has been carried out, and to-day Berlin has demonstrated the success of sewage irrigation on a very large scale.

The situation of the farms towards Berlin and towards other neighbouring centres of the population, is shown in the plan facing page 484, which is taken from the 1888 report of the Committee of the Senate of the French Republic.

Breslau, a town with 350,695 inhabitants, has next to Berlin the largest sewage farms in Germany, which were commenced in 1878 with an area of 1,554 acres, and have gradually been increased until they have now reached, by the purchase of another 1,873 acres, the total area of 3,427 acres. In the last report on the extension of these farms, the following interesting statement is contained:—

The cost (yearly working expenses and payments for capital

* 143,809 million gallons equal 642 million tons of sewage.

expenditure) per head of the population for chemical precipitation was in Frankfort-on-the-Main 1·22s., in Wiesbaden 0·68s., in Halle (without excreta) 0·80s., and in Essen (without excreta) 0·56s., whereas the cost of purification on land by broad irrigation amounted for the same unit in Breslau to only 0·44s., of which sum 0·22s. is chargeable to the pumping of the sewage. It is clear from these figures that the sewage of Breslau is considerably cheaper purified than the chemically-treated sewage of the other towns named, and that by adopting this system the city authorities are saving the ratepayers every year very considerable sums.

The first city on the Continent which established a sewage farm was Danzig, where in 1869 a farm of 1,236 acres was laid out for this purpose. Since that year the works have been in continuous use, and have always given complete satisfaction. Danzig has now a population of 123,690.

Freiburg in Breisgau—a town with about 55,000 inhabitants—purifies its sewage since 1890 on a sewage farm of 1,231 acres. Although the farm was at first strongly criticised, the results obtained by this treatment have been so satisfactory that it has now been decided to lay out further portions of the land already purchased for sewage treatment.

The City of Brunswick, which has about 100,000 inhabitants, has, after a great many difficulties, just completed the laying out of a sewage farm of 1,211 acres, and as the history of the sewage question in this town is very interesting and instructive, a few remarks concerning it may not be out of place.

After a great many proposals had been made the city authorities decided in 1887 to establish an experimental station for the chemical treatment of a portion of the town sewage. The results, however, were not considered satisfactory by the Government, which, in consequence, refused to give its sanction to this mode of treatment. Thereupon the City was compelled to consider the question of sewage irrigation, which again occupied several years, and a final settlement in favour of this treatment was only brought about in 1894, after the German Imperial Board of Health, through its medical inspector, Dr. Ohlmüller, had favourably reported upon the land scheme. This report deals very exhaustively with the whole question of sewage treatment, and is well worth a careful study.

Magdeburg, with a population of 226,410, is just about to complete the laying out of a sewage farm of 2,471 acres. The town is situated on the River Elbe, which carries a considerable quantity of water at all times, but as the Government would no longer allow the discharge of crude sewage into it, the city

authorities were compelled to purify the sewage, and this they ultimately decided to do on land.

Dortmund established chemical precipitation works for the treatment of its sewage in 1880, but the effluent was so little satisfactory that the town authorities are now compelled to further treat it on land. The population of Dortmund amounts at the present time to about 90,000 persons.

At Wiesbaden—the well-known watering place—the lime treatment has completely failed, and although the works have only been established a short time, the authorities, with a view to further avoid pollution of the stream which takes the effluent, are now about to conduct the latter in a cast-iron pipe line direct from the chemical works to the Rhine. The town has about 70,000 inhabitants.

Leipzig, which has a population of 397,860, is, according to the latest reports in the daily papers, again considering the question of sewage irrigation, although it abandoned this idea once and awarded three prizes for the best chemical scheme.

At Vienna, the capital of Austria, which has a population of 1,315,000, the authorities are in favour of utilising the town sewage on land and a committee of the Board of Agriculture has expressed itself strongly in favour of this treatment.

But, perhaps, in no other town has of late years the consideration of the best means of sewerage and sewage disposal led to so many public and private debates as in Paris, where these questions have been very hotly discussed until quite recently.

Paris has a population of over two and a half millions and although provided with sewers, employed up to now various forms of the conservancy method for the removal of all fœcal matters. No doubt it was at first thought that such an arrangement would admit of the contents of the sewers being emptied into the Seine, but pollution soon set in and in the year 1872 a portion of the sewage was for the first time utilised on 126 acres of land at Gennevilliers belonging to private owners. This treatment proved very successful and the area under sewage was from time to time enlarged until it has now reached a total of 1,945 acres. But as the land at Gennevilliers belong to private owners, is comparatively near to Paris and of limited extent only, the city authorities endeavoured to take the whole of the Paris sewage further down the Seine with a view there to purify it on land. However, for a long time they were not successful in obtaining the necessary parliamentary sanction for this course and it was only after the law of the 4th April, 1889, had been passed, that they could proceed in this direction. The next great step in the sanitary history of Paris is the law of the 10th July, 1894, which made the water carriage

system compulsory for the town, and clause fifteen of the bye-laws issued by the Prefect on the 8th August, 1894, renders the insertion of the disconnecting trap between house drains and street sewers obligatory. The authorities are now constructing an aqueduct of about nine miles in length from the pumping station at Clichy to the neighbourhood of Achères, where they have purchased 1,975 acres for sewage treatment. This scheme is so designed that the aqueduct can, when necessary, be continued further down stream so as to open up fresh areas for sewage irrigation.

From these remarks it follows that after a long and severe struggle, in which even M. Pasteur took part at one time as an opponent of the land treatment, the water carriage system pure and simple and sewage irrigation have been carried in the face of formidable odds.

The plan facing page 484 shows the position of the farms at Gennevilliers and in the vicinity of Achères in their relation to Paris and the neighbouring centres of population; it is taken from the 1888 report of the Committee of the Senate of the French Republic.

Concerning North America it is no doubt well known to the members of The Sanitary Institute, that the very excellent researches made at the experimental station at Lawrence of the State Board of Health for Massachusetts have led to an increased interest being taken in these questions and the following are some of the towns which have adopted the system of land purification:—Lenox, Amherst, Medfield, Framingham, Marlborough, Gardner, Westborough, and Brockton.¹

RECENT OPINIONS ON SEWAGE IRRIGATION.

It has already been stated that Pasteur at one time held opinions opposed to the purification of sewage on land, which were derived from his scientific researches, but that towards the end of his life the great savant—as is generally believed—somewhat modified his views on this point.

Professor Virchow, of Berlin, who as a member of the Berlin town council is intimately connected with the Berlin sewage farms, holds that sewage farms are in the interests of the public health desirable and excellent institutions.²

Professor Koenig, who is the director of the agricultural experimental station at Münster and who, as a chemist, has

¹ See Report of the State Board of Health for Massachusetts for 1892, page 557.

² See Th. Weyl's Paper:—*Beeinflussen die Rieselfelder die öffentliche Gesundheit?* page 6. Berlin, 1896.

given this matter his most careful consideration for years past arrives in his well-known book on the pollution of rivers at the following conclusions :—¹

“The most perfect purification of foul liquids containing nitrogenous organic matter *can*, *i.e.*, if done *correctly* be brought about by irrigation. (By this I do not mean to say, that for instance sewage irrigation is the only and most rational way of purifying and utilising fœcal matters; this entirely depends on conditions of locality and time; the most suitable disposal of fœcal matters is a question which I cannot touch upon at this point.)”

“Generally speaking, through chemical and mechanical means of precipitation or purification only the *suspended* matters can be removed; for just as little as we possess effective means for the precipitation of ammonia and potash, just as little do we possess such means for the removal of the *dissolved* organic matters. The precipitation of the dissolved organic matters can only to a limited extent be assisted by chemical agents of precipitation.”

Very much to the same conclusions as Professor Koenig came Allen Hazen, who investigated this matter in 1889 for the State Board of Health for Massachusetts.² He states, that in addition to the suspended matter from 22 to 41 per cent. of the dissolved matter were removed from the sewage by the chemicals (lime, copperas, ferric sulphate, and aluminium sulphate) employed by him, and in concluding his report he remarks :—“It is quite impossible to obtain effluents by chemical precipitation which will compare in organic purity with those obtained by intermittent filtration through sand.”

Mr. Dibdin, the chemist of the London County Council, expressed similar views in the discussion of the author's paper on the Berlin Sewage Farms, he remarked :—“Where sandy soil could be found for sewage irrigation, that method was no doubt the best. Ordinary precipitation processes, as he had before the honour of showing to the Institute (of Civil Engineers), would not remove more than a certain amount of the organic matters in solution.”³

Dr. Dupré is evidently of the same opinion, for in the discussion already quoted, he stated :—“He knew no one

¹ See *Die Verunreinigung der Gewässer* von Dr. J. König, page 74. Berlin, 1887.

² See Report of the State Board of Health for Massachusetts for 1890, page 784 and seq. Boston, 1890.

³ See the Berlin Sewage Farms, by H. Alfred Roechling, page 233, *Proceedings of the Institution of Civil Engineers*, Vol. CIX., Session 1891-92, Part III.

familiar with the subject who denied that the most effective treatment of sewage was by passing it through land, provided the land was suitable.”¹

Concerning the views held by Dr. Edward Frankland and the Local Government Board, it need hardly be repeated here that they are in favour of the purification of sewage on land.

The well known bacteriologist, Professor Carl Fraenkel, who has carefully examined these questions, states in an article on “Water Filtration and Sewage Irrigation,” as follows:—“In principle, therefore, the exclusion of all noxious matters from our watercourses is to be energetically insisted upon, and as the best means for obtaining this end, sewage irrigation must be recommended.”²

CONCLUDING REMARKS.

Innumerable further quotations might be made, but the few opinions mentioned will suffice to show, that of all methods of sewage treatment, sewage irrigation occupies a very prominent, if not the most prominent place, and that both leading bacteriologists and chemists have pronounced in its favour.

If the author be permitted to add his own testimony, he would like to say, that he has always been in favour of sewage irrigation, where the local conditions favoured this course, and he is glad to be able to state, that at Leicester a sewage farm of 1,700 acres on stiff clay and with steep falls, the laying out of which was designed by the late Mr. J. Gordon, has proved very successful under the direct management of a Committee of the Town Council. In proof of this the author would mention, that the Leicestershire County Council, which at first raised various complaints about the nature of the effluents, congratulated the Town Council in its last yearly report on the efficient way the sewage had been treated on the farm.

Whilst the author does not wish in the least to discourage other methods of sewage treatment, he believes to have shown that a one-sided condemnation of sewage irrigation is not supported by general established facts, but that on the contrary these facts are strongly in favour of the application of sewage to the land. In this respect he may be permitted to quote from a former paper of his, in which he stated:—“Much

¹ See the Berlin Sewage Farms, by H. Alfred Roechling, page 242, Proceedings of the Institution of Civil Engineers, Vol. CIX., Session 1891-92, Part III.

² See Wasserfiltration and Rieselwirthschaft by C. Fraenkel. Hygienische Rundschau Januar, 1896.

has been said and written for and against sewage farms, and the question whether chemical treatment or application to land is the better way to dispose of sewage has been fiercely discussed. The battle is still raging, though its din may perhaps be a little more distant, the public at large having grown weary of arguing this matter with no apparent likelihood of arriving at a satisfactory conclusion. The author is of opinion that there can be no general solution of this vexed question, and that a great mistake has been made in the past by over zealous advocates of the one or the other method, each party considering their own remedy to be an unfailing one in every case. These enthusiasts have thought that a success obtained in some particular case under special conditions could be anticipated under all circumstances, forgetting that like causes may not produce like results, if the conditions under which they have to work are not the same. The question is not so much whether sewage-farming or chemical treatment is theoretically the right way to dispose of town sewage, but rather whether in a particular case the one method is more likely than the other to give good results, as every case requires to be dealt with on its particular merits."

[*This discussion applies to the Papers by MR. HERBERT H. LAW, MR. HENRY LAW, and MR. H. A. ROECHLING.*]

Col. JONES, V.C. (Finchampstead), said with regard to Mr. Herbert H. Law's paper, that it described a most ingenious invention, likely to be useful in the way of applying precipitating chemical agents to the varying quantity of town sewage. He had on many occasions brought the want of such means of adjustment as an argument against the efficiency of precipitation works generally, from his practical knowledge of the extreme variety both in quantity and quality of the sewage to be dealt with. He had always complained of the difficulty of putting it into practice on a large scale. This ingenious arrangement, although it was complicated, appeared to him likely to work admirably, and to supply a great want where it was necessary to resort to precipitation. He then passed to Mr. Roechling's paper, which he hoped the members of the Institute would read carefully and study, because it was a mass of arguments against prejudice, which was most fatal to a right understanding of the sewage question in England. It appeared to him very ungrateful to find that all the pains that had been taken thirty or forty years ago, and since, in England, to work out the real facts about the sewage question, had been neglected and passed over of late years through simple inattention and want

of management of what they knew was the right thing. The Germans and the French had taken from us all the information, and had carried their works out systematically and properly, and with good results in consequence. He would draw attention to one point which was not mentioned in the paper, but which was arrived at from the accounts of the Berlin Municipality, and it was with regard to the manual labour of spreading sewage on those farms. It was that—taking a million of gallons per day of sewage—they pay fully three times the amount which he knew to be so expended on the best managed sewage farms in this country for spreading an equal volume of sewage. He did not think labour could be more expensive in Germany than in this country, and he attributed the better results in Germany to the high amount of labour expended on the actual spreading of the sewage over the land. The essential thing to practical men was that when the sewage was taken to the land it must be properly distributed, and therefore he thought that it was one of the most important points they could bear in mind in regard to this paper. Then he came to this prejudice which was everywhere opposing great difficulties to the proper systematic irrigation of sewage farms. M. Pasteur was an acknowledged authority, but he would like to point out that by 1889 he (M. Pasteur) had dropped the theory referred to in the paper. He had made careful investigations for certainly ten years or more before he dropped his old theory, which was only the theory of prejudiced people, viz., that to spread the germs of typhoid and other diseases about the land was a danger connected with sewage irrigation. They knew that in England, with all the badly-managed farms, no case of disease arising from germs in this way had ever been traced out, even in connection with the worst-managed sewage farms. He congratulated Mr. Roechling on his admirable paper, and he hoped it would be thoroughly studied.

Mr. E. G. MAWBAY (Leicester) said that this sewage farm at Leicester had been referred to in Mr. Roechling's paper, and it was referred to recently by a very able engineer as a great object lesson of success achieved on a clay farm under great difficulties. His very able predecessor, the late and much esteemed Mr. Gordon, had designed the main intercepting sewers at Leicester, the pumping engines, the rising mains, and the main carriers, and he (Mr. Mawbay) had had the honour of carrying out most of those works; but the preparation of all the land, the laying out and drainage of the farm and the carriers for about one-half of the farm had been designed and carried out by the speaker, which was about seven years ago. This scheme, in consequence of the density of the clay soil, was not advised by his predecessor, but it had been forced upon him on account of the great difficulties in obtaining the better kind of land which Mr. Gordon had recommended; and he therefore undertook the work with a very heavy heart. As it was clay land, and because it was considered impossible to go on successfully with the agricultural operations without sub-drains to drain the farm

in the ordinary way, a scheme had been prepared before his time with all the sub-drains connected with the trunk drains and the brooks. Then the great difficulty which occurred to his mind was, that if in draining in that way a clay farm which only had a foot of top soil as filter sewage cannot be filled in a less depth than about six feet of soil, it followed that the sewage would find its way into the sub-drains, foul, and go direct to the river. It was therefore prophesied all round that the Leicester farm would be a failure, and he was strongly advised by his friends to have nothing to do with it. However, he took it all in hand, and studied the question a great deal. Suppose the glass roof of a room to be the farm, and the ridge of the roof to be the watershed of the farm, the gradients or slopes of the farm being pretty steep, the sewage was sent up into the small receiving tanks in the centre of the farm. On this watershed there was a main carrier right through the farm, and then there were other main carriers going down subsidiary watersheds each way. The first idea he had, and which was adopted, was to "break up" by the side of the main carriers all the pasture fields into arable fields, and where the lower fields of the slopes were arable land to seed them down into old pasture or sow rye grass; the idea being to first have arable land to send crude sewage on to, and finish it off on the old pasture. He dealt with the farm in fields as he found it, instead of "stocking up" the hedges. There were now 1,700 acres of land, 1,400 acres of which were sewaged. He had the whole of the dykes deepened to not less than four feet, and some five feet, so that he could form a sort of natural drainage of all the fields to begin with, and that all these ditches should form the effluent drains. A great many of these fields were already drained about three feet deep for agricultural purposes, but this was not sufficient for their purpose. Now what he did—instead of carrying out the original proposal to have a complete system of drainage with all the sub-drains of fields to go into the master-drains, the master-drains to go into the trunk-drains, and all to go direct to the water-courses—was to take each field and deal with it separately. He laid a new master-drain along the bottom of each field to intercept the existing and the new branch-drains, and carried it to the lowest corner of the field, and then ran a free outfall-drain from it on to the surface of the next field as quickly as he could get it out. That was run down by the side of the dyke. At this free outfall he made a little chamber with one outlet and valve leading on the surface of the field, and another to the dyke. Then, at the bottom of the next field, he did the same, and at the bottom of all the fields. It sometimes happened that he could not get on to the surface of the very next field, but he missed one and got on to a lower one. The result had been, as he anticipated, that when the drain effluents came out at the bottom of the upper fields they were not fit to send away. So he sent them over the next lower fields, and so he had been able to turn the effluent from the drains either over more land to treat it over again, or, if it was fit, to send it into the nearest dyke. This has been the chief means of the success of this farm. They had been able to send away

a thoroughly good effluent. He also adopted the well-known system of putting on the surface effluent over and over again, and he had with these several arrangements no difficulty whatever in making the Leicester clay farm a success in purifying the dense sewage from nearly 200,000 people for six years past. There was one other point that was of great importance. He had a great deal of opposition to this scheme, just at first, till their present chairman (Alderman Sir Thomas Wright) championed him; so that the report was carried, and he was afterwards well supported by the committee. Another difficulty had been whether the bailiff should do the sewageing or whether he should direct it. The bailiff was a grand farmer, but he had not then had so much experience in sewage farming. Sir Thomas Wright got the committee to pass a resolution that until the farm was all laid out, and they had got into thorough working order, he should not only be the engineer, but be head over the farming and sewageing operations. He held that position for nearly three years, until it was proved without a doubt that he could succeed. The bailiff, being a very able man, grasped the situation, and he (the speaker) then reported to the committee that he wished to be free from the sewageing operations; and the bailiff (Mr. Thurston), together with a model committee and their able and energetic chairman and vice-chairman (Alderman Sir Thomas Wright and Alderman Collins), now managed it in a highly satisfactory manner. With respect to Mr. Law's paper, his ingenious arrangements appeared to be just what was wanted to make the supply of chemicals fit the ever-varying flow of sewage, and also the varying quality of the sewage, which changed very much throughout the day in manufacturing towns.

Mr. DAVID BALFOUR (Newcastle-upon-Tyne) said that with regard to the two papers that had been read by Mr. Herbert Law and Mr. Henry Law, he had great pleasure in complimenting those gentlemen on their papers. Mr. Henry Law's name in sanitation and civil engineering was known all over the country. As regards the subject of sewage irrigation or other treatment, he thought that the paper which had been prepared by Mr. Roechling (whom he had the pleasure of seeing occasionally, and who he was sorry to hear was not able to be present) was a very excellent paper indeed, and very comprehensive. He had lately had the opportunity of visiting the sewage irrigation and intermittent land filtration treatment at Paris, and also an opportunity at a Congress at Glasgow about a month ago, of examining another mode of treatment there, both being respectively excellent and successful examples of what could be done in regard to the purification of rivers, whether inland or tidal. The pollution by our City of Newcastle of our noble river Old Father Tyne could be similarly prevented by taking a lesson out of the book of Old Father Clyde at Glasgow, or the Thames at London. Referring to Paris for a little, the sewage of that city, after delivery by gravitation, and also "elevation," as the French call it (being pumped to a height of forty feet in Clichy), was conveyed on to excel-

lent land farther on at Grenvilliers. At present about 2,000 acres were used for the treatment of the sewage, and it was altogether very successful. He visited the City Engineer Monsieur Bechmann, whom he had met previously, and who kindly accompanied him there. The treatment was similar to that at Berlin, and the land was of a very open character. It consisted of a gravel sub-soil overlaid by a sandy loam. The treatment of the whole of the sewage was not effected there. Before reaching the farm he visited the main sewers of Paris. They were about ten feet in width and height and arched over, and were not a very great distance beneath the surface of the streets, and they were, as he saw in new extensions, generally made without interrupting the street traffic by surface excavation. He was told that about 780 men were continually at work cleansing the sewers; and so far as those men and frequent visitors (both ladies and gentlemen) to the sewers were concerned, no disease or complaints had been traceable thereto. Water mains for duplicate supply, also pipes for compressed air, telephone and telegraph wires were accommodated in the sewers. The sewage flowed along in a constant fresh-looking stream. There was no chemical treatment of it at any stage, neither in the sewer nor on the farm. The exploration of the larger main sewers was effected by an electrically-drawn launch and elegant boats. Reaching the end of the outfall sewer they inspected the farm, which comprised 2,000 acres. The sewage was distributed by various methods, particularly the ridge and furrow system, and surface irrigation. Most of the land treated was in the hands of the Authority. Part of the sewage, however, was given to tenants of the adjoining land where it was usefully and successfully employed. The under-drainage necessary was of a very partial character, being chiefly to concentrate the effluent and bring it to a common discharge into the river Seine. They found the effluent water without colour, taste or smell; the effluent brook was very clean, there was no deposit whatever, and it was very clear and limpid. He observed there were small minnow fishes in the stream as well. The management of a sewage farm was a very important matter; as important indeed as the construction, and design. As a matter of fact the management was quite half the battle. It was very important that no sewage works whatever should be let to tenants, their object being naturally profit, rather than purification. He thought we had arrived at a point when sewage purification was altogether, broadly speaking, a well solved and settled problem, and that authorities need not keep back for want of that. Of course they knew they had to have a great many meetings to consider "how not to do it" before it was done.

Dr. SYMONS (Bath) said he understood a gentleman to say that no evil result followed the spreading of typhoid germs on land. He did not think that it was quite in accordance with facts; he should have said the spreading of dead typhoid germs on land did no harm. It was generally thought that typhoid germs soon perished in sewage,

and were, therefore, dead when they reached the farm; with recent excrement, containing living typhoid germs, it was very different. Returning sewage to land was, undoubtedly, the most natural method to adopt; but, unfortunately, it was not always easy to get the necessary land, and the Regulations of the Local Government Board did not make it any easier. Under some circumstances the "septic tank" of Mr. Cameron, City Surveyor of Exeter, seemed worthy of trial, and he was sorry not to have heard that system discussed at that great meeting. Mr. Cameron's process was now under trial working at Exeter and at Yeovil; the results would be followed with interest.

Mr. ROGERS FIELD (London) said the observations of Mr. Mawbey seemed to him to be very important. They were told by all the authorities on the disposal of sewage by irrigation to "get suitable land." Well and good; but if the land was not suitable, what were they to do then? That was the problem which engineers and sanitary authorities had often to solve; and towards its solution Mr. Mawbey had, he thought, taken a great step in advance. Suppose, as was often the case, that they had clay land which was suitable for the disposal of the sewage in every respect except that it was clay land; if anyone could show how that could be made effectively to purify the sewage he would be a public benefactor. The problem was not to be solved by a trial on two or three acres, but only by trial on a large scale, as Mr. Mawbey had carried out at Leicester. The question of Leicester sewage happened to be peculiarly interesting to him. More than forty years ago he was a pupil of Mr. Thomas Wicksteed, the eminent engineer, who carried out at Leicester a system of sewage precipitation by lime and he had to do with the details of the work. It was the first time the process had ever been carried out on such a large scale. The work was undertaken by a company and it was estimated that there would be a large profit. The company however failed, and the town had to take over the sewage works. The precipitation process did not sufficiently purify the sewage. Eventually the town had to come to a sewage farm, and to take the unsuitable clay-land Mr. Mawbey spoke of. He believed that the way Mr. Mawbey had dealt with this land was absolutely the right way, and he had done the same sort of thing himself on a small scale. It must be remembered that they must under-drain the clay land for agricultural reasons, but instead of letting the main under-drain discharge into a ditch or river, as was generally done, they must be made to discharge on to the surface of the land at the nearest place the levels would permit. Then, if they could let the under-drains from this lower land discharge again on to the surface of the land, by this means they would obtain a pure effluent. But the process could be carried a little further than had been done by Mr. Mawbey. If there were not sufficient land on which to turn the effluent a second time, they could construct an artificial filter of burnt clay to discharge on to it. This would add to the expense, but be cheaper than chemical treatment. He quite agreed with Mr.

Mawbey as to what he said about the management. Whatever was spent in laying out sewage land, it would be all thrown away if the management was not under skilled scientific supervision. It was too much the custom to leave the whole matter to the farm bailiff, who would think much more about the crops than he would about the purification of the sewage.

Mr. J. E. PARKER (Fence Houses) said that the references in the papers had been to sewage disposal works for large communities. It was well known, however, that small communities had found themselves in great difficulties with regard to the question of sewage disposal, and, therefore, that was his excuse for rising, for he had to do with small communities. Speaking of the ingenious contrivance they had had before them of the chemical feeder, he thought it said a great deal for the ingenuity of the designer. There appeared from the diagram to be one little defect, and unless made of something that was not metal there would be considerable difficulty, because he found that allumino-ferric attacked even brass and gun metal. He quite agreed that the efficacy of a sewage farm depended on the management. He would also say with reference to sewage farms that there was a sentimental objection to them, and that objection had the effect of producing a depreciation in the value of the property which surrounded them. He knew a case in which a Parish Councillor was the sewage farm manager, and he happened to know that this Parish Councillor raised at the Parish Council meeting the question about the depreciation of the property. He said he had lived there himself and suffered no harm, but still a person objected to living in a house which was near a sewage farm. He thought these sentimental objections had to be considered.

Mr. HENRY LAW (London) said that without endorsing fully the observations made by Mr. Mawbey, he thought they would find as he progressed that the land would become better and better. They were quite aware of the effect of the action of allumino-ferric on iron, and the tanks were made of timber, lined with lead.

Dr. J. H. GARRETT (Cheltenham), as a chemist and Medical Officer of Health in that meeting of engineers, would say that the remarks he had just heard expressed in support of the broad irrigation system of sewage disposal were rather too enthusiastic, and he was sorry to feel obliged to put a little sprag in the wheel. He did not know whether all the gentlemen who had spoken had considered the condition of the effluents and of the water-courses receiving the effluents from broad irrigation sewage farms. From his point of view he could not say that he had often found them satisfactory. He thought the Borough Engineer of Leicester was very much to be congratulated upon having satisfied his Council. County Councils throughout the country were at present very far from being satisfied as to the effluents from sewage farms, and particularly from the broad irrigation farms. In Leicester and such large towns there

were at the disposal of the Council, gentlemen with great experience and ability, but in the smaller towns the services of such able men were not always available. And in regard to the management of sewage farms he was afraid that they were not always so well managed in the smaller towns as in Leicester. Generally speaking there was a great amount of carelessness exhibited in the application of sewage to land. In regard to the inspection of sewage farms he thought it was anything but well done. In the smaller towns almost anybody was appointed inspector of the sewage farm. The inspector walked round casually, and occasionally the committee, accompanied by their inspector, visited the sewage farm, and matters were reported to be very satisfactory. In a general way the inspector was a person who was quite incompetent to be inspector and to see that the sewage was being properly applied, whereas the importance of his duties could hardly be exaggerated. He had heard it stated that day that the borough engineer was the proper person to have the management of sewage farms, but he knew that frequently the borough engineer had a great many duties to perform, being an extremely busy man, and in some instances perhaps sewage farm management required a good deal of time. Sometimes in the smaller boroughs, sewage was run on to land which did not belong to the authority and which was not controlled by them. An agreement was entered into with the neighbouring farmers to receive sewage. This was a very bad plan and always resulted in great pollution of the water-courses.

Major LAMOROCK FLOWER (Lee Conservancy Board) thought that perhaps three or four words from him would not be entirely thrown away, seeing that for the last twenty-five years he had had plenty of opportunities for observing how sewage had been treated, and also of treating it to a very great extent. With regard to Mr. Herbert Law's paper, the use of chemicals in solution had been employed by him with very considerable success, but we were indebted to the author for the very excellent scientific mode of automatic application which had been exhibited to them, for in all their sewage treatment they had to deal with an unfortunate condition, which was, the fallibility of human nature. As to the management, or rather mismanagement, of sewage farms, he would say that, without exception, the failure in treatment of sewage on land was absolutely due to mismanagement. There was one other thing which perhaps sometimes leads to mistakes, and that was not allowing a scientific man to look after the work, but in dealing with it through committees. It was a hard thing to say, perhaps, but he would refer to one very clever remark made some years ago with regard to committees: "If the children of Israel in their passage through the wilderness had been governed by a committee instead of a leader, they would probably be wandering about the wilderness to-day."

Mr. H. ALFRED ROEHLING (Leicester), replied in writing to the discussion as follows:—"The subject of the purification of sewage is

such an important one that I think any information or any discussion throwing light upon it ought to be hailed with satisfaction, and if I have succeeded in doing this, even though it be to a small extent only, all my labours are well repaid. I am much obliged to Mr. Mawbey, the present Surveyor of Leicester, for affording me an opportunity of making a few remarks about—may I use that term—a very old acquaintance of mine, the Leicester Sewage Farm, which I have known intimately long before Mr. Mawbey was ever thought of as successor to the late Mr. Joseph Gordon. Indeed I have known this farm from the period, November 1884, when it was first thought of as a sewage farm for Leicester down to the present moment of penning these lines, whereas, to judge from his remarks, Mr. Mawbey has been connected with it “for nearly three years” only, at the end of which he voluntarily resigned his position as Engineer and Manager. Since then, so we must conclude, the farm has been managed by a Committee of the Leicester Town Council, whose Chairman and Vice-Chairman are Sir Thomas Wright and Mr. Alderman Collins, and whose Bailiff is Mr. F. Thurston. It is correct, that when this site was first mentioned for a sewage farm, the late Mr. Gordon did not like it so well as other sites which were in his opinion more eligible though the expression “with a heavy heart” appears to be beside the mark. This can hardly be surprising when we consider that the land at Beaumont Leys is heavy clay land, and that the sewage has to be lifted over 170 feet high; indeed, I don’t think any engineer worth that name would have spent the ratepayers’ money without any misgivings upon such a venture! When, however, this site was adopted Mr. Gordon was determined to do all in his power to make the farm a success. When Mr. Mawbey took up his duties as Surveyor of Leicester, at the end of October 1889, the plans for the laying out of the farm were complete, and the first contract all but finished. This contract comprised the tanks, the main and subsidiary carriers, the pipe carriers, the effluent water culverts, and a road for practically two-thirds or 850 acres of the then extent of the farm of 1,375 acres. The total amount of the tender was £14,351 9s. 6d., and according to the certificate of the 18th October, 1889, the works carried out to about within a fortnight of this date came to £11,028 9s. 11d. Some minor deviations have been made in laying out the remaining one-third portion of the farm, but that perhaps cannot be surprising. As to utilising the effluent from the higher lands on the fields lower down the slopes, this was always kept in view by the late Mr. Gordon, and with a view to convey some information concerning this point to him he asked me to visit the Rugby Sewage Farm, where this principal had for many years past been adopted by Mr. Baldwin Latham. Besides, it is so well known, that at Wimbledon too, this double system of irrigation is carried out, and, further, the considerations which lead up to it are so exceedingly elementary, that I need not say here another word concerning the engineering features involved in it. However, it would in my opinion be a great mistake to assume even for a moment, that the favourable purification results, obtained on the Leicester

Sewage Farm, are due to this double irrigation. Such an assumption is against what are now known to be the laws of purification of foul liquids. This purification is brought about by bacteria, and it is well known that they carry on their work most efficiently in the presence of a sufficient supply of oxygen, hence, it is a fact that purification proceeds most actively in the pores of an open soil near the surface of the land, but not in dark conduits such as underground pipes, &c. All that can, therefore, be said of the system of double irrigation is that it is a means to the end, not the end itself, and it is most important not to lose sight of this. This being so, there can be but little doubt that the favourable results obtained at Beaumont Leys are mainly due to the management of the farm, and here I think it is but fair to say, that had it not been for the untiring energy of Sir Thomas Wright, the never failing zeal of Mr. Alderman Collins, and the painstaking efforts of Mr. Thurston, the Leicestershire County Council would have spoken out before now with no uncertain voice, as it did formerly. In conclusion I should like to say that the work on the farm is by no means complete, and that the Committee go on with their drainage and other operations from year to year. Indeed, it would be surprising if all the work on so large a farm had been completed in comparatively a short time. It is the essence of a careful management to systematically study for a number of years the behaviour of clay land under sewage, and then to treat it by draining and other operations in the manner which benefits it most.

"River Pollution," by PROFESSOR HENRY ROBINSON,
M.Inst.C.E.

(FELLOW.)

IN my address as President of this Section at the Congress held in Newcastle in 1882, I stated that "As the various difficulties which existed a few years ago in regard to the purification of sewage have now been diminished by the further knowledge that has been gained, it may be reasonably expected that the Rivers Pollution Prevention Act of 1876 will be made more operative than has hitherto been the case." In the following year I again brought the question of River Pollution before the Congress which was held at Glasgow. The discussions on those papers showed that the necessity was then well recognised for a modification of the Act, to prevent its being (as it was), practically inoperative. It remained without change, however, until the year 1888, when the Local Government Act was passed, which gave County Councils power to enforce the River Pollution Prevention Act of 1876, and which also enabled

the Local Government Board to form joint committees to deal with river pollution. In 1892 the Mersey and Irwell Joint Committee obtained an Act, and this was followed in 1894 by the West Riding of Yorkshire Act, by which powers were conferred upon authorities to prevent river pollution who might be better expected to enforce the Acts than was previously the case.

The Rivers Pollution Prevention Bill which was introduced in the House of Commons last Session, extends to County Councils, Joint Committees and Rivers Boards in England, the main provisions of the Mersey and Irwell Act of 1892, and of the West Riding of Yorkshire Rivers Act of 1894. It also prevents the pollution of canals.

The Floods Prevention Bill, which was introduced in the Upper House by Lord Thring last Session, confers upon County Councils powers to cleanse water courses and to improve the channels of rivers by removing obstructions.

Both these Bills have unfortunately had to stand over to next Session, but it may be reasonably expected that in the near future they will be passed, and will lead to the present gross pollution of the streams throughout the country being abated. Having had to report upon the causes of pollution of many rivers, I have found that in the majority of cases they admit of a remedy. The main sources of pollution, broadly speaking, arise from sewage outfall works, where the system adopted is incapable of producing continuously good results, from manufacturing refuse being passed into streams as the natural vehicle for getting rid of waste products, also from trade refuse and accumulations of filthy matter being allowed to collect close to the banks, and to be washed into streams. As regards the pollutions due to defective sewage outfalls, they admit of being remedied in the light of recent experience, and by the expenditure of the necessary money to produce better results. The unsatisfactory way in which some local authorities have works of sewerage and of sewage disposal designed and executed, and the parsimonious manner in which the treatment of the sewage at the outfall is carried out, are mainly the causes of these pollutions.

Means of purifying sewage and sewage effluents are now available that were not known a few years ago, and I have no hesitation in saying that most sewage outfall works admit of modification with resultant advantages, both in simplifying the working, and improving the effluent, thus obtaining "the best practicable and available means," as stated in the Act.

The pollutions that arise from manufactories require to be dealt with having regard to the circumstances of each case.

The exercise of a little skill and care will enable many such pollutions to be abated by utilizing the waste products, and in other cases remedies can be found without involving an expenditure which would press too heavily upon the industry. A river has for so long a time been regarded as the natural way to get rid of filthy matter, whether from manufactories or otherwise, that those who have, in a *bona-fide* manner, acted upon this assumption, require some consideration in the enforcement of legislation to abate pollution. The fact, however, that, in the near future, the streams will no longer be able to be the recipients of polluting matters, has already been the means of arresting some mischief. Many are offenders from sheer ignorance. Some from a disinclination to incur expense which would lead to no advantage to themselves, whatever it might do for the benefit of others. As regards manufacturing refuse which now causes pollution to streams, I have, in my own practice, experience of cases where pollution has been arrested even with commercial advantage to the industries concerned.

The pollutions due to farm buildings, private dwellings and the like, admit of being diverted, and the filthy ditches which are cleansed by heavy rains washing the filth into the streams no longer continue. The majority of streams are so polluted, that it will take years after the causes of fouling are removed, before they return to a normal condition of purity. I believe that it will be necessary to accelerate this natural, self purifying action by artificial means, and so prevent, or rather lessen the continuance of the mischief.

With the improved condition of rivers, a large amount of much needed water will be available for town supply. Their filthy condition has unavoidably led to the exclusion of such waters from all engineering calculations in regard to water supply. With the disappearance of serious pollution this water will become available for storage. The inclusion of the bulk of flood water in reservoirs would enable compensation water to be discharged continuously instead of intermittently, at the same time that the injury arising from floods would be minimised.

The objection which at one time existed to the admission into reservoirs of waters not absolutely pure, may be regarded as steadily disappearing in the light of recent knowledge. Dr. E. Frankland (in a Paper at the Royal Institution last February) stated in speaking of storing the Thames water—"as regards the quality of this stored water, all my examinations of the effect of storage upon the chemical and especially upon the bacterial quality, point to the conclusion that it would be excellent. Indeed, the bacterial improvement of river water

by storage, for even a few days, is beyond all expectation." Again, he said, that "it is not too much to expect that storage for, say a couple of months would reduce the number of microbes in Thames flood water down to nearly the minimum ever found in that water in dry weather."

In a naturally pure stream the discharge into it of filthy matters has become more and more a cause of its deterioration, one being the increase in the amount of the polluting matter, and the other being the greater abstraction of pure water from the stream to provide for a supply to the populations which require it for dietetic, manufacturing or power purposes.

The amount of the abstraction, either permanent or temporary, of water from a river for any of these purposes has been the subject of much strife, and no definite relation between the amount that can be relied upon from the source of supply and that which can be utilised has been established; inasmuch as the conditions which obtain in rivers vary considerably. Hence the controversy that generally arises when water is intended to be abstracted and stored in impounding reservoirs. This often leads to compensation water being given to a river at a lower part of it, whereby the upper part is liable to become a dry bed in periods of drought, and consequently riparian owners on the banks of the river there are deprived of water altogether.

The pollution of the rivers of this country was characterised by the late Lord Shaftesbury as a "national evil." Those who have worked, as I have, to bring about a better state of things, will not, I trust, have to wait another fourteen years before a definite step in the direction of the enforcement of legislation is accomplished.

"India's Sanitary Needs," by J. W. PARRY, Assoc.M.Inst.C.E.,
F.S.I.

(MEMBER.)

It would be quite impossible to take up and discuss all or even many of the subjects embraced under this head, I therefore propose to refer chiefly to questions which concern District Boards—Unions as they are called in the Madras Presidency—and which correspond somewhat to Rural District Councils of England and Wales.

Before, however, taking up the principal points to be discussed, it is necessary to consider certain sanitary matters which concern India in general. Here I would express my indebtedness to the transactions of the Seventh International Congress of Hygiene and Demography, held in London in August, 1891; as also to the Blue Book Sanitary Measures in India for 1893—1894 which is the latest one we have received. In these transactions and in this report we have the testimony of the principal medical sanitary commissioners throughout India, as also the views of several able administrators such as Messrs. Ollivant, Ashburner and Cotton, of the Indian Civil Service; of Major R. C. Temple of the Indian Staff Corps; and lastly of several distinguished Parsi officials.

To show that the Government of India are quite aware that sanitary reforms are necessary, and are only restricted in their endeavours by the poverty of the country and the crippled state of the finances due to the depreciated rupee, I have added an abstract of the principal sanitary works already carried out up to 1891. In addition I give in a tabular form an abstract of the expenditure in all sanitary work for India during 1893—1894.

Abstract Expenditure on all Sanitary Work for India during 1893-94.

Province.	No. of Municipalities included.	Total Income of Municipalities, in Lakhs of Rupees.	Expenditure exclusive of roads in Lakhs of Rupees.	Remarks.
Bengal	146	37·39	16·13	Exclusive of Calcutta and neighbourhood (9 lakhs). In 41 Municipalities nothing spent on Sanitary work.
Do. (Local) ... {	...	...	2·17	
Do. (Private). {	...	...	3·69	
Assam	...	1·91	0·81	Village Sanitation Act, framed '93.
N. W. P.	103	50·78	29·45	
Punjab	149	40·64	6·07	
C. P.	19	16·78	2·33	Main work of Board was the direction of Village Sanitation.
Madras	55	27·47	14·53	
(Do.) Districts {	...	78·93	6·27	
Berar	11	3·68	2·39	Exclusive of Madras City and neighbourhood (10·71 lakhs).
Coorg	...	...	0·21	
Burma	...	...	0·81	
Bombay	...	...	0·83	Better Conservancy of coolie lines on plantations considered.
Do. (Districts) {	...	...	29·0	
		Total...	114·69	lakhs of rupees.

From this table we see that the total expenditure on sanitary works all over India, exclusive of Presidency towns, was 114·69 lakhs of rupees. If we add (9 + 10·71 + 22·93) lakhs for

these towns respectively we get a grand total of 157·33 lakhs, calling this 158 lakhs and converting at 1s. 2d. per rupee we get £921,000.

Again, assuming that roads cost the municipalities 60 per cent. and sanitary works 40 per cent., then 158 lakhs $\times$ 2·5 gives 395 lakhs, this at 1s. 2d. gives £2,300,000. In other words during 1893—1894 over the whole of India on sanitary works alone under one million pounds sterling were spent, while inclusive of maintenance of roads—under municipal limits—less than two and a half millions were expended. It is true that in most of the provinces the local governments both make and maintain the grand trunk roads, still it will be noticed how very small this total expenditure is for such a continent as India, especially if it were compared with the expenditure all over the British Isles for similar purposes.

It may be assumed that the large towns of Calcutta, Madras, Bombay, Allahabad, Lahore, Lucknow, Cawnpur, Nagpur, and other places, have municipal funds and are therefore able to pay for urgent sanitary measures, or are able to obtain loans when they desire an extensive scheme for water supply or drainage. In the Congress of 1891 Mr. T. H. Thornton, late Secretary to the Punjab Government, considered it prudent to concentrate sanitary efforts in towns. These he said “are the foci for radiating centres of disease. If they were set in order and made healthy much would be done: towns moreover were centres of intelligence, and their examples would gradually influence the neighbouring peasantry and render them amenable to successful sanitary treatment later on.” Here, on considering the matter a very great difficulty besets one, for the population of India in towns is said to be less than 10 per cent. of the whole, so that at least 90 per cent. of mankind live in villages, and if any real good is to be done we must begin at the village. By this I do not mean hamlets of a few straggling huts, but a decent sized village of say at least 5,000 inhabitants. I therefore propose to reply to the following question:—

What are the minimum sanitary reforms which can be initiated among a conservative, apathetic and ignorant people whose means are extremely limited?

Now it is worthy of note that none of the speakers at the 1891 Congress went into the financial aspects of village sanitation, and as this is a most essential point I propose to take it into consideration first of all. The subject matter then divides itself into two heads.

I. What funds are available among Indian Sanitary Boards?

II. What minimum sanitary measures are absolutely necessary among unions?

I.—WHAT FUNDS ARE AVAILABLE?

It must be clearly understood that most of the Indian District Sanitary Boards or Unions have not the incomes the similar Rural District Councils have in England and Wales. There is neither poor rate, sewer rate, lighting rate, nor general rate. There is a road cess rate, octroi duties, and other minor sources of revenue, such as wheel tax, sale of manure, &c. An example will perhaps make the meaning clearer.

We will suppose an Indian village of 10,000 people, the local rates and taxes do not amount to one rupee per head, they may be 8 anas, are probably 4 anas, or even as low as 2 anas per head. We will suppose 8 anas a head, this for the village gives 5,000 Rs., which taken at 1s. 2d. per rupee results in £292. Now take a similar sized village in England, and assume that the taxes are only 10s. a head, this gives £5,000, assume that 60 per cent. is required for the upkeep of the roads in both cases, leaving 40 per cent. available for all kinds of sanitary work, and we see that the Indian District Board has only £117 against the English Rural District Council's £2,000, or the latter has seventeen times the funds of the former.

One can do a good deal in sanitary work with £2,000, but one cannot do much with £117; for though labour is cheap enough in India, yet sanitary appliances are considerably dearer as they are generally sent from this country. The poor rate which is a big item in English rates and taxes, is not necessary in a country where the sons maintain the parents when they are passed the age of working for themselves. No wonder the Shastras bless the man whose quiver is full of sons, whereas daughters requiring dots and expensive marriage ceremonies are burdens greivous to be borne. In towns the rates, with a water supply amount to Rupees two or more per head, but even then how little this is compared to the English rates and taxes. How happy we should be if we were let off with 2s. 6d. per head for our local rates and taxes.

In the Madras Presidency there are two kinds of unions—major and minor. The major unions have the making and repairing of village streets and drains, and the constructing of tanks or wells for providing a water supply; while the minor unions have only imposed upon them the duty of cleansing streets, tanks, wells and drains. There is, however, no general act applicable all over India similar to the Public Health Act of 1875, by which the Sanitary Board can compel people to “sewer, level, pave, metal, flag, channel or make good, or so provide proper means for lighting the street within the time specified in the notice.” The Honorable Lionel Ashburner,

C.S.I., tells us that the Bombay Village Act of 1889, "is a well-meant attempt to improve sanitation of the rural district; but it has failed owing to the practical knowledge of the difficulties to be overcome," and it may be added, that the chief difficulty is the want of funds. Would some one suggest how these funds are to be obtained?

II.—WHAT ARE THE MINIMUM REMEDIAL MEASURES TO BE ADOPTED?

Under this head I propose to discuss (a) Village Water Supply; (b) Removal of Filth; (c) Necessary Action in case of Infectious Disease becoming known.

(A) *Village Water Supply.*

Good water is an absolute desideratum all the world over, but especially in a hot country like India, where it is likely to become easily contaminated. We shall leave river conservancy as involving altogether too large a scheme for our purpose, and consider chiefly wells and tanks which are the principal features of rural life. There is, however, one point to which it is necessary to draw attention, as the Bengal Government have lately issued a stringent resolution for enforcing sections 254 to 260 of the Municipal Act with regard to pollution of rivers at burning ghâts. *Indian Engineering* does not consider the resolution is stringent enough, for it says: "We do not under-rate the pollution by human corpses, but we maintain this is small compared to the pollution caused by throwing in daily excreta, dead cats, dogs, horses, rats, animals of all sorts, and vegetable refuse from every riparian town and village."

Is it too much to ask the unions to cover up the village wells and supply iron pumps? In this way leaves and surface drainage could not enter the well and there would be no risk from contamination of infected drinking vessels. In many parts of Lower Bengal and Madras Presidency the water is only 10 or 20 feet below the surface, in which case ordinary suction pumps could be used, these might be made up locally or purchased from some of the well-known engineering firms. In this country such a pump would cost from £2 to £4 inclusive of piping, and a similar one might be fixed up in the village for Rs. 50. In the Punjab, Rajputana, and other places well water is from 60 to 100 feet deep from the surface, in which case force pumps with gearing would be required.

I have made enquiries from Messrs. Joseph Evans and Sons, the well-known pump makers of Wolverhampton, who have kindly supplied me with the following information of costs, &c.:—

Particulars.	Fig. in Catalogue.	60-feet Well.	80-feet Well.	100-feet Well.	Remarks.
Bore of Working Barrel 2½ in.		£	£	£	
Bore of Suction and delivery pipe 1½ in.	303	17	19	20½	With fly-wheel for two persons to work will give 400 gallons per hour.
Stroke 9 in.					
Do. do.	307	25½	28	30½	
Do. do.	332	31½	28½	34	Do. do.
					{ For one bullock will give 600 gallons per hour.
Suction Pump	30	Depth 20ft. only, Cost £1 5s.			Applicable to Lower Bengal and Madras.

These prices include all costs, packing and putting f.o.b., discount also will be allowed for cash payment. Messrs. Evans and Sons also inform me that two men can easily work a 2½" by 9" stroke, fig. 303, single-barrelled arrangement against a total vertical lift of 60 feet without gearing. Should the well therefore be less than 60 feet in depth, the cost of the pump would be considerably less than the £17 shown in the table. The water in the Punjab wells, distant from irrigation canals, is nearer 80 feet than 60 feet and though this may be an unfortunate matter as regards cost of pumps, yet no doubt it makes the climate drier and the people are physically stronger than those in other parts of India. As the sanitary boards cannot afford to supply all the village wells at once with pumps they might supply one or more per annum. The convenience of a fly wheel and a continuous flow of water would soon be appreciated, especially by the women folk who have to draw the water, and no doubt the people would be willing to pay a small tax for this great blessing.

Surg.-Lieut.-Col. W. G. King, Sanitary Commissioner for Madras says, "let, however, the work be executed—let the fact be *demonstrated*, that pure water is now delivered in place of the filthy mixture formerly available, and there is no more grateful person than the villager. In short, I am of opinion that the greatest factor in preventing sanitary advance in this country is not prejudice—caste in other words—but the absence of familiarity with the methods generally dictated."

With regard to tanks it is absolutely necessary that water for drinking purposes should be stored in separate tanks from that used for washing clothes, the cattle too should on no account be permitted to go to the general drinking water tanks as is

almost invariably the case, but should have other tanks allotted to them. This might be arranged by paying a small fee to the headman of the village, who could then be held responsible. On returning home from the fields cattle get into the habit of going to the same place at the tank to drink, and if they are diverted a few times they will take kindly to any other tank.

(B) *Removal of Filth.*

In small villages there is no conservancy whatsoever. In the larger villages a certain portion of ground is taken by the Sanitary Board outside the village. Some of this is screened off for the sexes and trenches dug, after a time the screens are removed elsewhere, the trenches filled and others dug at the new site. In towns Horbury's galvanised iron latrines are placed at certain depôts and kept clean by a gang of sweepers; while Moule's dry earth system is adopted in hospitals and public institutions. Surg.-Lieut.-Col. W. G. King says that in the Madras Presidency "only eleven towns are fairly well supplied with latrines, while in twenty-six others they are at the rate of one for 1,000 to 2,000 people." He also notices a retrograde movement in the cleanliness of private premises and especially privies. Here I may be permitted to give some personal reminiscences.

During 1881-1883 I was stationed at Bhiwani as assistant engineer on the Rewari-Ferozpur State Railway. I used to visit the house of a wealthy grain merchant whose privy was on the top of his house, and the excreta used to trickle down a 4-inch recess along the face of the outer wall, the drinking water well was less than 40 feet from this wall. Fortunately the well was deep or the whole family would have been poisoned and would have attributed the poisoning to "Kismet" or fate. The interior decoration of the reception room had panels of Jaipur marble with mosaics, the walls were frescoed depicting scenes from the Epic poem Ramayan, while the ceiling was highly ornate with gaudy colors and gilding. Now Bhiwani being on the edge of the Bikanir desert the wells were chiefly brackish and sweet water was a great desideratum, it so happened that I had been ordered to make a survey of all the sweet water wells in the neighbourhood for locomotives; the merchant hearing of this came to me and offered a fee of 1,000 rupees if I would find him sweet water. I informed him that officials were not permitted to take fees but that I would give him my advice gratis. Unfortunately the ground proposed was outside his enclosure: meanwhile he had been spending large sums with diviners who lay on their stomachs all night long and pretended to hear the

subterranean rumbling of waters ; however, they did not manage to tap the fresh water stratum with their wands. Soon after I left Bhiwani I heard that the merchant purchased the bit of ground suggested, dug a well and to his delight came upon fresh water. What I wish prominently to bring forward is that this man did not keep his premises in a sanitary state, nor did he employ sweepers, nor did he contribute his fair share to the local rates and taxes when he could easily have done so. Yet if an epidemic arose he would be one of the first to raise his voice against the Government of India.

There is one point that sanitary boards might insist upon, and that is that private or public pails containing excreta should be covered with ashes. Every house burns wood or charcoal for cooking food so that plenty of ashes are always available. This sanitary precaution is specially necessary in India, as it is said that the average fœcal matter per individual is two or three times that produced in England. Sanitary boards might also order the burning by each householder of vegetable refuse instead of throwing it on to the street or alley. In neither case would these reforms cost money, though certain persons would have to be punished before the people learnt to do what is necessary for the public health. Lastly the unions might see that the manure from cattle is not stacked up in each courtyard to rot for ever, but placed on the leeward side beyond the village. If villagers could only be persuaded that night soil when properly mixed with loam, peat, or ashes is of inestimable value in increasing the amount of crops they would soon make voluntary efforts ; Surg.-Lieut.-Col. King's advice therefore to municipalities to teach the ryot by cultivating trenched ground is an excellent one. He also noticed that in the ceded districts and in Madras men of the highest caste would go to the night soil depôts and bargain for manure just as they would bargain for other things in the ordinary bazaars.

(C) *Diseases.*

The common diseases in India are fever, pneumonia, small-pox, dysentery, diarrhœa, and most important of all, cholera. Everyone gets a dose of fever and sometimes pneumonia during the months of September to November when the cold weather is coming in, the remedies are flannel next the skin, quinine and nourishment. As rich and poor suffer alike I do not see that sanitary boards should be called upon to take this matter up at all, unless they can afford to build fever hospitals, and few can afford that luxury.

Surg.-Maj. Kartikar in a paper read at the 1891 Congress says, "I say then that for compulsory vaccination to be received

without opposition or disgust by the vast majority of the Indian public in the present state of society, what is absolutely necessary to do is to bring a calf to the very door." As this is the opinion of a native gentleman who must understand the feelings of his countrymen, large towns might adopt the novel procedure of sending calves round to each man's door. It is a notorious fact that the mortality from small-pox has enormously decreased since compulsory vaccination was ordered. Moreover, the ravages of this dreadful disease which was one of the curses of the Empire during former dynasties is considerably modified owing to the protecting ægis of the British Raj. Every person visiting India cannot help noticing that the greater number of natives one meets have had some form of small-pox, and therefore compulsory vaccination like *Suttee* is an irksome necessity. The deaths from diarrhoea and dysentery are due to the contamination of a filthy subsoil and impure water; when these are improved the percentage of deaths will decrease.

We now come to the worst scourge of all—cholera. Most of us who have had to do with an outbreak of cholera in our coolie camps know how difficult it is to get the coolies to burn the infected rags or to take the cholera pills unless we are standing by, and we all get severe reprimands from the Government of India for not keeping off an outbreak which we were powerless to prevent. It is said that cholera is waterborne and is of course due to Koch's cholera bacillus, at any rate in Northern India it is of frequent occurrence in the springtime when the unripe fruit comes in. If village headmen would only give warning in time the first few cases could be nipped in the bud; for cholera spreads very rapidly when it once makes a start.

Before closing it is necessary to say a few words on ventilation. At Bhiwani, which was said to contain 33,000 inhabitants in 1883, I can only remember four decently paved streets 24 ft. in width metalled with kankar. Most of the streets or alleys were 12 to 16 ft. in width and were unmetalled. Bhiwani was also a walled town, so that unless a strong wind was blowing very little air circulated at all. It will take many years teaching to induce even the intelligent Brahmin to believe that 5,000 cubic feet of air per hour constantly changed are required in an oriental climate to live healthily; as to the unsophisticated rustic, he would tell you that he much preferred 5,000 odours from his goats and herds, for do not the shastras tell him that even the presence of a cow is a blessing?

I might have said something on offensive trades, drainage and other sanitary matters, but then we should exceed the limits of village sanitation.

In conclusion, I take the liberty of suggesting to village

unions as follows: After repairing the roads, devote what money you have, first of all to covering in the village wells and supplying iron pumps, and have these wells periodically cleaned say four times a year. Keep the tanks for drinking water separate from those for washing your clothes and persons, and on no account let cattle get into the former. Insist upon excreta being covered by ashes, and vegetable refuse being burnt by each householder as much as possible. By cajolery or giving honorary titles squeeze out as much money as you can from the wealthy members of the community who ought to do something to assist the British Raj which has done so much for them, enabling them to obtain such wealth as they never could have acquired under any other rulers. See that the latrines are on the leeward side of the village, and that the sweepers do the work allotted to them; don't permit offensive trades within the village itself, and lastly, when there is a cholera epidemic don't sit still and say it is Kismet or fate, but at least burn the clothing of the cholera patients. If you do even these few things you will receive the Asis or blessing, not only of posterity but also of your contemporaries, and India will certainly consider you worthy of a place in Swargâ or Paradise.

"Notes upon the Planning of Secondary Schools," by J. OSBORNE SMITH, F.R.I.B.A.

(FELLOW.)

THE systematic supply of Secondary Schools, and the development of Endowed Schools during the past thirty years, have encouraged and indeed given great impetus to the production of school buildings of a healthier and more cheerful type than those which they supplanted.

At the request of the Council, I have prepared a few notes upon the conditions which affect the health of the children who are being taught in some of the more recently erected schools.

ASPECT.

Various opinions are held as to the most suitable aspect for class rooms, the influence of sunlight upon the young and tender being so important, no rooms for teaching should have a sunless aspect.

In south-east rooms the early morning sunlight is much appreciated during the colder months of the year, and the

difference between north and south rooms from the point of cheerfulness is most marked.

In situations where it is not possible to secure direct sunlight upon the chief windows of a room, it is often possible to arrange for it to enter otherwise. The less favoured positions can be occupied by the studio, cloak-rooms, laboratory, lavatories, &c.

CLASS ROOMS.

The dimensions and proportions of the class rooms vary, but the shape is usually found more convenient the nearer it approaches a square. When the form is oblong the main lighting should be upon one of the longer sides. The height of course varies with the size, but if the means of ventilation are ample the rooms need not be so lofty as they are sometimes made—*e.g.*, 12 feet will be found sufficient from a sanitary point of view, as well as on the score of economy, for class rooms to hold thirty to forty children.

The relative positions of the door and fireplace in relation to the windows, deserve more consideration than is usually given. Waste of space necessarily arises where both door and fireplace are not situated at the end of the room occupied by the teacher. It is not convenient for the fireplace to be in the centre of the end wall; sometimes it may be well placed near the door. The corner of the room on the right hand of the teacher is a position with many advantages.

The fireplace should contain some form of ventilating or warm air producing grate, and fresh air should be brought to it from outside well above the ground, all inlets being short and accessible for cleaning; the air chamber for warming the incoming air ought also, for cleanliness sake, to be readily accessible. In large rooms or where there are two or more external walls, it is sometimes found desirable to supplement the fire by hot water pipes under the windows or along the wall opposite to the teacher. Open fireplaces should not be omitted from schools of this kind, without very full and serious consideration of the means to be employed to warm and ventilate the buildings and especially the class rooms.

ASSEMBLY ROOM OR CENTRAL HALL.

This important room should be near the principal entrance, and have ample means for access—it was a common defect in the earlier schools that only one entrance was arranged. This should be regarded as inadmissible except in very small schools. It is now not unusual for the class rooms to be entered direct from this room; this is done chiefly for reasons of economy, but the plan with a corridor between the hall and the class rooms has

many advantages. When there is no corridor, access to the upper class rooms is arranged from a balcony in the assembly room, along one or more sides, affording excellent opportunity for the architect to display his skill in designing, a feature which unless carefully treated will be heavy in appearance and tends to diminish the lightness and cheerfulness of the room.

Side lighting for this hall is preferable for the sake of ventilation. Where top lighting is used great care and judgment are required to avoid too much glass, which, moreover, should be placed as near the sides as possible in order to prevent deep shadows being cast upon the floor from the balconies. Centre top lights are rarely successful for school-rooms of any kind.

Good acoustic conditions ought to be secured for this room.

STUDIO.

The class-room for teaching drawing ought to be larger than the ordinary rooms to allow more space for each pupil, with easel, &c., to work in, as well as for placing groups of models, store cupboards, board racks, sink, &c. Its height should be greater than that of the other class-rooms, and the single window (if possible) should be some five or six feet at least above the floor and extend quite up to the ceiling.

LABORATORY.

The size of this must depend upon the extent to which science is taught in the school. It should be lofty, well lighted, with the window sills just above table height and extending to the ceiling; ventilation must be specially studied, particularly the means of readily producing cross currents of air at the levels of the work tables and ceiling. The floor ought to be impervious and covered with asphalt or other material unaffected by acids, &c., and to be currented to an outlet in case of accidental flooding and to facilitate cleaning. A store-room and lift, if on an upper floor, should be near at hand, also gas, and high and low pressure water.

It is convenient sometimes to plan a separate building for science teaching. The fittings vary according to the scheme of teaching, but sinks and a good supply of water are essential.

CLOAK-ROOMS.

The best position for cloak-rooms is near the pupil's entrance, plenty of light and cross ventilation are the chief requirements; stands for cloaks should be about six feet apart from centre to centre, and about one lineal foot of stand space should be allowed for each pupil.

Means for drying wet clothes are desirable, and are usually provided. Great care should be taken to separate these from the class rooms by well ventilated corridors or otherwise.

Cloak rooms of less height than 9 ft. cannot be efficiently lighted and ventilated.

LAVATORIES.

These should also be arranged near the pupils' entrance, and be separated from the main building by a staircase or lobby, with ample cross ventilation. The floors should be of impervious materials, and the height from floor to ceiling not less than 8 ft. 6 in. Each closet should have a separate window, and be entered from a well-ventilated lobby, leading out of the lavatory.

Washbasins should not be placed in cloak rooms without being screened off.

It is not necessary in any case that W.Cs. should be placed in a detached building, nor is it desirable in most schools of this class; but when they are placed below other rooms the ceiling should be of impermeable materials as well as the floors. Divisions and enclosing partitions should be solid.

OFFICE AND WAITING ROOM.

These rooms must be near the chief entrance, and if possible near the platform end of the assembly room, neither of them need be as large as a class room, but from the office windows it should be possible to see the main entrances to the building. The office is a workroom and also a reception room, it should be well lighted, cheerful and convenient with, if possible, a lavatory near at hand for the use of the head master or mistress.

TEACHERS' ROOM.

This room should overlook the playground and its entrances and be reasonably near to the office. A small cloak room, with lavatory and closet, are convenient and desirable adjuncts. It should not be less in size than an average class room. The glass line of the windows should be nearer the floor than in the class rooms, in this as in other respects the room should be regarded as a work room and sitting room combined.

LUNCHEON OR DINING ROOM, KITCHEN AND OFFICES, CARETAKER'S ROOM, &C.

These domestic rooms should be planned with a separate entrance, and be cut off from the school rooms with prompt access from the kitchen to the entrances, and from the school

to the dining room. On no account should any of the noise or odours from the domestic rooms be allowed to enter the school proper.

CORRIDORS.

Main corridors should not be less than 7 ft. wide nor of less height than the rooms adjoining, windows at each end are essential, and there should be ample lighting throughout, especially at points where they deviate from a straight line.

STAIRS.

The position, form and size of the staircases are most important, no greater inconvenience in a school can be conceived than a carelessly designed staircase in the wrong place. A building designed to accommodate more than say 150 children, should have two distinct staircases as far apart as possible, and near the assembly room,

A clear width of 4 ft. is often found to be sufficient, but 4 ft. 6 in. is much better, while 5 ft. may be regarded as luxurious.

Winders and circular or elliptical staircases are inconvenient, and in my opinion ought never to be planned for these schools, wherever it is possible to avoid doing so.

The rise of each step should not exceed $6\frac{1}{2}$ in.; 6 in. is better when obtainable. 11 in. should be the minimum width of the tread (from nosing to nosing). Staircases need not be lofty if sufficient head room and ample lighting be secured.

ENTRANCES.

These should be placed so as to be seen from the office or teachers' room, or to be otherwise conveniently under supervision.

PLAYGROUND.

This should be as ample as circumstances permit, and should contain fives courts, tennis courts, and if possible a cricket field, spaces for small gardens, shed for games' apparatus, &c., Trees upon the site should be judiciously preserved for their own sake as beautiful objects, and for the sake of the shade afforded in hot weather. Covered playgrounds, gymnasias, &c., should be formed in the larger schools.

WALLS.

Walls must of course be built of sufficient substance to resist heat, cold and moisture. Hollow walls in very exposed situations are useful in spite of their disadvantages, but solid walls of good

materials are better for ordinary positions. All openings in walls, flues, chaces, &c., should be made accessible for cleaning.

The greatest care should be taken, and thoroughly effective means should be adopted to prevent moisture penetrating the walls from above downwards, or from the ground upwards. Solid damp-proof courses formed of asphalt, slate, cement, &c., ought alone to be used, being much more effective than the various glazed perforated substitutes.

FLOORS.

Floors of class rooms should if possible be impermeable, and covered with wood. Where wood joists must be used special care should be taken to ensure rigidity, and provide effective means of checking the passage of sound and air through the floors.

Floors of all lavatories and science-rooms should be solid, with hard non-absorbent coverings. The use of porous breeze concrete for such floors is not to be commended.

Wood floor coverings should be polished, and have skirting fillets of sufficient width to keep the desks away from the walls.

ROOFS.

Roofs, if of the usual wood rafters, and slate, tile, or lead coverings, should be close boarded, and have some non-conducting material under the outer coverings.

DOORS.

The width of doors to class rooms should be limited to dimensions which will permit the passage of the usual moveable furniture, 3 ft. to 3 ft. 3 in. is usually sufficient. Those to studios, corridors, cloak rooms, dining rooms, entrances, &c., should be wider, with pairs of doors hung folding or to swing as may be found desirable.

Glazed upper panels are very useful in assisting supervision and maintaining discipline. I have known them objected to for apparently good reasons, but they are usually found to be convenient.

WINDOWS.

The essential points to be borne in mind regarding windows are :—

1. The chief lighting for *all* rooms, except perhaps those for science teaching, should be in one wall only, that on the left hand side of the pupils, with an extra window conveniently arranged where possible for cross ventilation or extra sunlight.

2. The glass line should be as near the ceiling as possible and not nearer the floor than 3 ft. 6 in. or 4 ft. in class rooms.

3. The window frames should be as near the outer surface of the wall as appearance, Building Acts, and other circumstances will permit, to afford means for obtaining admission of air without interfering with blinds, &c., and also to allow the maximum of floor space to be used without the desks being placed too close to the glass.

4. All windows should be made so as to be opened easily by children and to the fullest extent possible, and should be constructed to permit portions of them to remain open if desired while work is going on without the possibility of downward currents of air being felt by the pupils.

To describe the various windows in use would exceed the time at my disposal, but the following are a few familiar kinds which ought to be used with discretion or not at all :—

- a. Wide and heavy double hung sashes.
- b. Centre hung casements.
- c. Folding casements hung at side.
- d. Fixed sashes.

VENTILATION AND WARMING.

The cost of forming and maintaining a system of mechanical ventilation, and the desire for an open fire for the sake of cheerfulness and prompt control account for the fact that in most of the schools of the kind under consideration the open fireplace has been utilised.

If a school building be designed to allow currents of air to sweep entirely across it during the pupil's absence; and each classroom be provided with two shafts or flues from the floor to above the roof, with inlets to each at floor and ceiling levels, in addition to a large warm air grate and suitable windows it is found in practice, that adequate means for warming and ventilation are thus economically obtained.

Their effective use depends greatly of course upon the Teachers in charge of the rooms, but it is an exception to find a head-master or head-mistress who is not keenly alive to the value of the means afforded and familiar with the use of them.

Those persons who prefer a temperature of 70 degs., and who upon feeling a slight movement of the air will block up warm air inlets, paste over the outlet openings, put sand bags at the windows and rubber tubing round the doors, keep up large fires and then complain of ill-fitting windows, and draughts are, I am convinced, rare exceptions.

Vertical inlet tubes, deep sill fillets to windows and the various valve ventilators, are all useful as aids when kept clean,

but unless air is warmed before it enters a school, the inlets will remain closed during six months of the year when fires are in use. This fact accounts for the popularity of the various ventilating grates, most of which can be taken to pieces periodically for cleaning.

The assembly room, corridors, cloak rooms, lavatories, laboratory, entrance lobbies and staircases can be more conveniently warmed by hot water pipes. It should be possible to raise the temperature in the corridors, cloak rooms, laboratories, &c., to about 50° during cold weather, for the purpose of preserving a fairly equable temperature inside the building and protecting the sanitary arrangements and water services from disorganization by frost.

The small pipe medium pressure apparatus is found very useful for warming schools, on account of the small quantity of liquid used, enabling heat to be produced in less time than with larger pipes. These small pipes, moreover, can be used under skylights and in other positions where the larger pipes could not conveniently be placed.

The practice of arranging hot water pipes in channels below the floor of the spaces to be warmed, with open gratings above them, is undesirable and unnecessary in schools because of the difficulty and cost of keeping the pipes and channels free from foul matter from boots and floors.

[*For discussion on this paper see page 548.*]

"The Sanitary Construction and Fitting of Stables, Cow Houses and Piggeries," by LOUIS HANKS.

(ASSOCIATE.)

THE subject of this paper is one of such importance that it is surprising how little it is considered, and what a small amount of reliable literature, or data, is available for reference. Among the few standard works on horse and cattle management there is hardly one which attempts to deal practically or scientifically with this important branch of the subject.

Taking the subject of Stables first, it will be found convenient to divide this into two sections: dealing first with essen-

tials of planning, construction and sanitation; and secondly with the interior fittings, &c., adapted for different classes of horses under varying conditions.

It is obvious that the planning of stables must be largely governed by the site obtainable. What might be an ideal scheme as applied to a country house, with ample space available, would be quite impossible in a crowded district or town, and therefore general rules only can be laid down, which must be varied to suit specific conditions.

In the planning of large stable buildings it is a good arrangement to have a quadrangular yard entered by an archway under or by the coachman's residence and forage store, which will form the front elevation of the scheme. On either side of the yard can be a range of stables with stalls or loose boxes, with a sick box in one corner and a washing shed in another corner. The remaining side or end will contain the coach houses with rooms over for grooms and helpers, for whom separate w.c. and lavatory accommodation must be provided, distinct from that for the use of the coachman's family.

Part of the yard should be covered with a light iron and glass roof for washing purposes.

Another arrangement would have the buildings on three sides only of the yard, the coach house and groom's quarters on one side, the coachman's cottage, forage store, sick box, &c., on other side, and range of stables at end of yard. In the case of small stables for a few horses where (as in the case of most town sites), the animals, vehicles, and coachman's residence have to be under one roof, special precautions must be taken to secure hygienic conditions, and reference will be particularly made to this in connection with building and fitting. The site should be a dry one on natural deep gravel, chalk, rock, or firm sandy soil, avoiding all artificial or made grounds where possible, but any ordinary loam or clay, even the wettest, may be made suitable by proper foundations and careful subsoil drainage. In the case of a specially wet clay or other damp soil it is sometimes advisable to artificially raise the site within the walls from six inches upwards, by a bed of dry, clean broken brick, before concreting, forming a dry area round outside of walls to the same depth, the site to be deeply trenched and land drained.

In all cases of damp or low-lying ground the precaution of subsoil draining should be adopted, as this is a comparatively simple matter if done as soon as the site is cleared, but if it is neglected, or the evil is not discovered until the buildings are erected it is a most difficult and costly matter to rectify. It is hardly necessary to say that the ends of the agricultural drain

pipes or trenches filled with furnace clinker, broken brick, chalk, or otherwise which may be used, must be carried right across the site so as to discharge into a deeper graded ditch or channel right outside the walls and under the lowest level of the foundations. These precautions if carefully followed out will effectually dry the dampest site and prepare it for building operations.

Having secured a dry situation, by natural or artificial means, the foundations for the walls of the stable building will be prepared by excavation and concreting, and when this is thoroughly consolidated the building operations will be proceeded with in the usual manner, care being taken to put in a good damp course, of lead, asphalte, slates, and cement, or vitrified tile, at least six inches above the level of the external ground. The walls should be built of hard well burnt stock bricks, faced if desired with red or other fancy bricks and set in good lime or cement mortar, or of substantial masonry, set in cement. Concrete walling has been used with advantage in some cases, but demands much care in securing homogeneity in the material, and should preferably be faced on the outside with hanging tiles or cement slabs, to ensure weather-tightness, especially in exposed situations liable to driving rains.

The internal face of all brickwork should be neatly pointed or rendered with cement and sand, steel-trowelled, but for the inner walls of a stable, cow house, or piggery, where expense is not the first object, nothing is nicer than glazed bricks or tiles. These should be of a soft tint or colour, but not pure white as the animals' eyes are injuriously affected by plain white.

White should be particularly avoided at the stall heads or sides, where a soft green, buff, or grey is very nice in appearance and restful to the horses' eyes.

A very usual and economical plan is to terminate the glazed bricks or tiles at a height of 7 ft. from the floor at the head of stalls and 4 ft. 6 in. high round rest of walls, capped with an iron moulding, and the walls above smoothly cemented and painted.

If it can possibly be avoided, no rooms or loft should be over the horses' standings, and the roof of the stable should be of open timber work neatly boarded, stained, and varnished. This has two advantages, as it gives extra height and air space, and the varnished surface is impervious, sanitary, and easily cleaned.

If circumstances compel the use of rooms over a stable, the ceiling should be in *no case* less than 10 ft. from the floor, but a minimum height of 11 or 12 ft. should be insisted on wherever possible.

It is obvious that if a height of 10 ft. is desirable in a room

intended for human habitation, the greater height and bulk of a horse demands increased height and more air, so that an allowance of from 1,100 to 1,800 cubic feet should be given to each horse. This is obtained by allowing 9 ft. $\times$ 6 ft. for each stall, which with 7 ft. $\times$ 6 ft. of passage-way at heel gives 96 ft. superficial of floor space, which multiplied by 12 ft. nett height gives 1,152 cubic feet.

For loose boxes a floor space of 12 ft. $\times$ 12 ft. should be allowed where possible, and never less than 10 ft. $\times$ 10 ft., with passage space extra.

The construction of the ceiling in question should receive much more care than is usually bestowed.

The best form would be a light iron and concrete floor for the loft or rooms over a stable, as this has several advantages. It is fireproof, sound-proof, durable, and impervious to the passage of any vitiated air from the stable below. The underside forming the ceiling of the stable can be smoothly cemented and painted or whitewashed.

If a wood joist and a boarded ceiling is the only one available, several precautions must be taken.

The floor boards should be grooved and tongued, the joints stopped, and the floor of the upper rooms varnished, the under surface of the joists being carefully lathed, plastered, and painted, to form an impervious stable ceiling. A better plan in many respects, but not quite so neat, would be to form a ceiling of flat iron sheets, butted closely together and nailed to the underside of the joists. This could be painted, and would form a more permanent and sanitary surface than the lath and plaster.

If the rooms over must be used for dwellings, under no circumstances whatever must the staircase or any shaft or ladderway communicate directly with the stable, or all the vitiated air and heat will ascend thereby into the rooms above. Serious illness has been repeatedly caused in this way, and always risk and discomfort to the occupants.

An external staircase, or one divided by a brick partition from the stable, should always be provided; and if such an internal stairway is being formed, it is a good plan to make the space large enough to accommodate the hay and corn shoots as well, as fodder is absorbent of foul odours, and should not be in communication with the stable directly, as in the case of a loft over.

The stable roof can be of tiles or slates, &c., and does not call for special mention, except that provision must be made for one or more exit ventilators for foul and heated air. If one large exhaust ventilator is to be employed, as in the case of

a stable with rooms over, it must be connected with the stable ceiling by means of an air-tight metal shaft, passing down hermetically sealed through the upper rooms, and carried along the stable ceiling as a horizontal duct, having ventilating gratings in the bottom at intervals of about six feet for the entry of foul heated air, which will travel along and be drawn up the outlet shaft by the exhaust ventilator on roof.

If there are no rooms over the stable, one or more ridge or turret ventilators must be provided, with folding or sliding louvres, which can be opened or partly closed by cords or gearing as the temperature may require.

Fresh air must be admitted in such a way that each animal gets an ample allowance without draught, as draughts do as much harm as the fresh air does good. This is best obtained by fixing an adjustable louver or hopper ventilator in the wall at the head of each animal's stall or box, about two feet above the top of the stall partition.

The advantage of the hopper type is that the current of air does not blow directly on the animal, but is deflected upwards for a short distance, and then falls by gravitation towards the floor displacing the lighter heated air, and then in its turn, becoming hot and foul, consequently lighter, and rising by levitation to the outlet ventilators in roof or ceiling, as before described.

The Sherringham Inlet Ventilator is one of the oldest and best, being easily procured, cheap and readily fixed, and it will admit a sufficient supply of air for one horse or cow. The Crosse ventilator is slightly different in form, but very useful in all respects. Some of the adjustable glazed hopper ventilators made by professional stable fitters are also very good and sanitary.

The use of a thermometer should always be insisted on in a stable or cow-house, so that an equable temperature may be maintained, cool in summer and moderately warm in winter. Overheating is a thing to be avoided, otherwise the animals are apt to be chilled on going out. As long as they are shielded from damp, from the inclemency of the weather, and from draughts, the heat of their bodies and bedding will keep them comfortable and healthy. This question of ventilation is one of the first importance, and should receive more careful consideration than it usually does.

It is often difficult in town stables to get the ventilation at heads of stalls direct from the open-air, on account of adjoining buildings, and in such cases it is advisable to fix a horizontal metal shaft along the wall of stable over the heads of horses, with one end freely open to the external air, and the other end

continued up from far end of stable as a vertical shaft to above the roof.

A current of air will always travel along this, and the inlet ventilator at head of each stall is simply fixed in this air shaft, from which air will blow in freely. The top sash in every stable window also should have one pane made to hinge or swing on centres, so as to be available for ventilation. In all cases the thermometer should be watched.

The next important point to consider is the floor, which must be hard, durable, impervious to moisture, but not slippery.

Under all circumstances, whether in town or country stables, it is imperative that the *entire floor* be concreted to a depth of six inches with good cement concrete, in proportion of one of cement to six of gravel or burnt ballast, laid to proper falls for facilitating the flow of surface drainage and to keep back the ground damp. On this various kinds of paving can be laid. For a first-class stable one of the best pavings is the Chamfered Adamanatine Clinker brick, bedded in cement and well grouted with fluid neat cement. It is well coloured, hard, gritty, and durable.

The blue Staffordshire paving brick is also a good paving and largely used; but with any brick paving special care must be taken in grouting the joints thoroughly with impervious cement, otherwise the least crevice will permit drainage to soak in and smell.

For this reason large number of stables are now laid with patent cement floors, which are formed of a three inch thickness of Portland cement mixed with pulverized granite, &c., laid in situ, on a four inch bed of dry broken brick, laid to falls and with the finished top surface scored or grooved to give foothold for the animals. When properly laid and well grooved this is doubtless the best and most sanitary paving as it is homogeneous, and the absence of joints offers no entry for liquids, thus possessing an undoubted advantage over any of the jointed brick pavings. Great care must be taken in securing the best material, well laid and of sufficient thickness. It is obvious that different classes of animals require different strengths of paving. Even a two inch thickness of granite cement paving will stand light carriage horses, but the writer has seen this thickness stamped right through by heavy dray horses, for which a three inch thickness is none too much.

The all important question of drainage is now to be considered. It may be at once stated as a cardinal rule, that *no* underground drains should be permitted in a sanitary stable or cow shed.

The best plan is to have the paving itself sloped with an even

fall of four-tenths of an inch to the foot run, from sides to centre of stalls and boxes and from head to heel, also the same slope from upper to lower end of stable.

This will form a valley or depression down the centre of each standing, from head to heel, along which liquid will freely travel, to be collected by a similar shallow gutter along the heels of stalls or range of boxes, falling to the lowest point where the surface gutter will pass as a half channel pipe through the outer wall of stable, discharging over a trapped gully in the open air.

This gully should be a large and deep one, fitted with a removable iron pan or bucket to catch any dung, straw or solid matter which can be removed every day. By this means all underground drains are avoided within the building, but the objection has been occasionally raised that the shallow surface channels allow the animals' bedding to become soddened with wet, causing nuisance and discomfort. In the writer's opinion this is a very feeble objection, but to obviate this special iron sunk gutter channels with movable perforated iron covers can be fixed half way up each stall and along heels of same, jointed with proper tee and angle piece connections.

The liquids then run through the holes in the covers into the sunk gutter, which can, if desired, be made with sloping bottoms of the same four-tenths of an inch to one foot gradient already referred to.

By this means the paving can be kept nearly level, the graded gutters carrying all liquids rapidly away. All that is necessary is for the covers to be lifted off and channels swept daily.

To make this system still more perfect the draw off tap for water can be fixed at highest end of stable over shallowest part of gutter, so that the waste water can flush the gutter and the tap be turned on for this purpose.

This system will keep the stable sweet and the bedding dry, and is well worth the extra expense of construction.

Care must always be taken not to exceed a slope of four-tenths to half-an-inch per foot run in any direction for stable paving as anything steeper than this imposes an injurious strain on the ligaments of the horses' legs while standing in a stall for any length of time.

Serious trouble has been known to result from too steep a pitch. The slope of four-tenths of an inch to one foot may be relied on as the result of years of practical experience in stable paving.

The fitments of the stable have lastly to be considered. These should never be wholly of wood, as this is clumsy in

appearance, easily damaged, liable to infection, insanitary, and difficult to keep clean.

The heel posts or columns of stalls and loose boxes should be of stout cast iron from four inches to six inches diameter, and not less than five-eighths to three-quarters of an inch in thickness, otherwise they will be fractured by a kick. They should have projecting flanged bases twelve inches square, with holes for belting to a good stone base twelve inches below the ground line, or with eighteen inch long bases with a double flange for embedding in a mass of concrete. If such base fixings are carefully made they will stand the hardest wear for years without movement. The posts should be capped with a round ball head and rounded mouldings. No sharp corners, mouldings or projections can be tolerated for a moment in any stable fitting, as serious accidents have resulted from such vagaries on the part of inexpert founders and ironmongers, ignorant of stable requirements.

For the same reason no spiked or projecting post heads, brackets, or ring staples should be used. Every hard surface in a stable must be smooth and rounded off, even at the sacrifice of appearance.

Wrought iron posts are sometimes advocated on the score of less liability to fracture, but wrought iron is more easily corroded in a stable, the shafts of stable posts are simply made of thin wrought iron gas pipe with bases and caps cast on, and altogether practical experience favours the use of stout cast iron in preference to wrought iron for posts.

The divisions between stalls usually consist of an iron sill at the ground line, a panel of hard, varnished grooved and tongued boarding, about 4 ft. 6 in. high from post to wall, surmounted by a top panel of wrought iron vertical-barred grating, with a strong grooved mid-rail to receive top of boarding, and a rounded top capping, which is ramped from 7 ft. high at head of stall to about 5 ft. high at post end. This top of grating is 7 ft. uniform height all round loose boxes, having a wood panel 4 ft. 6 in. high at sides of box, but the front grating being rather more open, say three feet of woodwork and four feet of open ventilating grating. The sides of loose boxes should always be less open than the front, or the animals will be fidgetted by seeing each other. For this reason a solid panel about three feet long is often inserted at the manger end to prevent the horses seeing each other whilst feeding.

The doors of loose boxes should be strongly framed of iron or wood, with a top panel of ventilating grating, and a safety latch which the horse cannot open himself, and which offers no projection open or shut against which he can hurt himself.

The mangers should be fixed about 3 ft. 6 in. from floor, or slightly lower according to height of horse. For private stables where loose hay is used the manger fitment should also contain the hay-rack, so that the horse can feed underhead. It is well also to have a water-pot alongside, which is always handy for giving a mash, even if the horse is usually watered from a bucket. The customary stall fitment consists of an iron top plate the full width of the stall and supported on a bracket each end, having three large openings with rounded lips. To the opening at one end is bolted the hay-rack, which should have a seed-tray at bottom to prevent waste by dropping. The centre opening receives the manger, which should be wide and deep to prevent the corn being tossed out by the horse in feeding. In some cases it is necessary to put an iron cross-bar at each end to prevent the horse indulging in the trick, leaving space between for him to reach the corn but no more. The water or mash-pot is fixed at the other end of the fitting, and should have a waste-plug at bottom for quickly letting off stale water into a bucket or down the surface gutter.

Both manger and trough should be of galvanized or enamelled iron. The hay-rack and top plate being galvanized or japanned. Care must be taken that the edges of all openings are rounded and curled under or a horse will cut or chafe himself.

The front edge of the manger plate must be carefully curved under or formed into a barrel for the same reason. In many cases it is a safe and neat expedient to board in the front of the manger fitting, sloping from under the curved lip right back to the wall just above floor. This prevents crib-biting, prevents a horse getting his bedding pushed under the manger and prevents danger to the animal in rising from the ground. The loose-box manger fitment is usually constructed on the same principles but adapted to fit a corner of the box, although in some cases, especially in racing stables, the manger and hay-rack are in separate corners.

Overhead hay-racks should be avoided as the horse in pulling down his food gets dust and seeds in his eyes.

In the case of the hard-working horses of omnibus, tramway, and carrying companies, contractors, fire brigades, business firms, &c., it is so generally and successfully the custom to give them chopped hay and bruised corn mixture, that in most cases no hay-rack is used, there being one long open manger, or a manger and gruel pot in each stall. The pan should be deep and wide with cross bars at each end to prevent food being thrown out. In some cases the pans are made to lift out for cleansing, but anyhow, both plate and pan must be of painted or galvanized iron.

Much could be said on the subject of halter tyings, harness fittings, cleaning hooks, &c., but space forbids. Corn bins should be of iron with divisions, hinged lids and locks. Stable buckets should be of iron, with wood bottom rims, so as to be clean without being too noisy.

With regard to cow fittings, the general rules laid down for the sanitary construction, ventilation and drainage of stables will all apply to cow sheds, but a few additional matters have to be considered. It is advantageous in planning a cow house to arrange the standings so that there is a feeding passage between the heads of the stalls and the back wall, so that the animals can be fed without the necessity for the attendant to push by them to reach the troughs. There will of course be a wide passage at heel of stalls, and in many cases the floor of stalls is raised a few inches above the level of passage.

The divisions should be entirely of iron, situated eight feet apart for a double stall to hold two cows, or five feet apart for one cow. The divisions usually extend only about half the length of the animal, as this is sufficient. The regulations made under the Dairies, Cowsheds and Milkshops Order of Local Government Board, 1886-86, give a minimum stall space of 8ft. $\times$ 4ft. for one cow, or 8ft. $\times$ 7ft. for two cows. A slide and ring is fixed in the middle of each division for attachment of the binding chain. The food trough must be of iron fixed near the floor, or of strong glazed earthenware. If for a double stall it should have a partition dividing it into a compartment for each cow. The stall division is cut away so that the water trough is fixed midway under it sufficient for two cows, but with the division shielding one cow from the horns of the next. The hay-rack is fixed just above the manger and is usually continuous the whole length of the shed.

Nothing but iron should be allowed for the fittings, as it can be cleaned and disinfected. Wood cannot as it is pervious, absorbent, and a fruitful source of contagion. A separate apartment should be provided for a calving pen, and another one with a copper, hot water supply and impervious underground pit for grains; also bins for meal, bran, &c., quite separated from cow shed. An ample supply of water should be provided in a covered cistern fixed at least six feet above ground with open overflow, providing at least twelve gallons for each cow, the water being laid on to each cow trough, which will also have a waste plug. No w.c., urinal, or dwelling room to communicate with cow shed.

All the rules for sanitation, cleanliness, &c., as laid down for stables are even more important as regards cow sheds, on account of the important bearing on food supply.

Piggeries should be constructed with as much care and sanitary forethought as either stables or cow houses. There is no reason why the pig should exist in the usual filthy state. The styes and yard enclosures should be of iron or of brickwork cemented. The styes should have a passage at back for cleaning purposes, with doors of communication.

The yards should have the feeding troughs in the front outer wall by side of the gate, as they are much better in that position than as sometimes placed in the back wall of stye, as the animals in the latter case slop their food over their bedding in eagerness to reach the troughs. This matters less in the open yards. The troughs should be entirely of iron, with a hinged falling shutter, which can be pushed inwards and bolted, while filling or cleaning the troughs, and secured outwards at other times. The paving should be as described for stables and cow houses, with surface drainage only.

In the case of cow sheds, piggeries, and country stables, it is economical to convey the surface drainage to an impervious covered catch pit in open yard, and pump it from there as required for use as liquid manure.

In town stables, &c., even with surface drainage, a proper modern system of sanitation must be adopted, thoroughly ventilated and disconnected from sewer. The receiving gully trap outside stable wall will communicate by a watertight pipe drain, with a proper covered manhole in the yard or mews, not connected to the general house drainage, but running direct to an intercepting manhole nearest to sewer from which it is disconnected by a siphon trap, with fresh air inlet ventilator and up-cast vent pipe as for house drainage.

[For discussion on this paper see page 548.]

"Sanitary Fittings and their Connections," by W. E. BLAND, R.P.C., Lecturer on Sanitary Science, Durham College of Science, Newcastle.

WHEN honoured with an invitation to prepare a paper for this Congress, it occurred to me that one on "Sanitary Fittings," might lead to a discussion on many points connected with the subject, upon which opinions widely differ. There exists, unfortunately, a general indifference, and consequent ignorance, on the part of both owners and occupants, of the various sanitary fittings with which the average house is surrounded, an indifference, it is to be regretted, which often extends to those

responsible for the work, and many cases of disease and suffering are traceable to their neglect.

I find that certain fittings, advocated, and even demanded, by the authorities of some towns, are condemned by others, though the circumstances attending their use are equal. This should not be the case, although differences of opinion will always exist.

It is impossible to deal with such a subject fully within the twenty minutes allowed for each paper. I have therefore decided to confine myself to those fittings met with and used in an average middle class residence.

Monetary considerations are responsible for many of the evils which exist, but whilst freely admitting that cost demands thought in all such matters, I venture to think, that most of those now present will agree with me in the opinion, that many of the so-called cheap and useless fittings, now being used, should be prohibited as dangerous to health and life.

The sewer intercepting trap demands first consideration, it being now looked upon as a necessity; undoubtedly the ventilation of the public sewer, by the town authorities, is rendered more difficult by its use, but the fact of the proof that typhoid and other fever germs, discharged into a sewer, can, not only live there, but multiply and be carried in the sewage wherever it goes, leads me to think that the practice of disconnecting the house drain from the common sewer is a wise one. We should guard our homes against danger from below ground, as carefully as we do from above.

Respecting the ventilation of public sewers, I would suggest that suitable extracting shafts might be carried up the towers and steeples of churches, chapels and halls, &c., without seriously affecting their appearance; and with good effect, as such buildings are generally placed pretty central in thickly populated districts.

There is a great variety of disconnecting traps manufactured, sections of some of which I illustrate.

They are frequently placed at some considerable distance from the house, making it difficult for them to be properly cleared by small discharges, (such as from lavatories, and the two gallon flush of a water closet, which lose their force en route) if not so constructed as to form the least possible resistance. At the same time it is requisite that a water seal of not less than $2\frac{1}{2}$ inches be provided to resist the back pressure of the gas in the sewer. In my opinion, a V-shaped trap meets, most suitably, these requirements, as it contains the least quantity of water, and consequent resistance, to obtain the necessary water seal. By carefully constructing the inlet

to the trap the energy of the flush can also, to a certain extent, be concentrated at this point to act with greater force; this can best be done by slightly contracting the channel or pipe connected to the trap, giving it a quick fall, and allowing a vertical drop of some three to four inches upon the standing water of the trap.

By the extra fall the velocity is increased, by contracting the channel a deeper volume is obtained, and by the vertical drop pressure is gained, and these advantages act just at the point they are most required. I give an illustration showing the section of such a trap, and also one having its inlet and outlet on the same level.

This latter was doubtless constructed, to disconnect an old drain already laid, and save the expense of altering the level of the pipes which would be necessary to allow the trap, before described, being used. When reduced in the neck and body it answers fairly well and is much better than having no disconnection, though soiled paper and other matter will float on the surface of the standing water; these accumulate, and are liable to choke the trap if not dislodged by the bath flush or other forcible discharge.

The cost of these traps would be about equal; and yet hundreds of the latter are used on new work, where ample fall could be obtained to allow of the better designed trap being used. This, I contend, is one strong instance of the indifference to which I have referred.

Another objectionable point in connection with this fitting is, that the trap and channel are usually left open at the bottom

— Disconnecting Trap —

— SECTION —

Fresh air inlet.

Fig. 1.

— Disconnecting Trap —

— SECTION —

Fig. 2.

of a chamber provided with an air-tight cover, thus allowing the chamber to become a foul air shaft.

I think the trap and channel should be constructed to receive the air-tight cover, similar to those for iron drains, the chamber would then be for means of inspection only, and the necessity of making the cover of the chamber air tight would be overcome, a difficulty seldom effectually carried out in practice.

The stopper or cap, giving access to the drain beyond the trap, should also have a much safer means of jointing than is usually provided, or the object for which the trap is fixed will be defeated* (say a clipped brass screw cap). The simplicity with which cast iron sanitary fittings can be secured is a strong recommendation in their favour. I should, however, view with the greatest concern, the general introduction of iron drains and fittings without a rigid, and most carefully drawn out set of bye-laws first being issued, stipulating the strength, weight, coating, jointing, &c., necessary to secure a permanent result.

Otherwise, light iron pipes and fittings, roughly cast inside, without any effective protection against corrosion, and cracked sockets, would find their way into the speculative building, leaving a state much more deplorable than exists at present, on such property.

The next fitting requiring consideration is the gully-trap, generally fixed to disconnect sink, bath and lavatory waste-pipe from the house drains.

The illustration shows the section of a fitting, which is still being extensively fitted on works at present in course of erection.

This gully, by its water seal, effectually prevents the passage of bad air from a dirty drain (or sewer, where no sewer trap is fixed). It however has the failing, of not only collecting, but of retaining all manner of refuse matter, which, if not regularly cleared away, decomposes, and throws off gases, quite as objectionable

Fig: 3.

* The back pressure in a tidal sewer is sometimes quite sufficient to blow out the ordinary bedded or slipped stopper.

and dangerous as those it is provided to obviate. As a matter of fact, those kind of gully fittings, become, in course of time, so many small cesspools about a house, for they are seldom cleaned out, and when this is done properly, the cleaner runs the risk of inhaling the drain air by breaking the water-seal. The old pan closet, which has been completely banished, was little worse than this fitting.

I am aware it has been remarked, that it is necessary to collect this sediment which might otherwise choke the drain; this argument only holds good in very large establishments and hotels, where a large quantity of grease is sent in to the drains. In the average villa or terrace residence, where the drains and fittings are properly arranged, it has been repeatedly proved, that such sediment is effectually carried into the sewer; where it should go, as quickly and completely as possible.

A properly formed waste disconnecting fitting should be of rounded form, having a water-seal of not less than $2\frac{3}{4}$ in., and a large hopper top and grate, to admit of air and light penetrating to the standing water; sunlight being unfavourable to the life of most fever germs, and a disinfectant.

It should receive the discharges below the grating, so that they may act as a cleansing force upon the trap and drain; this is especially the case from a bath discharge, and I would strongly press this point as one worthy of more consideration on the part of architects and drainage contractors.

The grease-trap hardly comes within our consideration—seldom being required in an average sized residence; there are however, so many badly formed fittings used for this purpose, a brief consideration of its duties might be profitable.

Its object is to intercept greasy matter, when discharged in quantities so large as to be liable to congeal, before being carried to the sewer, and thus choke up the drains. Grease becomes solid on cooling, and can best be collected by taking advantage of this property. The grease trap should therefore have a sufficient capacity to keep the temperature of its contents low, the discharges should enter below the water level, and be made to pass through as slowly as possible, to enable the grease to congeal and separate itself from the water.

It should be ventilated and placed in an easily accessible position, as it requires frequent and regular cleansing. It should be so trapped from the drain, that it can be thoroughly

Fig. 5.

cleaned out in all its parts without breaking the water seal. The general form of grease trap receives the discharges on the surface of the water, breaking up the grease, and making it difficult to clean out, with loss of water seal in doing so.

Irregular attention, the unpleasant operation of cleaning out such traps, and the difficulty of disposing of the grease as it accumulates, has led to the adoption of an Automatic Flushing Tank, of sufficient capacity to break up the solid grease, and carry it in that form direct into the sewer.

There are several other external fittings I should like to deal with, but want of time renders it necessary to pass on to internal sanitary fittings.

Water-closets naturally call for first attention, as there is no other fitting with respect to which such a difference of opinion exists.

In some towns I could name, the wash-down style of closet is objected to, and the wash-out demanded; whilst in others further north—Glasgow, for instance—the wash-down is insisted upon, and the wash-out condemned, and yet the water company's regulations, in each case, stipulate a two-gallon flush.

We all know that large numbers of these fittings have only the recommendation of cheapness, and their use practically means laying on sewer gas to a house, instead of protecting its occupants from such a danger; the fact, however, that they are still daily being fixed shows that indifference still largely prevails on this important matter.

The best way to face the difficulty of deciding which are the

most sanitary is to find out what are the chief requisites of a really efficient water-closet. Briefly, they are as follows:

- 1st. Simplicity of action in its working parts.
- 2nd. A perfect and efficient water seal of not less than $2\frac{1}{2}$ ".
- 3rd. That no dry surface shall be exposed to contamination.
- 4th. That the basin shall retain a sufficient area and depth of water to immediately drown the deposits, and prevent smell whilst in use.

5th. To have a flushing arrangement that will enable the contents of the basin and trap to be completely changed by the regulation flush.

6th. To have a secure and permanent means of connection to the soil pipe or drain, that can be easily examined, or repaired when desired.

I am no advocate of ornamentation on water-closets; providing, however, its usefulness is not interfered with, it may be added to any extent, and a pet name given to it also if so desired.

The fittings at present in general use are known as—

- The Valve Closet.
- „ Hopper Closet.
- „ Wash-out Closet.
- „ Wash-down Closet.
- „ Siphonic Closet.

The Valve Closet was about the first introduced, and with its improvements up to date is still, when properly constructed, one of the best fittings in the market, having all the above requirements, with the exception of the first—simplicity of its working parts.

It should be constructed on the "Pedestal" principle, so that the wood casing and objectionable safe can be dispensed with, should have a flushing rim (not pan), and its overflow ventilated and out of reach of contamination.

When discharged it allows a large body of water to go down with the excretal matter, which prevents, to a great extent, the furring and staining of the soil pipe and

drain (an important item). It is, however, too costly for general use, and, indeed, unsuitable also, requiring more consideration in its use than it would be likely to receive.

The hopper-closet is well known, and when properly shaped will, with attention, do its work fairly well with an ordinary flush.

The hopper should be short and fixed on a pedestal base (without casing), preferably of lead, which allows of a soldered joint being made on the outlet-side of the trap, or a brass thimble to caulk into the drain.

Its weak point, however, is that it retains insufficient water, and exposes a large area of dry surface to contamination, which no ordinary flush can possibly keep clean without the assistance and free use of the closet brush, which it too seldom gets. When lead traps are used they should be freely ventilated to prevent their destruction from within, and protected from lime and cement against a similar action from outside.

Fig. 7

The wash-out kind was next constructed to obviate the exposure of so large a dry surface associated with the hopper style, by the introduction of a dished out basin containing a body of water. It is not possible, however, to obtain a depth of more than three-quarters of an inch in the dished portion (quite inadequate), without introducing a resistance too great for any ordinary flush to effectually remove together with the contents of the trap. The traps are so shallow in some of these closets that not more than three-quarters of an inch water seal is obtained. I need hardly

say it is not safe to use such a fitting. The out-go is so placed that a large portion of the flush is washed against the side of the basin. When this closet is adopted care should be taken to fix the cistern at such a height as will not give the flush a force strong enough to rebound from the side of the basin, or an eddy will be formed in the dished part that will prevent it being cleared

Fig. 8.

of its contents. This can best be overcome by a combined stream and rim flush.

Generally speaking this kind of closet meets few of the requirements of an efficient appliance, and I do not feel justified in having it fixed especially with a two-gallon flush.

The wash-down closet was introduced as an improvement on the wash-out, and I think a decided advance in the right direction; when properly constructed a large area and depth of water can be retained in the basin, providing an efficient seal to the trap. The outgo being from the bottom, the full force of the flush acts immediately to clean the basin and trap together.

The connection should be made above the floor-line. An after flush is also necessary to insure the full seal of the trap being retained, and care should be taken to see that this after flush chamber is so placed as to entirely empty itself, or it is liable to fracture by frost in winter.

The siphonic action has been recently applied to water-closets with very good results. A depth and area of water can be retained quite equal to the valve closet, without any mechanical working parts to get out of order; an extra deep seal of from $3\frac{1}{2}$ in. to 6 in. can also be obtained. They can be effectually flushed by an ordinary syphon cistern, and are quick and quiet in action.

Its connection can be securely made by means of a soldered joint.

In every way this style of closet meets with the requisites mentioned as being essential in a perfect closet-fitting, and will no doubt, when better known, come into general use.

Fig. 9.

Fig. 10.

A closet that is silent in action is much to be desired. It is most annoying to have your sleep disturbed by a rushing of waters and creaking of levers and valves; it is equally unpleasant to have your visits to such places advertised in a similar manner.

There are several methods of connecting the basin and the soil-pipe, a most important item, and yet one upon which the greatest indifference and carelessness prevails. I dare venture the assertion that over seventy-five per cent. of the closets fitted in this district during the last six months have been connected to the soil-pipe or drain by a slipped putty or red lead joint, which cannot be looked upon except as a doubtful and improper connection.

Surely authorities who have power to condemn a defective joint in a drain outside the house and below the ground, should have power to condemn such an imperfect connection inside the house. If they have not such power it is time they had, and that it should be immediately exercised in stopping at once and for good so dangerous a practice, in all new buildings at least.

I illustrate many efforts that have been made at various times to ensure a perfect joint to the soil-pipe, as follows:—

The brass socket and cement caulked joint.

The brass ring and bolted rubber ring joint.

The threaded basin and brass collar joint.
 The soldered lead joint (most secure).
 The porcelain and lead soldered joint.

PORCELAIN & LEAD SOLDERED JOINT.

The latter is gaining daily favour and is a clever arrangement.

By coating and burning a metallic substance upon porcelain it practically becomes alloyed to it in such a manner that will enable a soldered joint to be made effectually. A fairly secure soldered joint can also be effected without the coating.

Care is equally necessary in connecting the lead and iron pipes, which is also generally made by the "unreliable-slipped putty-joint."

The more secure methods of making this connection are as follows:—

1. By a tapered flange and bolted joint.

TAPERED FLANGED & BOLTED JOINT.

2. A grooved and turned flange and gland joint.

3. By soldering a brass or copper nipple to the lead and caulking it securely into the iron socket, the latter arrangement is looked upon as most secure, as a galvanic action is liable to be set up where lead comes in direct contact with iron.

— BRASS THIMBLE CONNECTION —

Similar care should be exercised in jointing the soil-pipe to the drain at the foot. A deflecting foot-shoe should always be provided if the discharge has a direct vertical drop.

The question of the flushing of closets will be brought before you by others during the Congress; I will therefore pass over this part of the subject with the brief remarks that, whilst two gallons can be made to clear a closet fitting, it is obviously absurd to expect it to keep the soil pipe from a third or fourth story closet clean; and whilst this limited supply is enforced, I contend it is impossible to obtain that perfection in sanitary arrangements so much desired.

Baths, lavatories, and sinks in their turn require the same careful consideration in construction.

It is important that the outlets should be somewhat larger than the trap and waste pipe, so that a sufficient influx may be

obtained to entirely fill and clear them, and pass quickly into the drain with the same object.

Little fear need be entertained about the cleanliness of drains having a properly arranged bath discharge into them at the head of their system.

It is a very common fault to fix unnecessarily large traps below these fittings. It should be obvious to all, who will give the matter fair consideration, that a trap which is larger than the inlet grate feeding it cannot be properly flushed; it accordingly fould and becomes as objectionable as the dirty waste pipe, the smell from which it is intended to prevent.

Waste and overflow fittings present the greatest difficulty. They are generally cast on and form a part of the appliance, being in dark, concealed places, and quite inaccessible for cleansing purposes.

Such arrangements cannot be considered as satisfactory from a sanitary point of view. I have already spoken of the influence of light, especially sunlight, as a powerful disinfectant, and destroyer of bacteria.

The great object to be arrived at, therefore, is to have all the fittings exposed as far as possible to the light. The overflow pipes should not be cast on, but separately fixed to the fitting, in such a manner that they can be easily disconnected and cleansed. The trap should be fixed immediately under and close to the outlet, so that the least possible surface is exposed to contamination.

The illustration shows a very neat arrangement applied to the baths of a Glasgow firm. I should like, however, to have

SECTIONS SHOWING QUICK BATH WASTE
ARRANGEMENTS.

seen the overflow unattached, say in the form of a strong

glass tube, with a ground-in joint at the bottom, so that it could be lifted out and put under the tap when fouled. I do not see any difficulty in its application to either a bath or lavatory.

The practice of fixing baths along the side of the wall is neither necessary nor proper. They should be fixed in such a manner that free access can be had all round them. I have frequently traced an objectionable smell to an accumulation of soapy splashings between the wall and the bath.

Of all sanitary fittings inside a house the scullery sink demands special attention, being frequently situated where food is prepared and stored.

It should be of a material that will not retain filth within its pores; dressed stone, therefore, is objectionable, as also is wood. Enamelled fireclay or tinned copper seems to be the best kind of material for general use. The sink should be fitted on galvanised brackets fixed in the wall, which leaves the whole space below clear for easy sweeping and cleaning, besides being more convenient to work against.

Glazed brick piers and pedestals are preferred by some, and

can, of course, be easily cleaned. Wood bearers or casings, however, should never be used.

The back (and side also if fixed in a corner) should be carried up the wall some 9 inches, to prevent splashes from dirty, black and greasy water accumulating between the back of sink and wall, with a result that can readily be imagined.

It is frequently remarked that a sink discharge pipe is so short, as a rule, that no trap is necessary—indeed is only an impediment—whilst to allow a passage of air through the pipe is a distinct gain.

I can fully endorse the latter portion of such an argument, providing the air is made to pass to the outside of the house.

But to pass air into the house through a dirty waste pipe immediately under the nose of a servant who may be preparing articles of food, is to my mind a practice which cannot be defended.

Should any person be in doubt as to impurities the air can take up on its passage through such a pipe, I would suggest that they passed their handkerchief down, after which process, I venture to think, they will have visible proof.

The deservedly condemned slipped-putty joint is the general means of connection for the waste pipe. A proper brass fitting with coupling for soldered joint, however, is just as necessary for a sink as a bath or lavatory, and it is difficult to find any other reason than indifference on this subject to explain why they are not always used.

In concluding, I am aware that my remarks may not be altogether new to many present, but the fact that there exists so much indifference, and so many bad appliances in use, is, I think, sufficient excuse for bringing this subject before the Congress.

Who is responsible for the present deplorable state of things, and how can they be best remedied, are queries that require an answer.

The growing desire to obtain everything on the cheap, including our health, has led to a most unjust system of competition amongst many of those responsible for the conduct of this branch of engineering, resulting in inferior workmanship and material being used.

The chief fault however, in my opinion, rests with those charged with the responsibility of protecting the health of the community against such evils. The present duties of "Sanitary Authorities" fall far short of the requirements of the times. It may be that they are not provided with the legal power necessary to enable them to carry out their duties as they could wish; it may be that their duties are too numerous to be effectually attended to; or that many of them have never had the training necessary to enable them to properly carry out the Sanitary Engineering branch of these duties. Be that as it

may, the fact that defective and dangerous arrangements are being daily exposed, on *new* as well as old buildings, proves conclusively that the public health has not yet got that protection it should have.

Whilst admitting freely that much has and is being done by this valuable institution, assisted by the Medical profession and others, to remedy existing evils, I am of opinion that a stronger influence for prevention is necessary, and that the time has arrived for the creation of a New Government Department, or "Central Board of Health," to whom should be delegated all questions relating to domestic sanitary construction, including the selection or otherwise of sanitary appliances generally, with power to issue bye-laws for the guidance of Sanitary Authorities, and to restrict arbitrary (though oft-times well meant) judgments of individuals, water companies, and others. By this means some uniformity of practice throughout the Kingdom would be secured.

The duties of Sanitary Inspectors are now becoming so responsible and important, that ample remuneration should be offered with a view to the public securing the services of thoroughly qualified and specially trained engineers, and who should be clear of undue local influences.

[*This discussion applies to the Papers by Mr. J. OSBORNE SMITH
Mr. LOUIS HANKS, and Mr. W. E. BLAND.*]

THE CHAIRMAN (Mr. D. Balfour, Newcastle-upon-Tyne), referring to Mr. Bland's paper for a moment, said surely there were few water companies who would insist on providing a two-gallon flush only. Bye-laws and other enactments ought to prevent anything of the sort being possible. As to soil-pipes, he thought they ought always to be outside, and never inside, as he had noticed them in several parts of Paris quite recently. The ventilation opening in closets, he thought, was often overlooked in the administration of bye-laws. There should be a full and permanent opening at the ceiling, as the Local Government Board embodies always in bye-laws.

Dr. HERBERT JONES (Crewe) said he should like to say how very opportune was the paper upon the construction of elementary schools, for the Education department appeared to be sanctioning plans for buildings which were not in accordance with some of the conditions which most of them considered were necessary. Take one point which was emphasised and which could not be too strongly insisted upon, that all windows should reach the ceiling level, for in more than one instance which had lately come under his notice this important requirement had been entirely ignored. He could not agree so cordially with the Author when he advised that windows

should only be upon one side of the room, to the left of the pupils, undoubtedly the proper position; but if the room is a wide one, one-half will receive little or no sunlight, more especially if the street is narrow, or if opposite to the schools there are high buildings. He was sorry that Mr. Smith said nothing about the construction of the floor of the playground; this was a very important point, for if any substance such as ashes were laid down, the ground got very dirty in wet weather, and in dry much dirt and dust would be carried into the school. There must be an impervious and hard substance for the floor of a playground. He was sure all would agree with the Author that for purposes of ventilation there should not be a heavy wide sash window too heavy to be readily raised. He was glad also to hear the protest against sunken hot-water pipes placed beneath a grating. How this was ever allowed to be done in public buildings he could not imagine, yet the condition prevailed not only in schools but in public halls, and very constantly in churches, indeed he had noticed such an arrangement only yesterday in the Cathedral at Newcastle. There was no doubt that tuberculous matter must often have got deposited in those channels, for a man with a tuberculous cough not caring to expectorate upon the floor of the church, would not hesitate to spit on to or beneath a grating, where there would be an excellent nourishing ground for the bacillus, which would be inhaled in turn by a subsequent worshipper, and thus the circle completed. Referring again to the subject of ventilation, he thought that in those towns where electric power could be had they might very properly use electric fans; the cost was not great, they were very readily set in action, and extracted the foul air from a room very speedily.

The Rev. P. C. FORTIN (Lanchester) said that he had not heard the whole of Mr. Osborne Smith's paper, but he quite agreed with him that to obtain the maximum of light the windows should go up to the ceiling, and also that they should be only on one side and end, or ends of the school. He could not agree with the last speaker, who was in favour of windows on both sides, as this had an injurious effect on the eyesight of the children. He spoke from some little experience; for twenty-five years he had been manager of three different schools, and ought therefore to know something about the matter. In two of the schools the children sat with their backs to the light, and faced a wall on which were hung maps, pictures, &c. In the third school, on account of the position of the door, the children sat facing the windows, and his attention was drawn to the number of children who suffered from weak eyes and defective eyesight. He found upon examination that the number of such cases were greatly in excess of those from the other two schools put together. Thinking the matter over, he had come to the conclusion that the evil arose from the fact of the children having constantly faced the light. He had had the desks therefore re-arranged in such a way that the children sat with their backs to the windows, and he was happy to say with very successful results. There were now no complaints from the children about their eyes; they did their work much better

than they did under the old conditions, more particularly as regarded writing and drawing. Raising their eyes from their books or papers, they were rested by looking at the wall opposite, and this would have been impossible if the light had come from both sides. Above all things clouded or obscure glass should be avoided, as it had a most depressing and bewildering effect upon the children. It had been suggested that the school desks might have been placed in various positions according to the windows, but a very little practical knowledge of school work would soon have shown that this was impossible, as the classes would have been broken up, and the teacher would have lost command over the school. For elementary schools, the regulations issued by the Education Department would generally be foundamply sufficient.

Mr. MOSS FLOWER (Bristol) said he had listened with a great deal of interest to the papers read by Mr. Hanks and Mr. Bland. He could endorse all that Mr. Hanks had said, and considered that most of the suggestions made as to the fittings of stables were very good. Mr. Bland made a suggestion as to carrying of sewer-ventilating pipes up the sides of churches. That, on the surface, looked a good plan, but he feared they would find a good deal of sentiment in opposition to it. In building new churches the thing might be arranged. Mr. Bland concluded his paper by referring to the fact that incompetent men were often appointed sanitary inspectors. He knew this was so in many instances, but he thought that Mr. Bland would agree with him that it was practically impossible, with the small staffs that we had in our towns and districts, to get perfection by inspection. It seemed to him that we could only get this by educating the public, and setting forth at all times a good standard of work. The employment of a good number of efficient sanitary inspectors would, of course, go a long way to bring this about.

Mr. ROGERS FIELD (London), said he agreed with the last speaker that what was now wanted more than anything else was that the public and the Local Sanitary Authorities should be properly educated in the right way of looking at these matters. That was one great object of the Sanitary Institute; and he thought that the paper by Mr. Bland was the very sort of thing wanted to educate the public and Sanitary Authorities. At the end of Mr. Bland's paper he asked why it happened that if there were very good bye-laws on this subject that they were not put into force. He thought it arose chiefly from ignorance. Members of Sanitary Authorities thought these were small details, and did not see the importance of them. But if it were pointed out, in the way suggested by Mr. Bland, that some of these matters which seem so trivial may mean the difference between good sanitation and bad sanitation, he thought that the authorities would take them up, and see that they had proper bye-laws, and that they were carried out. He was disinclined to say much about details, because one ought to study the paper carefully before giving an opinion. But there were one or two things that he should like to mention. There was the

question of using cast-iron pipes for drains, which was becoming a very important one. For the last 20 years he had devoted himself very largely to the question of the drainage of large institutions, such as hospitals, asylums, schools, as well as of houses. For many years he never used iron pipes except where drains passed under buildings, and then he always used them. In ordinary cases he used stone-ware drains, laying them on concrete, and jointing them in the best way that he could. It had frequently happened that after a lapse of years he had been asked to examine and test the drainage again, and his experience in this connection had very much altered his opinion as to stone-ware drains. In a large number of cases where stone-ware drains had been laid in the best way, and left absolutely water-tight, he had found that when re-tested after such lapse of years, they were leaking, whereas in no single instance had he found an iron pipe which was not sound. That experience had induced him lately to use iron pipes very largely. In fact, in many large institutions every drain he constructed was of iron pipes, and the first cost was not so much greater, as one would think, than that of well laid stone-ware drains. Mr. Bland said if iron pipes were going to be used there ought to be rigid regulations with regard to size and weight. To this he quite agreed. The iron pipes that he had been speaking of were heavy ones of cast iron, properly coated, and they lasted admirably. But if in Specifications they merely mentioned "iron pipes," without stating details, builders would get very light ones—and even rain-water pipes—and the consequences would be worse than the condition of things they sought to remedy. Again, Mr. Bland mentioned grease traps, in which grease collected and remained until some person came and cleaned them out, in order to prevent the matter getting into the drains. He soon found that these grease traps were abominable things, from which the most offensive smells arose. He had to give them up, and to take to the modern practice of putting the grease into a large receptacle in which it would cool, and then flush it out by an automatic flushing tank.

Mr. ARCHIBALD DUNN (President of the Northern Architectural Association) said he was sorry to have to say that he could not agree with some of the observations that had fallen from Mr. Rogers Field on the question of drainage. The large question had been raised as to whether iron pipes should be used instead of earthenware pipes. He thought if ever that were adopted it would be a great misfortune. He thought it would be found, if the experiment were tried, that iron pipes did not last as long as ware pipes. He had examples of the latter which had been buried in the ground for centuries, and which, upon being taken out, were found to be as fresh as they were when they were put into the ground. He had little hesitation in saying that they had no examples of iron work—cast or wrought—of which the same could be said. He was one of those who thought that they used far too much iron in the construction of their buildings, and he thought if iron pipes were substituted for earthen-

ware pipes for sewage purposes it would be a great misfortune. He thought the time would come when some structures of iron, such as our bridges, would have to be replaced to prevent falling. The deterioration of iron could not be got over, his own opinion was even if iron pipes were enamelled and all precautions taken, it would be a great misfortune to adopt the change referred to.

Mr. J. OSBORNE SMITH (London) said he was extremely grateful for the cordial way in which his notes had been received. He did not know that there were many matters calling for explanation; but he would like to have made quite clear what was meant by windows on one side of the room, because on that point experience had taught him to hold strong opinions. A class room should be mainly lighted from one side—the side on the left of the children—and it was quite possible, no matter what might be the size of the room, to adequately and thoroughly light it from one side. He had seen class rooms with windows put in to avoid a blank wall, and not at all necessary for purposes of lighting. The reversing of desks would be difficult in a properly-managed school. The schools he had been referring to were not elementary schools, with large class rooms, but secondary schools, with rooms for 30 to 40 pupils. He did not think the suggestion as to the desks would be workable in such a school. As to the floor of the playground, it should be impervious. A gravel floor was a great nuisance in a playground. Something had been said about electric fans for improving ventilation. He had in the course of his experience to take out a number of mechanical appliances in secondary schools because they did not get properly looked after. He would like to say, with reference to one of the other papers, that he could corroborate very strongly the remarks made by Mr. Rogers Field about grease traps. They were things that ought never to be put in at all now, unless connected with a flush tank. It was a rare thing to find them anywhere now. They used to cause a great deal of annoyance and inconvenience. He would also like to say, with reference to the exposing of pipes, that all pipes, including gas-pipes and water-pipes, should be exposed. It was often a terrible nuisance to find pipes buried in plaster.

Mr. LOUIS HANKS (London) thanked them for the kind manner in which they had received his paper. It had not provoked any expressions of dissent, so he ventured to conclude that it had found acceptance. While we were thinking so much about the sanitary surroundings of human beings, he thought it would not be out of place to consider those of animals. Possibly he dwelt too much on the sanitary fittings of stables, but he wished it to be understood that his remarks applied equally to cow-houses, for they were of great importance.

Mr. W. E. BLAND (Newcastle-upon-Tyne) said there was one thing which had given him satisfaction and that was that his paper should have been criticised by so able a gentleman as Mr. Rogers Field. Being Lecturer at the Durham College of Science, it was absolutely necessary that he should get his information, as far as

possible, from facts and experience. The information would naturally be acted upon in the course of time as students got older and it should be correct as far as it could be obtained. With regard to grease traps he would call attention to an ordinary yard gulley which was usually fixed, he thought, to collect greasy sediment from the ordinary house sink. With Mr. Rogers Field and other gentlemen who had spoken, he fully agreed that the principle was wrong. He had seen as much as four to five gallons of sediment (of the most objectionable nature) taken from fittings of that description. He wished most strongly to endorse the opinion that they were the wrong sort of fittings to use, although they were at the present time being fixed in large numbers, and to really good houses. Grease traps should only, he thought, be used in exceptional cases where a large quantity of grease was likely to collect from the preparation of savouries, sauces, &c., and stop up the drains. The principle of breaking up the grease by a flushing tank was the right one to adopt in all cases where they were used. With regard to the tray below valve closets, he particularly stated that valve closets should be of the pedestal kind, without wood casing. Consequently no tray was necessary, as any splashing would fall on the floor and be washed up as it occurred. The tray was objectionable, as it always got splashings from the closet and became offensive. Where they had a pedestal closet there was no necessity for a tray under it.

A MEMBER: How do they get over the difficulty of placing a valve closet on a boarded floor without a tray?

MR. BLAND said it was advisable to have the floors of all closets prepared of such a material that splashings were not likely to sink in. With regard to the question raised as to Sanitary Inspectors and their staff being frequently too limited, what he desired more particularly to suggest was that the sanitary engineering branch of the present inspectors' duty had recently become so important, that it would be better to place it in the hands of thoroughly qualified Sanitary Engineers, who would be under the direct control of a new Board of Health. By that means undue local influence would be removed, and he thought greater protection to the public would be obtained by a higher class of work. He could only express his sincere thanks for the manner in which his paper had been taken up.

"On the Ventilation and Lighting of a Church," by JOHN T. BRODIE, Assoc.M.Inst.C.E.

(MEMBER.)

THIS paper gave a general description of the church of Holy Trinity, Whitehaven, with details of the ventilation by means of eleven fixed hoppers in the windows and seven outlet ventilators in the ceilings. The installation of electric lighting in the church was also described.

[For discussion on this paper see page 560.]

On "*The Diameters and Inclines of Drains and the Flush, etc., necessary for Household Purposes, together with the results of Actual Experiments made by the Newcastle and Gateshead Water Company in conjunction with the Northern Architectural Association,*" by ARTHUR B. PLUMMER, F.R.I.B.A.

ABSTRACT.

IN March of this year, as Hon. Sec. of the Northern Architectural Association, I received a letter from Messrs. Oliver and Leeson, Architects, drawing my attention to the fact that the Newcastle and Gateshead Water Company were again requiring in their revised regulations (then issued), that service cisterns in connection with w.c.'s should not allow of a flush of more than two gallons. I was desired to get up a memorial amongst architects and others requesting that four gallons might be allowed. Previous to taking any steps in the matter I called upon Mr. Smith, the Secretary, who at once kindly went with me to the Company's yard at The Manors, Newcastle, in order to introduce me to Mr. Askwith and to draw my attention to excellent fittings and cisterns recommended and used by the Company.

With the use of such fittings it was reasonably maintained that a two-gallon cistern was all that was necessary for flushing purposes within a residence, and it was mentioned that water companies were not required to provide water for flushing drains outside a dwelling but simply for domestic purposes.

The representatives of the Water Company next invited Mr. Leeson and myself to a further interview at The Manors' Yard, and thereupon very kindly arranged to fit up various cisterns and w.c. fittings, and lengths of drains for our further private inspection before inviting the members of the council of our Association to give the matter their consideration. On May 29th, Mr. Leeson and I spent a morning at the Manors' Yard, together with Mr. Alfred L. Forster and Mr. Askwith of the Water Company. We made a number of experiments and tests in connection with the various apparatus then fitted up.

There were two lengths of drain laid (each about 83 ft. long). One length was formed of 6 in. drain pipes, with a fall of 1 in

40, having a Buchan Trap 19 ft. from where the drain gradient commenced, with an obtuse bend at 12 ft. from the discharge mouth of the drain.

The second length was formed of 4 in. glass lined pipes, with a fall of 1 in 60, having a Buchan Trap at 6 ft. from the start of the drain gradient, with a right angle bend at about 12 ft. from the discharge mouth of the drain. (See Plans, p. 557, and Tables, p. 559.)

Various w.c. apparatus were fitted up in connection with these two lengths of drain, and were placed at heights representing the ground and first floor levels of a dwelling house.

We first tested the 6 in. drain with a ground floor Shanks' two-gallon flush syphon cistern with a $1\frac{1}{4}$ in. flush pipe. The distance from the water line in the cistern to the top of the wash-down basin was 3 ft. 8 in., and from the top of the basin to the bottom of the pipe where the drain gradient commenced was 3 ft. 8 in. A mixture of soft soap and sawdust weighing $10\frac{1}{4}$ ozs., without paper, was placed in the basin. The first flush cleared the basin, but it was not till the sixth flush that half the charge came out at the mouth of the drain, and at the eighth flush the remainder came out.

We carried out eight other similar courses of tests with various flushes, &c., detailed particulars of which have been retained. We noticed from the foregoing tests that although the 4 in. drain was not of so steep a gradient as the 6 in. drain, and although it also had a much more acute bend in it, the result of these experiments was decidedly in favour of the smaller drain pipe. Sufficient had been done during this morning's work to convince those present of the importance of these experiments; it was felt, however, that the only way to obtain exact results was to make a very large number of similar experiments in connection with each drain and apparatus, and to strike an average of the results in each case.

The water companies' representatives proposed that the Northern Architectural Association should send a representative to work in conjunction with their Company's agent in connection with these proposed further tests, and in accordance with this suggestion such arrangements as were desired were subsequently agreed upon.

I think we may take it for granted that no water company would desire to supply less water for flushing purposes than such an amount as may be the minimum quantity necessary. It would be undoubtedly penny wise and pound foolish to supply too small a flush, as in such a case two or more flushes would be found to be necessary, and would undoubtedly be used by consumers instead of one of adequate amount. Now that

pedestal closets are being universally introduced, and are used at all times and for all sorts of household purposes, the much greater amount of water wasted and used than was formerly the case, becomes a matter of serious consideration for any Water Company.

I am clearly of opinion that all syphon cisterns are a mistake, so far as Water Companies are concerned, and they are not necessary from other points of view. Of course in the case of syphon cisterns, the full amount of the flush, say two gallons, is obliged to be used upon every occasion, whereas with other cisterns only half a gallon can be used if desired, and in many instances may be all that is necessary, on other occasions it is however, quite indispensable that the handle should be pulled till the full two-gallon flush is obtained.

Various architects have for a long time been convinced, that many local authorities often compelled drains to be laid of unnecessarily large diameters in connection with private properties, and have felt that if only such authorities could be convinced that such is the case, it would be a decided advantage. If the Water Companies' experiments help to prove that drains of as small a diameter as necessary are more easily flushed and kept clean with a minimum flush than drains of an unnecessarily large diameter (which more easily choke up and become foul), we may reasonably expect that some good will be the result of these experiments.

I know of instances where in the case of drains from even single w.c.'s, nothing less than a diameter of six inches will be allowed by local authorities. I may mention that the Education Department seem to understand the importance of not having large drains; in their Code of Regulations they state that four inches in diameter is sufficient to receive the discharge of as many as ten w.c.'s. I find that the bye-laws of the various local authorities in the north of England practically leave the question of the diameter to the discretion of such authorities. It is generally stated that "the drains are to be placed in positions, of such size and of such materials, and at such levels as may seem to the Council sufficient for the purpose of effectually draining the same," or else it is stated that "every drain shall be of adequate size, and if constructed or adapted for conveying sewage to have an internal diameter not less than four inches." It would seem to me to be desirable that the maximum as well as the minimum size of drains should be stipulated and considered, and that a regular scale of sizes of drains should be drawn up and included in the bye-laws (as in the case of the various thicknesses of walls); if such scale were not binding in every case it would at any rate be able to be

NEWCASTLE AND GATESHEAD

Tests made with 2 Gallon
Valve Cistern.

3-INCH IRON PIPE DF

HEAD WATER COMPANY.

Gallon Alternating
istern.

PIPE DRAIN.

ION.

N.

Tests made with 2 Gallon
Valve Cistern
3-INCH IRON PIPE [

Valve Cistern

3-INCH IRON PIPE

ELEVATION.

CISTERN

1 1/2"

7' 9 1/2"

A

CISTERN

1 1/2"

13' 9 1/2"

B

RADIUS 8 1/2"

GROUND LEVEL

FALL 1 IN 48

2-INCH IRON PIPE

PLAN.

3-INCH IRON PIPE

3-INCH IRON PIPE

EAD WATER COMPANY.

Gallon Alternating
stern.

PIPE DRAIN.

ION.

N.

referred to as a guide by any council or architects as to how they should use their discretion.

I may perhaps mention that the London County Council made an application to the Local Government Board last year desiring that the flush might be increased from two to three gallons, the result of this enquiry was that the two gallon flush was adhered to. I am of opinion that two gallons is sufficient for satisfactory sanitary apparatus, but not enough for flushing large drain pipes laid to a gradient of from 1 in 40 to 1 in 80; of course many cisterns, nominally two gallons, contain either more or less than that amount. If consumers obtain water by meter, they can, of course, have a larger flush, and in certain cases this may be necessary, or else by some means they should have drains of a size and incline, &c., that can be flushed with the Company's allowance of water.

On August 11th a new series of tests was commenced, when four 82 ft. lengths of drain were laid to a gradient of 1 in 40, and alongside each other, viz.: 6 in. and 4 in. sanitary pipe drains, and 4 in. and 3 in. glass-lined metal pipes. Each length had an almost right-angled bend at 12 ft. from the mouth, at a further distance of 4 ft. there were Buchan's traps in the 6 in. and 4 in. pipes, and a Dubois' trap in the 3 in. pipe, at a further distance of 8 ft. there were four junctions in connection with yard conveniences, 58 ft. beyond the drains were connected with four soil pipes, each having connection with ground and first floor w.c.'s. All the cisterns were two-gallon, with 1½ in. flush pipes and Hopper basins.

We started to experiment with the 6 in. drain by charging the top floor w.c. with a six ounce solid mixture of soft soap and sawdust, &c., as before, and flushing with two gallons, the same thing was next done in connection with the ground-floor closet and then with the yard w.c. We commenced again and continued in rotation as before till each of the three closets had been flushed and charged twenty times, after the fourteenth round the drain was entirely blocked. Of twenty-two and a half pounds put in only seven passed out. Considerable force was necessary with a hose-pipe next morning to clear this drain out again. Similar experiments in connection with the 4 in. sanitary pipe resulted in the charge passing much more freely through it till a stoppage took place at the end of the sixth round, and again a very considerable flush was necessary to clear the drain. In the case of the 4 in. metal pipes the results were satisfactory and the 3 in. metal were even more so, each charge practically came direct through the drain with each flush and it therefore became unnecessary to again test this drain under less severe circumstances.

It must be remembered that in allowing a two-gallon flush, the Newcastle Company are only doing what almost all other companies (who give the matter much consideration) in the kingdom do, with I understand the exception of Southend, where a two-and-a-half gallon flush is conceded. This was however agreed to before the date of the Local Government Board Inquiry, already referred to. This also is the case with Bradford where there is (or was) a three-gallon flush. I may however mention that there was a very serious water famine at Bradford two or three years ago. It would perhaps be possible satisfactorily to meet the requirements of water companies, and the present demands of local authorities, by having large drains of a V or egg-shaped section.

The drawing shows a section of drain-pipe proposed by me, which maintains the advantage of the circular exterior with the small and large circular interior for flushing and flood purposes; it also avoids the objection of being top-heavy and difficult to manufacture, as is the case with the otherwise excellent egg-shaped pipes.

In the drawing the darker portion represents the section of the spigot end of the pipe, and the outer lighter portion the section of the socket.

Another satisfactory course would be to convey waste water from baths, etc., to a flushing tank at the head of the drain, or where bath wastes can be conveyed direct there; no better flush could be desired under any circumstances.

We conducted a further series of tests at the water company's yard, allowing consideration for other water flowing in the drains between the use of the w.c.'s. The closets were therefore charged in the same way as before, and in the same rotation, but after each flush with the charge in it, each cistern was discharged a second time into the drain simply as water without any charge. In no case was this second flush of the nature of a 4-gallon flush at one time, because the first flush was allowed to be cleared through the drain and the cistern to

NOTE.—Somewhat similar designs for drain pipes are illustrated in "The Transactions of The Sanitary Institute," Vol. IX., pp. 283, 292.—ED.

fill again before the second was discharged into it. In the case of the 6 in. drain the second flush had the effect of preventing the stoppage, as was the case in the former tests, and the 4 in. and 3 in. pipes worked satisfactorily.

A third series of tests, similar to the first, was conducted with a two-and-a-half instead of a two-gallon flush, with the result that the 6 in. pipe now worked satisfactorily, and it therefore became unnecessary to test the 4 in. and 3 in. pipes in this way. I am of opinion that wash-down closets are the best from a sanitary point of view, and for flushing purposes.

The paper was accompanied by twenty-two sheets of tabulated experiments, the chief results of which are tabulated below.

Throughout the series the general arrangement of the pipes and traps, and the position of the closets, was similar to that shown in the diagrams facing page 557. In each experiment six ounces of artificial fæces (solid mixture of soft soap and sawdust) and four pieces of paper were put into the closet pan, and the amount of soil and paper flushed into the manhole was taken out and weighed with the water it had absorbed. There are no data to show the relative weights of the material when dry and when wet, and, therefore, the proportion of the materials flushed out in each experiment, or series of experiments, cannot be ascertained. But as all the experiments were carried out in the same way, the results are comparable as regards the different pipes used.

Size of Drain and Quantity of Flush.	Position of Closet on Plan.	Numbers of Tests.	Weight of Material put in.		Weight of Material flushed out.	Remarks.
6-inch Fireclay Pipe, 2-gallon flush.	A	20	oz. 120	Paper. 80	oz. 5	In five cases the drain is noted as being blocked; in seven others that the water came through very slowly; and in one that the trap was filled with soil.
	B	20	120	80	...	
	C	20	120	80	102 $\frac{3}{4}$	
		60	360	240	107 $\frac{3}{4}$	
6-inch Fireclay Pipe, 2 $\frac{1}{2}$ -gallon flush.	A	20	120	80	74 $\frac{1}{4}$	In one case it is noted that the trap was filled with paper and soil.
	B	20	120	80	69 $\frac{1}{2}$	
	C	20	120	80	279	
		60	360	240	422 $\frac{3}{4}$	

Size of Drain and Quantity of Flush.	Position of Closet on Plan.	Numbers of Tests.	Weight of Material put in.		Weight of Material flushed out.	Remarks.
4-inch Fireclay Pipe, 2-gallon flush.	A	10	oz. 60	Paper. 40	oz. Nil	Against fourteen of these experiments it is noted that the drain was blocked; and in two other cases that the water was trickling or running very slowly.
	B	10	60	40	Nil	
	C	10	60	40	37½	
		30	180	120	37½	
4-inch Iron Pipe, 2-gallon flush.	A	20	120	80	101	Against one experiment it is noted that the drain was stopped; and in another that the soil was sticking.
	B	20	120	80	121	
	C	20	120	80	222½	
		60	360	240	444½	
4-inch Iron Pipe, 2½-gallon flush.	A	3	18	12	25½	
	B	3	18	12	22	
	C	3	18	12	24	
		9	54	36	71½	
3-inch Iron Pipe, 2-gallon flush.	A	20	120	80	149	In three consecutive experiments the drain was blocked, and the hose was turned on to clear the stoppage, which was found to be caused by a small piece of stick; and in one other case the water was running slowly.
	B	20	120	80	120	
	C	20	120	80	147	
		60	360	240	416	
3-inch Iron Pipe, 2½-gallon flush.	A	3	18	12	23½	
	B	3	18	12	20½	
	C	3	18	12	23	
		9	54	36	67	
Plummer's Pipe. (See Drawing, p. 5.) 2-gallon flush.	A	20	120	80	67¾	In all the experiments the materials put into the closet were flushed into the trap in the drain.
	B	20	120	80	114	
	C	20	120	80	185	
		60	360	240	366¾	

This Discussion applies to the papers by Mr. J. T. BRODIE and Mr. A. B. PLUMMER.

THE CHAIRMAN (Mr. D. Balfour) said, in reference to church ventilation, that they ought to have more facilities for sanitation as well as for sanctification. From Mr. Plummer's paper they found that no doubt water companies were obliged to consider the question

of economy very considerably, but efficiency must at the same time be maintained. He called upon the meeting to give a vote of thanks to Mr. Brodie and Mr. Plummer for their papers.

Mr. ROGERS FIELD (London) said: Mr. Plummer's paper had greatly interested him, and he thought that the Northern Architectural Association did good service in having such a matter as that referred to, gone into, and that they might do further good service in the same direction. The question of the two gallons flush was one to which he had been forced to pay great attention. He quite agreed that there should be no waste of water, and that no more water should be used for flushing than was necessary for sanitary purposes, but he thought that the question must be looked at from the point of view of the public welfare. One of the chief objects of giving a water supply was that we might have good sanitation, and a sufficient supply should therefore be allowed for closets to carry away foul matter under the ordinary conditions which occur in practice. If it could be shown that a two-gallon flush would not do that, then he thought, in the interests of the public, that the quantity should be increased. His attention was first called to the question something like twenty years ago, when his practice in dealing with the reconstruction of the drainage and sanitary arrangements of buildings largely increased. He then used the two-gallon flush, as this was considered sufficient by the best authorities of that day. He took great care to get the best apparatus, and have it fixed in the best way; but, notwithstanding this, he gradually found that the closets did not clear themselves in actual practice as well as was expected. This led him to investigate the question very carefully, and he found that two gallons was running it much too fine—as, although this quantity acted fairly when everything was perfectly arranged and constantly attended to—a number of circumstances arose in practice which prevented this perfect condition, and then the two-gallon flush was not sufficient. He therefore increased the flush to two-and-a-half gallons whenever he could, and entered two-and-a-half gallons in his specifications. As his experience extended, and the greatly increased use of inspection chambers offered better opportunities of observing the flush, he became convinced that even two-and-a-half gallons was not sufficient, and for many years past he had adopted a three-gallon flush. With a three-gallon flush he had had no difficulty or trouble. The Sanitary Institute some years ago went very carefully into the question, and tried a number of experiments, and the conclusion came to was that a two-gallon flush was not sufficient. He had also had other opportunities of investigating the matter experimentally, but the conclusion he had come to with reference to experiments was that they did not show what took place in the ordinary conditions of practice. He did not say that one could not get experiments to show this, but he did say that no experiments yet tried, so far as he was aware, showed what took place in ordinary conditions. He would very strongly advise the Northern Architectural Association

to gain information from their members of what they find takes place in practice. This is what engineers and architects wanted to know—not mere opinions, but facts. If the Association did what he suggested they would collect a body of valuable facts. There are many reasons why a two-gallon flush is not sufficient, and they were technical ones, which an architect would understand. If there were a nominal two-gallon cistern, it did not follow that the water flushed out of the cistern was two gallons; in fact, in practice it was generally less. The reason of this was that the ball cock was always regulated to keep the water in the cistern below the overflow, and often much below the overflow. In the same way a three-gallon cistern does not mean that three gallons of water are used in practice. It means that only about two-and-a-half gallons are used. Again, the two-gallon limit prevents the use of many excellent forms of valveless closets, which would not work with two gallons, even under the most favourable conditions. There was another point in the paper which was an important one. Mr. Plummer said, "It must be remembered that in allowing a two-gallon flush, the Newcastle Company are only doing what almost all other companies (who give the matter much consideration) in the kingdom do, with I understand the exception of Southend, where a two-and-a-half-gallon flush is conceded." Even in the case of Water Companies, Southend was by no means the only Company which allowed more than two gallons. If, however, instead of collecting statistics with reference to Water Companies, we were to collect statistics relating to Corporations and Local Sanitary Authorities who were themselves in charge of the water supply, we should find just the opposite—viz., that a very large number, perhaps more than half, adopt a two-and-a-half or three-gallon flush. Why was this? It is not supposed that the Sanitary Authorities wish to waste water. The reason must be that they find that it is to the interests of the public to allow such a flush.

Mr. OSBORNE SMITH (London) said: Having had rather exceptional experience in regard to plans where this question of the sizes of cisterns and flushing comes in, he had listened to Mr. Plummer's paper with a considerable amount of interest, and it had corroborated an impression which had been upon his mind for years past. He had often felt satisfied, although he had never been able to try the experiment, that a pipe even smaller than three inches would be ample for branch drains. To consider the difference between a 6 in. drain and 3 in. drain with all this matter put in them. The 3 in. drain would flush every time, whereas the 6 in. drain very often became stopped. He distinctly remembered some time ago seeing an old 4 or 4½ inch soil pipe taken down. It had probably been in the position whence it was removed, 100 years. He had no doubt that for the last fifty years the soil had been passing through 2½ in. It was highly polished and the sides were as hard as ebony. This and other things had shown him that we were going in the right direction in insisting on small pipes, and these experiments coming after the decision in London about the two gallon flush, made it quite

clear that a two gallon flush was not such a bad thing as it was made out to be. He had to examine periodically many High Schools where girls attend in large numbers, and girls, as is known, use closets very much more frequently than boys. Take a range of a dozen closets in a school; girls come out for recreation, and all the closets are used at once. As soon as one girl leaves a closet another goes in; and it was very inconvenient if the flushing cistern was not ready to discharge at once when required. He made his cisterns fill in half-a-minute when they were in use. At some schools he had found by experience that a two gallon cistern answered its purpose well if the water pipes were made large enough. An ordinary two-gallon cistern answers every purpose, and can be made to fill in half-a-minute. And that was the important point. In ordinary cases it does not much matter if it takes two or three minutes, but in schools and places of that kind where closets are used rapidly, it was very necessary that they should fill rapidly. The experiments that had been carried out did not point much to the doing away with 4 in. drains, because there must always be something approaching that to carry off surface storm water. But for drains that convey soil only, he was convinced that a 3 in. pipe was ample.

Mr. W. E. BLAND (Newcastle-upon-Tyne) said, in reference to a remark of Mr. Plummer's which seemed to imply that water companies were now on the road down to a two-gallon flush, instead of up to a larger quantity, that he wished to record the fact stated to him by a Glasgow councillor recently, that the City Engineer, Water Works Engineer, Medical Officer, and Sanitary Inspector of that city had put their heads together and arrived at the conclusion that two gallons was not sufficient, and now allow three gallons instead of two. This showed a tendency rather upward than downward. Seeing that the chief object of water companies, in seeking to reduce the quantity to two gallons, was to save water, he would suggest that they try to save it in other directions, for instance, much cold water was run to waste uselessly through baths, lavatories, and sinks before the hot water arrived at the tap, where the hot-water supply was not properly arranged. They might endeavour to save this waste, instead of taking from the supply to water closets where it was really needed.

Mr. F. HOOPER (London) said that he was representing the Architectural Association of the South of England, and was glad to know that their allies in the North had undertaken so valuable a series of experiments as those that had just been explained. We feel great diffidence in even referring to a matter which had been treated so largely by Mr. Rogers Field. But might they not think that the experiments which had been conducted in the North by Mr. Plummer and his confrères were even of a higher standard than Mr. Field would give them credit for? The difficulty of dealing with sewage was so enormous, and the diluted character of the sewage at its outfall so remarkable that anything which would reduce the volume of it was of the greatest importance, and he thought it would be a pity if, in the year 1896, they were to set forth a belief that a three-

gallon flush was the minimum, especially as their successors might find that a far less volume was ample! If Mr. Plummer could manage by any improvements in the forms of pipes, and by adjusting the proportions of the sections more accurately to their requirements to make a small supply sufficient, he would deserve far more thanks than those who urge a greater expenditure of water.

Mr. J. MUNCE (Belfast) said he thought the whole tenor of Mr. Field's remarks showed how useless the experiments were which he made some years ago. Mr. Field first thought that a two-gallon flush was quite enough, but when he went to inspect some closets fitted up under his direction with two-gallon cisterns he found the drains stopped, and he decided a two-and-a-half gallon flush was necessary; to-day he advocated three gallons, probably next year he would advise four gallons. This first showed that much of the discussion here was merely the opinion formed at the moment without careful study. He stated this after eleven years' experience of Sanitary Congresses. A pipe prepared with much care had been laid before them by Mr. Plummer, who must have put himself to great trouble; but with the exception of the last speaker no one had attended to it. A good deal of courage was required to bring a new pipe before such a meeting. For years he had had charge of large numbers of drains from public buildings and dwellings, and the experiments detailed by Mr. Plummer were just his experience; drains stopped a few yards from closets simply because the flush was insufficient to carry the contents of the water-closet through the disconnecting trap. Some new form of pipe must be devised, or this stoppage would go on. He did not know whether the experience of other members was like his own as to disconnecting traps, which were to a large extent sources of danger, especially if put to every house without sufficient water to flush each time a closet was used. In Belfast owners of property complained of constant stoppages from insufficient flushing, and three gallons were used. The pipe shown by Mr. Plummer would not necessarily involve the alteration of all the drainage systems because the sockets could be fitted to ordinary drain pipes, and the new pipe could be used from time to time as renewals were made.

Mr. A. DUNN (Newcastle-upon-Tyne) said: They had listened to an invaluable paper—a paper dealing with the results of absolute experiments fairly carried out by Mr. Plummer. He had listened to the paper with the greatest possible satisfaction, and thought that Mr. Plummer had established one or two things worthy of notice. He seemed to have established that a smaller size drain was the most useful for household drains and that a two-gallon flush was too little. These two facts ought, the speaker thought, to go forth from this Institute as well-established by the experiments of Mr. Plummer. He thought Mr. Plummer had shown a new form of drainage pipe which met a great difficulty. It answered its purpose not only with a smaller flush but with the large supply which comes from the rainfall. There was another thing, which was not mentioned, but

which he thought was absolutely necessary for making household drainage absolutely perfect, and it was that the cistern in a house should have attached to it a small flushing tank. This might be a little expensive, but these experiments all showed that a flushing tank, in addition to the other conditions, would make the system of household drainage almost perfect.

Mr. C. H. COOPER (Wimbledon) objected to the section of pipe proposed by Mr. Plummer, as each time a drain made with these pipes was flushed, deposit would be left to accumulate on the shoulders on either side. In the case of egg-shaped pipes no such objection could be raised, but these pipes would not keep their shape during burning. Even circular pipes were difficult to keep in shape during burning, and he (Mr. Cooper) did not believe it practicable to burn pipes of the sections shown by Mr. Plummer, and he should much prefer to see actual burnt pipes to models.

Mr. T. J. ALLEN (Newcastle-upon-Tyne) said that manufacturers preferred the circular pipe; it was more easily handled. But there was no more difficulty in burning the other. They could be placed in the kilns and they would carry just as easily. They were all of equal thickness, and manufacturers were prepared to make them. He could not say that these pipes would be more easily made than circular pipes, but they could burn them as truly as circular pipes. The egg-shaped pipe was difficult to work with. They had made them, but did not care about making them.

Mr. J. T. BRODIE returned thanks for the way his paper had been received.

Mr. A. B. PLUMMER (Newcastle-upon-Tyne) said: The fittings and lengths of drain, referred to in his paper, were still to be seen in the Water Company's Yard, and they would be glad to have them further tested. With regard to Water Companies' allowance of two gallons, he wished to say that he was speaking of Water Companies, and not (as has been suggested) of Local Authorities who had themselves charge of the water supply. He found that where water was superabundant there were a few more companies supplying more than two gallons than he had been aware of, but they could not be forced to supply more than the two gallons. They were faced with this difficulty, in most cases they could not get more than two gallons, which would only satisfactorily flush small drains, and Local Authorities, for various reasons, frequently insisted upon larger drains. But he did not say pull up all the present drains. What he said was this, why should they not in new work, try to get over the difficulty they were faced with, by means of a drain pipe such as he proposed. It was a question of necessity.