MR. F. J. DOMMERQUE:—I would like to instance a few points which I have noted in Germany. I have had occasion to meet several engineers who had charge of large accumulator stations in Germany about three years ago, and asked them their saving in their special stations, and found it not less than 30 per cent. I think that further savings could be effected, as the accumulators could be placed in cellars, or in the third or fourth stories of buildings, and so the outlay for buildings would be decreased. In one city I found that the accumulators were placed two or three miles from the station itself. My experience has been that the first outlay was considerably higher than the entire steam plant, and it was feared the first time it would not pay at all, and that the city would have considerably money to pay in addition to the income. It was figured out, and it was shown, that where accumulators are used to any extent, that it was cheaper to use them than it was to use the battery engines.

MR. CARL K. MACFADDEN:—I have a set of accumulators about 180 in number, located at a large gas engine central station in this city, and although I cannot say the battery is taking a great deal of our evening load, I have every reason to believe that if we had the right size of storage battery auxiliary, we would get some excellent results. We have installed an electric light station of over 400 horse-power in gas engines here in the city, and have found in a number of cases that although the battery plant has a capacity of not over 600 ampere-hours, it has helped us in a wonderful way when we have had trouble with an engine, and we have found it especially valuable in very light loads, when it would not pay us to run the smallest engine, which is of 80 horse-power. I can see a very good chance of supplying storage batteries in certain stations, such as I have spoken of, and I notice that it is being taken up to an ever-increasing extent in European stations. With the improved methods of manufacturing storage battery plates, and with the guarantees which some of the larger manufacturers are now able to give, I see no reason why they should not be used to as correspondingly great an extent in America as in Europe. In small gas engine stations, there has been considerable attention paid to storage battery auxiliaries. In large gas engine stations, storage batteries will be used in conjunction with improved types of gas engines, so as to keep the engine up to its best load, for the gas engine ought to be loaded up to its rated load to get its best results, the same as the ordinary steam engine.

MR. LUDWIG GUTMANN:—The reason that the storage battery business is so well developed in Europe and almost neglected in America can, no doubt, be traced to the fact that in Europe until within the last year or two, with few exceptions, all installations were of the low tension continuous current type. In many places, especially in theaters, it was compulsory to provide means, such as storage batteries, to prevent a sudden giving out of light,

due to defects in machines. On the other hand we find in America the majority of installations of the high tension alternating current order. I remember having seen stations some eight or nine years ago in England, for instance, that of the Alhambra Theater in London, in which the engine and dynamo capacity were selected smaller than necessary for the total output. The balance was installed in storage batteries, which were charged during the day and helped the two Edison dynamos at night to supply the light, while they were also used in the day time to supply the few lamps that were needed all over the house.

Here in America there was not such a great need for storage batteries, or, if it existed, it was not satisfied because capital was afraid of master patents such as Brush, Faure and Planté, and, no doubt, a pressure was exercised by the companies controlling these patents on others who wanted to venture into the storage battery business.

However, now the fundamental patents having expired, we will experience a greater activity in the development and manufacture of storage cells. The need for such cells has been growing steadily, and I believe that no great stimulation is required for their introduction.

In Europe circumstances aided the development of this branch, and among these were the prohibition of overhead wires in many cities, and the use of too great engines, which would have needed considerable valuable space, heavy foundations, also large space for receiving and storing coal. The battery was a means of permitting the use of a smaller engine and dynamo and storage of the energy, preparatory to the heavy demand.

It seems to be an American trait to neglect one undeveloped branch of the business at the expense of another which is advanced to the greatest extent. I wish to remind you of the sudden start of many engineering firms into the high tension alternating current work in 1887 and 1888; then the vigorous attack on the railway motor and its development, and now since that has also passed into a field of stability, there is a unanimous attack prepared to solve the storage battery problem. The fruit is worth looking for, as the usefulness of the storage battery is far greater than may be thought for at first sight by many. It will not be restricted to low tension continuous current work, but it will be used in central station distribution by means of high tension single and pluri-phased alternating currents which are changed by rotary transformer into continuous currents to charge the batteries with the surplus energy the dynamos develop at the time of light loads.

MR. SHEEHY :—With reference to my experience with storage batteries in connection with signal work, I will say that it is of very recent date, and, in fact, I might say that the various classes of batteries have been used. I had to do with the first one used

in this country, as well as those brought from Europe. I do not think there is anything I can say to add to the discussion this evening. So far as my faith in storage batteries is concerned, I believe very emphatically in its use, and would even go further in my endorsement than any one here to-night has gone.

MR. M. H. GERRY, JR.:—I am much interested in the application of storage batteries, and have listened with great pleasure to the remarks I have heard this evening. I am profoundly impressed with the desirability of using storage batteries in connection with fluctuating loads for both lighting and power purposes, provided that batteries can be found which will satisfy commercial conditions. Much has been written in the past in regard to the great losses and rapid deterioration of storage batteries, but I cannot help thinking that the results may have been partially due to improper handling, or inefficient apparatus for regulating the charging or discharging currents. If a storage battery can be obtained, costing not more than the same kilowatt capacity of a first-class prime mover, having a commercial efficiency of 75 per cent., and a cost of maintenance not greater than six per cent. of the investment, then such a battery can be used in a great many power stations with advantage in point of economy. It is only a question now, whether such a battery can be obtained, and a great many practical engineers are looking with considerable interest in the direction of storage battery manufacturers.

I have listened with pleasure to the gentlemen here to-night who have had large experience in this attractive field, but regret that they have not said more in regard to deterioration, and to the maximum discharge which batteries can safely stand. I would like to add a word in reference to the rating. The present method of stating the capacity in kilowatt-hours or ampere-hours is not altogether satisfactory. More important than the total capacity in the application to fluctuating loads is the maximum rate at which a battery can be repeatedly discharged without seriously damaging it. A kilowatt rating representing this maximum discharge would be of more value in cases of this kind than the kilowatt-hour or ampere-hour rating above referred to.

MR. B. J. ARNOLD:—The first thing which I wish to call attention to is the discussion of Mr. Perry, in which he advocates the use of gas engines for taking the peak of the load, or the fluctuating load of electric plants, instead of batteries. He states that under no circumstances would he recommend the use of batteries, for the simple reason that the gas engine will be found more economical. I think this is rather a broad statement, and one which the advocates of this system will have some difficulty in substantiating, for the reason that gas engines working on variable loads are extremely uneconomical, and not only are they uneconomical, but they are very sensitive to changes of load. If the load on a gas engine changes suddenly, it is liable to re-

quire immediate attention on the part of the operator to keep it in operation, as indicated by my experience with some engines. It is probable that certain makes of engines are more reliable in this particular than others, but under any circumstances it is almost imperative to have an attendant near a gas engine while it is in operation, if working on variable loads. For this reason and the fact that the gas engine is uneconomical at light loads, the plan of placing gas engines in different localities over which a system of electrical distributing mains were being operated, in order to help out the heavy loads at distant points would be impracticable, as each engine would necessitate an attendant to start the engine at the time that the line required extra power. On a railroad circuit, this demand is constantly changing from the negative to the positive factor, and if a gas engine is used, it would be running a portion of the time with practically no load, and the next instant with excessive overload. A battery installed in the same locality would receive the excessive current delivered to it when the demand on the line was light, and discharge it into the line when the demand was heavy, automatically, thus storing the energy and giving it back when needed, without the services of an attendant. The figures given by Mr. Perry, showing the consumption of gas at various loads, show that the engine consumes over three times as much gas per H. P. when running at one H. P. as it does at 12 H. P., its rated capacity, and in railroad work the engine would be thus running a large portion of its time, and I believe that the results would be far from satisfactory to the company operating such a system, especially if there were any number of engines in operation. A gas engine could be installed as an auxiliary to a central station to carry the peak of the load if it was comparatively steady, as is the case in lighting plants, but my judgment is that it will be much better economy and engineering to put in another steam engine, which could be driven from the same battery of boilers, steam piping, etc., already in the station, than to install a gas engine and necessitate the attendance of engineers especially skilled in handling both steam and gas engines. There is no question in my judgment but that a gas engine plant, installed properly and run on producer gas, will deliver a K. W. hour on the switchboard for less money than a steam engine plant can do it, but in order to do so, the engines must be run at practically a constant load. Such a plant, working in conjunction with a battery auxiliary, I believe to be the most feasible solution of the power station question, and one which we will probably come to in this country in the near future.

Probably of more interest than any general discussion of this question will be some specific cases showing the application of batteries. I have brought with me to-night some load diagrams of stations in which batteries will be installed. The first, shown in Fig. 2, represents the diagram of a railroad plant operating

near Chicago. You will notice the similarity of the peaks, and that they occur at equal intervals of time. This is caused by the road having upon it a four per cent. grade, about one-quarter of a mile long, up which a car is propelled every 20 minutes, there being four cars in operation on the line, and so spaced that the cars reach this grade 20 minutes apart. The result is, that it was necessary to install a very much larger engine and generator in this station, in order to take the maximum load of the line when the car reaches this grade, necessitating the operation of a 250 H. P. engine the entire 18 hours that the road is in operation, merely to be able to haul one car up this grade, and to operate the other three at the same time. This was the first case that occurred in my experience wherein I thought it advisable to recommend the adoption of a battery auxiliary. After making an accurate test of the plant, I found that the total average energy required from the power station to operate the road was about 50 electrical H. P.; consequently, if an engine and generator of 65 H. P. were installed and working in conjunction with a battery auxiliary, the road could be operated with this size plant, and the large engine shut down. I am unable to give you the results of this installation, as it is not yet running, but hope to at some future time. You will readily see that an investment for a 65 H. P. engine and generator and a battery auxiliary, to do this work, is much less than is at present carried to do the same work.

The most important application of batteries to lighting work, which I have had to do with, is the plant now being installed in the Chicago Board of Trade. In this plant the operating expenses average now about \$25,000 per year, using simple engines at 75 lbs. of steam, hydraulic elevators with compound pumps working steam full stroke, and old style belted electric plant with shafting. By increasing the steam pressure to 125 lbs., installing new boilers, new compound engines, and with direct connected generators, electric elevators and a battery auxiliary, we expect to reduce the operating expenses to \$15,000 a year. The present system of operation necessitates the use of three shifts of men, working eight hours each, making the labor pay-roll rather high. With the new system, using the battery auxiliary, there will be but two shifts of men, working eight hours each; a third man working but eight hours, thus reducing the cost of labor in the plant very materially, as the battery takes care of the entire load for a period of eight hours. At present it is necessary to signal to the engineer to start up the engines and dynamos when the janitors require light at night, while sweeping the rooms, and to use the hydraulic elevator. With the new system, the battery will handle the elevator and lights in the building automatically at night.

Referring to Fig. 3, which represents the load diagram of the plant of the Chicago Board of Trade as it now is, and as it will

be when the revised plant is in operation; the lower lines of the diagram, representing the various lighting loads, and the large line *A, a, b, c, d, e, f, g, h, i, j, k, l, m, n, o, p, q*, representing the load of the plant for 24 hours under the new conditions. The parallelogram *A, B, C, D* represents the total electrical energy of the 75 k. w. generator, operating from 7 o'clock A. M. until 11 o'clock P. M., over a period of 16 hours, involving two shifts of labor at eight hours each. That portion of the parallelogram, having shade lines inclining to the right at an angle of 45 degrees, represents the energy which will be delivered from the generator to the batteries. That portion of the diagram having shade lines inclining to the right, at an angle of 120 degrees with the base line, represents the energy which will be delivered to the line direct from the generator without the aid of the batteries, while that portion represented by the shade lines inclining to the left, at an angle of 45 degrees, represents the energy given to the line from the battery alone. It will be noticed that between the hours of 9 A. M. and 2 P. M. the batteries act in conjunction with the generator, as the demand is in excess of the capacity of the generator, while from 11 o'clock P. M. until 7 A. M. the entire load of the plant is carried by the batteries without the aid of the generators, thus leaving all of the plant, except the batteries, idle for this period of the twenty-four hours, and necessitating but one attendant during this time, who fires the boilers in the winter for steam heating, and also acts as watchman. With this arrangement, the 75 kilowatt unit operates for a period of sixteen hours at its maximum economical load, and is then shut down and stands idle until the next operating period. From this plant will be operated 1,000 16 c. P. incandescent lamps, four 10 H. P. electric motors, four 30 H. P. electric elevators, and it is expected that one 75 k. w. generator will handle this load economically when the plant is completed, it being understood that the maximum capacity of these machines is seldom required at any one time. With this arrangement, lights or power can be turned on any part of the building at any time during the entire 24 hours of the day without necessitating any attention from the engineer in charge, thus gaining not only economy, but a great feeling of relief on the part of the operators, which they do not now have, or for that matter do not have in any plant operating on a variable load without the use of some kind of a reservoir, in the shape of a large engine, running underloaded, or a battery auxiliary.

Mr. Abbott has given us a very carefully prepared discussion upon the cost of the operation of the London lighting plants, when operating as they do now, and has shown what might be expected, if they were operated with battery auxiliary.

The records of European stations, so far as I am able to secure, show that the plants operating with battery auxiliary are delivering a k. w. hour to the consumer at a somewhat lower rate than

those operating without batteries, when the conditions are similar.

The chief difficulties which have prevented the introduction of batteries on a large scale in this country in the past have been as follows:

1. The danger of suits for infringement which were liable to follow in case a purchaser attempted to use batteries.

2. The desire on the part of the manufacturer to furnish a battery for as low a cost as possible, and in many cases installing them of too small size to do the work required, the result being rapid deterioration and subsequent disastrous results to the battery business.

3. The lack of knowledge on the part of the operators or attendants in charge of the batteries.

A battery plant properly built, with sufficient lead to do the work required of it, and properly handled, will prove an economical investment where the conditions are favorable; but it should be borne in mind that a battery, like every other power-saving device, cannot effect a saving, unless the load is such as to warrant its use, which is especially the case on variable electric loads.

Those having charge of plants using batteries should bear in mind that batteries absorb and give out energy by virtue of a chemical action, and that anything which in any way prevents the proper harmonizing of the chemical elements entering into the batteries, begins to cause deterioration immediately. Consequently early attention must be given to defects, or serious results will follow. In other words, a battery plant is like any piece of mechanism or other device which requires some knowledge on the part of the operator to keep it in good condition, and as before stated, a large part of the battery failures in this country have been caused by the attendants not thoroughly understanding the device they were attempting to handle, and thus allowing destructive chemical action to continue until the batteries were practically destroyed, when attention at the right time would have prevented it.

The system which I have adopted for all plants installed under my direction is as follows:—*First*, I insist upon a recording ammeter being placed upon each plant, and daily charts from each plant mailed to my office. In this manner I am able to tell immediately whether or not the cells of any particular plant are being overcharged, overdischarged, or gradually discharged more than they are charged, until the surplus of the cells is exhausted, which is one of the chief sources of disaster in batteries. *Second*, each week the plant is examined by an expert, and the specific gravity of the electrolyte of each cell and the voltage of each cell examined and placed upon a report and handed in. From this we are able to tell whether or not the cell is short-circuited, or the electrolyte too heavy or too light for economical working, and

if defects are noted, the operator of the plant is notified immediately to remedy the defect, and if he is not capable of doing this, an expert is sent to do it. By this system of inspection it is hoped that a sufficient number of plant operators will become skilled enough to properly handle a battery installation, and after that time, I think, we will have fewer storage battery failures.

MR. MACFADDEN:—I would like to ask Mr. Arnold whether or not those tests on steam engines and on gas engines, were made on brake tests or indicated horse-power. I have found that in some gas engine plants with which I have had to do, that the gas used per indicated horse-power varied but little with different loads. It will be found that the gas used per indicated horse-power will run very nearly the same whether the engine is running under load or over load; also, that on some tests of a 200 H. P. engine, when on half load and under, we can get practically the same results for indicated horse-power, where consumption of gas is concerned, as we can for full loads. Also that the highest efficiency for this particular engine is not at the point of maximum possible load. I mean that the highest efficiency of that engine is not reached when the engine is doing its maximum work. I can take an engine that is designed to run 55 brake horse-power, load it up to 70 brake horse-power, and the engine will carry it. The highest efficiency is not obtained with the highest possible initial pressure that can be obtained. I think that this is somewhat different from the usually accepted views with regard to the gas engine, and I have the data which I will distribute to those who wish to investigate the matter. It would be especially interesting in this case, provided the tests were taken as indicated horse-power instead of brake horse-power. The amount of gas and fuel for indicated horse-power, I think, will be found to be somewhat different from brake horse-power. Mr. Perry gives the data of a test on horse-power development. I should imagine that this means in the cylinder, in the absence of anything stated to the contrary, the gas consumption being too low for brake horse-power.

MR. ARNOLD:—I would say that I have examined the engines you have referred to, and find them to be double cylinder engines which explode once at each cylinder, or twice at each complete revolution of the shaft, and it is undoubtedly true that such an engine can stand a heavy overload better than many types of gas engines.

PROF. CARHART:—I regret that I cannot give you any information on the commercial side, but I have been very much interested listening to the discussion here this evening. I have had a little experience, however, with storage batteries. Three years ago I had the pleasure of visiting, in company with several other gentlemen, the central stations of London, through the kindness of Professor Silvanus Thompson. We visited all, or nearly all, of them, and, as you know, the storage battery is an important

factor in all these stations. One thing that impressed me very much, in comparison with what I had been accustomed to see in connection with storage batteries in America, was the fact that they construct their storage batteries there for durability. The cells were of enormous size and capacity. They were extremely heavy, and intended for actual use. They were not made, apparently by the manufacturers, to make money out of, by selling cheap metal at a high price, but they were made for service and durability. In connection with that, it occurred to me that there must be quite an addition to the cost of the plant besides that of the battery installation, namely, provision for its storage. The building costs as much where the storage battery is used, as it does where it is not used, because of the very large area required for the placing of the batteries. There are a good many appliances, too, as you know, in connection with a storage battery plant in addition to the cells themselves. The arrangements for throwing cells in and out, according to the requirements of the plant, are very elaborate and costly. They are put up in an attractive and substantial manner. They are not placed in cellars, nor yet in attics, but in very substantial buildings. They are running their engines there at the point of highest efficiency, because the number of engines changes with the load. As the load comes on, additional engines are started up. And yet they find it economical to use the storage battery in connection with their plants.

Another item ought to go into Mr. Abbott's estimate, and that is, the cost of the acid required to set up the cells. The cost of acid amounts to considerable, for the acid ought to be of the purest quality. I have had a little experience with two types of battery. I think the Pollak battery is a thoroughly good one, but it certainly depreciates quite rapidly. In the one that I have, some of the cells have had to be taken out and repaired. The people in charge of these stations in London, which use storage batteries, watch them very carefully, and when anything is the matter with them, they put them in the hospital. Storage cells remind me of an invalid, requiring great care and watchfulness. They must be taken care of and watched, when they are not giving their highest efficiency. They require considerable labor, and this item ought to be added to the account. It requires the labor of one or two experts continually, to look after these cells. I think the last battery that I have tried, gave out toward the close of last year from the fact that it stood a long time without being used. I inquired of Mr. Pollak regarding this, and he assured me that it could be left standing. Mine, consisting of 36 cells, did stand without losing more than two volts in three months. The voltage scarcely dropped at all. I measured carefully to assure myself that it kept its voltage during that period. But there was sulphating under the active material, and when we came to use it, it would swell in spots. Mr.

Pollak insisted upon it that some foreign material must have gotten into the cells which caused them to give out. But I think it came from the fact that the cells were not kept in constant use. I found that it don't do to let them stand. It is like the human body in this respect, the cell needs exercise to keep it in good condition.

I have come across one or two points of scientific interest. It is certain that the internal resistance of a storage battery changes considerably with the length of time that it is discharged. As it is discharged, we have a sulphate formed, which has a higher resistance than the active material. This internal resistance will change in the course of charging for half-an-hour. Then there is another point. You all know that the internal resistance of any primary battery decreases as the current increases. We have been able to get very nice smooth curves. With a storage cell the change is small and is quite difficult to measure, but measurement shows that the internal resistance is lower when the current which we are taking from the battery is larger.

MR. ARNOLD:—When you start charging a battery, you can force current into it for a while with a lower voltage than you can when the battery becomes partially charged. Is not part of this attributable to the lower internal resistance of the battery when not fully charged? As the cells become charged, it is necessary to increase the voltage of the charging current in order to keep the charging current constant. This must be due to the increased internal resistance of the battery. It is well known that the resistance of a mixture of sulphuric acid and water is least, having a specific gravity of about 1.123 at ordinary temperatures, and, as the specific gravity varies either way from this, the resistance increases.

PROF. CARHART:—The internal resistance falls as you charge, because the sulphate is reduced, and for that reason it ought to take less voltage to force the current through. The battery does not have as high efficiency when it is discharged with a large current as when it is discharged with a smaller current, but the smaller internal resistance is a slight offset.

MR. DOMMERQUE:—I remember that the company which manufactured the accumulators for Hanover, Germany, has made a contract with the city to keep them in perfect running order at four per cent. of the first cost for ten years, and that this company makes money at that, which I conclude from the fact that when I was there in 1887, they ran their factory by a small locomobile, while to-day they have immense factories at Hagen, Berlin and Vienna. In most stations the accumulators have a space about one-half to one metre square for each cell. On the Continent I found that they do not give accumulators a very good place, but put them in basements, or somewhere where the ground does not cost so much. I think this is cheaper than to provide space for engines or dynamos instead, because the latter must have a good foundation.

PROF. W. M. STINE:—It seems singularly appropriate to enter a plea for the proper consideration of the storage battery itself in connection with its engineering applicability for lighting and power uses. It is 35 years since Gaston Planté (1860) made the first experiments from which the storage batteries of the present have been developed. The field has been a prolific one for investigation and invention. The storage battery is thus older than dynamo-electric machinery by about seven years. Sufficient time has certainly elapsed for the practical development of this class of apparatus. Yet after 35 years we are still telling each other how excellent a thing the storage battery would prove, were it only more generally used, and still in the dark for reliable data on which to base our conclusions.

There is good reason for the lack of data for the life and usefulness of storage batteries. Through all the years they have been with us, they have existed in tentative form, and their history is a failure of one form, leading to fresh experiments on others. That they have recently been the subject of large speculation by some of our leading financiers is by no means a convincing argument in their favor. This is neither the first nor the greatest financial combination of its kind, and should it not prove successful, it is only adding one more to a long list of disastrous failures.

The engineering view of our subject has been frequently and pretty exhaustively presented, but too often by those who have had no practical experience with batteries, and whose estimates of first cost, maintenance and depreciation are far below the actual figures.

A commercially practical storage battery would be one of the greatest boons to electrical engineers. This is undeniable. It does not require any especial foresight to realize the great advantages accruing from their use. The problem of when and how far to employ them, is not more difficult of solution than the most advantageous amounts and distribution of copper in distributing circuits. It requires that a sufficient number of load curves be taken to get a reliable average curve. It then remains to determine the size of generating plant to handle the average load, and the addition to this to handle the peaks in the load, allowing sufficient reserve to handle the maximum peak likely to occur. The equivalent in batteries of this reserve portion of the plant can then be calculated. The total operating expense in each case would present no especial difficulty, were data at hand, which would reliably state the depreciation, maintenance and labor involved by the use of storage batteries. Additional elements would be the enhanced efficiency of the generating plant when run with a nearly constant load of the service and battery combined, and the power factor of the batteries, or their efficiency from the generator to the consumer. With such data as outlined, the question of the commercial applicability of the

storage battery would be a very simple one. All that would be necessary would be to balance accounts between the two classes of reserve plants. On the one side would be the first cost of generators, engines, boilers and accessories, labor, maintenance, operating expenses and depreciation. On the other, the first cost of the reserve equivalent in batteries, their maintenance, depreciation, operating expenses, labor, and the large number of accessories. Here conscientious calculation would leave but little room for discussion, except on methods and details of installation. If the problem has been fairly stated, then why does the present hesitation to install batteries exist? There is no doubt that storage batteries would prove desirable adjuncts to many power and lighting stations, and would be generally introduced, could any reliance be placed upon such low depreciation as $7\frac{1}{2}$ per cent., as has been recently stated.

But American engineers are justly conservative on this latter point. In too many cases the depreciation has reached 100 per cent., or the batteries have been abandoned in a short time.

It is undeniable that a strong sentiment exists in this country against the storage battery. Most of the data obtainable is against it. Under such circumstances it would be wise to make haste slowly, and let the burden of the introduction of batteries rest on the company manufacturing them.

The argument that the engineering world wants, is not engineering calculations showing a paper economy, but it wants to be granted the demonstration of plates that have stood at least from 1,500 to 2,000 daily reversals on continuous service. A battery of which at least 90 per cent. of its plates could make such a showing would be not a mere curiosity, but a most convincing argument.

The general trend of practice is to employ a greater weight of lead per ampere-hour capacity. Those who have had much experience with storage batteries know that plates fail from at least three causes: (a) the loss of active and irreversible material falling to the bottom of the cell; (b) rupture of plates due to mechanical strains; (c) disintegration, or crumbling of the supporting structure of plates.

Heavier plates, then, will remedy the second and third faults to a limited extent, but be without influence on the first. The heavier plates suffer the same actual loss in pound weight of active material as lighter ones, but can support the loss for a greater length of time. But the proportionate life of a heavy plate, owing to physical disintegration, may in reality be less than the lighter one. The interest on the first cost of the extra lead which is used to ward off the day of final destruction, is a direct loss, unless the proportionate life of the heavy plate greatly exceeds that of the lighter one. The use of more lead in plates, by no means diminishes the wear on batteries.

It has been so often proven that the use of reliable storage

batteries is excellent engineering practice, that the arguments have become mere platitudes. But where shall we obtain the reliable battery? Certainly it is yet to be proven that it is made in America. Can we point to any make of battery that has stood up under at last five years of ordinary commercial service? The records of the Patent Office show that the storage battery has received its full share of attention from inventors, and yet we hear the common report from the different styles of plates that they have gone to pieces under short service. Litigation is claimed to be responsible for the non-use of storage batteries in this country. Yet we all know better than this. If a perfectly reliable battery had existed, it would have come to the surface in spite of all lawsuits. The very fact that manufacturers are constantly changing the form of plates, etc., is sufficient argument to show that plates will not stand up under service. Great stress is laid on the extensive use of the storage battery in England, Germany and Switzerland. But here the plants are too modern to prove their ultimate economy. One of the oldest and best known of English plates is rumored to be proving a failure, for the very reason that this plate has been in use long enough to demonstrate that it does not possess sufficient life.

European practice offers a counter argument. The fact that batteries are used there so extensively, shows that they must prove at least a partial success. Let American engineers, then, profit by European experience. Let us go to them for our information. But how shall this be obtained? The suggestion is offered that our technical papers procure from European central stations using storage batteries reliable statements which shall, without fear or favor, state fully all facts in regard to their installation. Such data should note the style of battery in use, its ampere-hour weight, the purity and specific gravity of the electrolyte, the methods pursued in operating and caring for batteries, first cost of batteries and accessories, their actual power factor, the outlay for repairs and renewals, the length of time the battery has been in actual service, and the life of plates so far as used.

Another question remains to be decided. Can batteries be profitably sold outright? In very many cases the manufacturer has maintained a fostering care over plates installed, and the life shown has in a measure been due to frequent patching up of plates.

Among points not sufficiently emphasized by many writers, is the great outlay for the numerous expensive accessories demanded by a first-class installation; the constant attention and treating which they demand, and the disagreeable nature of repairs due to handling sulphuric acid.

A notable article appears in the *Elektrotechnische Zeitschrift* for October 17, 1895. It fully states just such data as we desire, for an installation of 120 cells of Tudor battery made in Hagen, Westphalia. The cells were 52 ampere-hours capacity; normal

discharge rate of 10 amperes, and charging current of eight amperes. The battery was installed in 1890, and has been in constant use. With the exception of renewal of electrolyte in one cell, no repairs or renewals were necessary. The installation was for the Head Bureau of Telegraphs in Berlin, and used on its service wires. The discharging current never exceeded 0.25 amperes. The cells were charged each 10th—11th day. On analysis of the record, owing to the small discharge current, we can draw no conclusions as to what would have been the life of the plates under conditions of normal discharge, say 5 to 10 amperes. These batteries in all have been reversed not to exceed 200 times, this being equivalent to not more than one year's active service, such as would have been required of them in lighting and power plants. An increase in capacity is noted, a condition which is to be expected under such service.

It is to be hoped that this timely article will be followed by many others equally reliable.

MR. ARNOLD:—In referring to the maintenance, it seems to me that the best evidence that could be relied upon is the guarantees which are made by the companies that are backing these battery installations with their money. They are not going to guarantee something which they do not believe they can depend upon, and I do not see any reason for doubting their ability to do this, when they are willing to make contracts which make them liable if they are not able to fulfil their promises. I believe batteries can be maintained at a profit for seven and one-half per cent. of their first cost per annum when working within their limits.

Up to the present I have not been in favor of batteries being put upon street cars, but figures which have recently been shown me from the records of a road operating 25 cars in Paris, in which the maintenance of batteries is given at $\frac{6.3}{100}$ of a cent. per car mile, covering a period of over two years of operation, causes me to look upon this question more favorably, and if on investigation this record proves to be correct, many of us may have to change our minds regarding storage battery cars. One thing is certain, that the first cost of a road is less with storage battery equipment than it is with trolley equipment, for the reason that the power station investment is less, and there is no expense for the overhead or feeder system. A set of cells in this city which have been used over two years now, none of which has been returned to the factory for repairs, are reported to me to be in as good condition as they were the day they were started. These are operated on a fluctuating load, but evidently have not been overworked. I attribute a large portion of the durability of this particular plant to the excellent quality of lead used in the construction of the cells. This, together with the use of chemically pure acid, and the careful attention which has been given by the operator who is an expert on battery work, has shown an excellent result, confirming more than ever my belief that the thing

we need most in this country at present is a class of trained men, capable of handling batteries properly, rather than radical improvements in the batteries themselves.

MR. FELDMAN:—In the *Electrician* (August 30) are given the latest results of using storage batteries by the Birmingham, England, Central Tramway Company to work the cars. The figures presented by the chairman of the company showed that while the mileage had remained stationary, the receipts had decreased six per cent., and the expenses increased 27 per cent., the total cost per car mile having grown from 14½d. to nearly 18½d. The exact figures of the four different systems supplied by the company per car mile are as follows: Cable, 5.43d.; horse, 8.67d.; steam, 9.11d.; storage batteries, 18.43d.; while last year a profit of over £1,200 had been earned by the accumulator cars. This year the chairman reported a loss of £1,735.

MR. DOMMERQUE:—I had the good fortune to meet Mr. Tudor in 1887, and he himself told me that he had had accumulators in service for seven years, which he charged regularly. He says, that figuring on this basis, he could guarantee for 10 years, and that the repair bill would not amount to more than 10 per cent. of the first cost.

[Adjourned.]

DISCUSSION IN SAN FRANCISCO.

A meeting of the California members to discuss the topic of "Storage Battery Applications" was an after-dinner feature, at Frank's rotisserie in San Francisco, on the evening of November 30th, Vice-President W. F. C. Hasson, in the Chair. Mr. E. J. Molera opened the discussion giving a review of the early history of the storage battery, and an interesting account of his own experiments. He also exhibited the first Planté cell imported into the country.

Dr. F. A. C. Perrine, Local Secretary, then read extracts from the communications presented by Mr. Childs and others at the New York meeting, after which he gave the following contribution to the discussion:

"The importance of the auxiliary use of storage batteries in comparatively small plants operating electric lights and electric railroad systems has not been widely discussed, although the principles involved have been indicated in all papers by the advocates of the batteries. In order to make a comparison of an auxiliary storage battery for a small electric light plant and a similar electric railroad plant, I have obtained the enclosed load curves derived respectively from the San José, Cal., street railroad and electric light systems. The curve of the lighting plant (Fig. 4), while showing a great variation between the maximum and minimum load, indicates at the same time that there is no well defined peak in the lighting curve of such a system, and

FIG. 4.—Load Curves, San Jose (Cal.) Light and Power Co.

FIG. 5.

particularly on account of the relatively small importance of incandescent lighting in residences when compared with the incandescent and arc lights sold by contract, we see that the only value an auxiliary battery plant would have in any such station lies

FIG. 6.—First Street car curve. Five cars. Showing changes in current along one line as the five cars are operating in the time of one trip. The drop along this line varies with the current curve.

in its ability to carry the load between the period of extinguishing the city lights at night, and the time they are again turned on the following evening. In the particular plant under consideration, a test has shown that the amount of coke used per

indicated horse-power hour during the main period of illumination (from 6 P. M. to 12 P. M.) is 10.8 pounds, in spite of the incidental variations and the low peak; while if we turn to the electric railroad curve (Fig. 5), we see not only an average peak, which is as clearly defined as that belonging to the lighting plant, but also that a variable loss occurs along the line. This loss amounts in the present case to a maximum of 15 per cent. Under such circumstances not only would the generating machinery be operated at a better maximum efficiency were storage batteries installed, but also by locating them along the line and not simply at the generating station, the great loss we speak of would be overcome without the use of additional feeders, and the cars could be run on a better time schedule and with greater satisfaction to the traveling public. At the present time the cost of the storage battery and its probable short life hinders extensive introduction into such plants. The average price at which storage batteries are furnished at the present time amounts to as much as 75 cents per pound of grid, which certainly seems excessive for such apparatus; and, while noting this high price, there seems to be no reason why battery makers should not increase the weight of lead in the battery grid, especially when we consider the fact that in such an increase of weight lies the secret of low maintenance cost for storage batteries. German manufacturers have realized the importance of this increase of weight and its small addition to the manufacturing cost, on account of the fact that they are required to guarantee the life of the cells, and it is to be hoped that the recent introduction of European batteries into this country will have a tendency toward heavy battery plates, with a consequent increase in life, and diminution of troubles due to buckling and short-circuiting. When these difficulties are completely overcome, as is now easily possible, the great first cost of the batteries will undoubtedly not militate so largely against their installation as it does at the present time."