

Optimal Capacitor Placement in a Radial Distribution System using Plant Growth Simulation Algorithm

R. Srinivasa Rao and S. V. L. Narasimham

Abstract—This paper presents a new and efficient approach for capacitor placement in radial distribution systems that determine the optimal locations and size of capacitor with an objective of improving the voltage profile and reduction of power loss. The solution methodology has two parts: in part one the loss sensitivity factors are used to select the candidate locations for the capacitor placement and in part two a new algorithm that employs Plant growth Simulation Algorithm (PGSA) is used to estimate the optimal size of capacitors at the optimal buses determined in part one. The main advantage of the proposed method is that it does not require any external control parameters. The other advantage is that it handles the objective function and the constraints separately, avoiding the trouble to determine the barrier factors. The proposed method is applied to 9, 34, and 85-bus radial distribution systems. The solutions obtained by the proposed method are compared with other methods. The proposed method has outperformed the other methods in terms of the quality of solution.

Keywords—Distribution systems, Capacitor placement, loss reduction, Loss sensitivity factors, PGSA.

I. INTRODUCTION

THE loss minimization in distribution systems has assumed greater significance recently since the trend towards distribution automation will require the most efficient operating scenario for economic viability variations. Studies have indicated that as much as 13% of total power generated is wasted in the form of losses at the distribution level [1]. To reduce these losses, shunt capacitor banks are installed on distribution primary feeders. The advantages with the addition of shunt capacitors banks are to improve the power factor, feeder voltage profile, Power loss reduction and increases available capacity of feeders. Therefore it is important to find optimal location and sizes of capacitors in the system to achieve the above mentioned objectives.

Since, the optimal capacitor placement is a complicated combinatorial optimization problem, many different optimization techniques and algorithms have been proposed in the past. Schmill [2] developed a basic theory of optimal capacitor placement. He presented his well known 2/3 rule for the placement of one capacitor assuming a uniform load and a uniform distribution feeder. Duran *et al* [3] considered the capacitor sizes as discrete variables and employed dynamic

programming to solve the problem. Grainger and Lee [4] developed a nonlinear programming based method in which capacitor location and capacity were expressed as continuous variables. Grainger *et al* [5] formulated the capacitor placement and voltage regulators problem and proposed decoupled solution methodology for general distribution system. Baran and Wu [6, 7] presented a method with mixed integer programming. Sundharajan and Pahwa [8] proposed the genetic algorithm approach to determine the optimal placement of capacitors based on the mechanism of natural selection. In most of the methods mentioned above, the capacitors are often assumed as continuous variables. However, the commercially available capacitors are discrete. Selecting integer capacitor sizes closest to the optimal values found by the continuous variable approach may not guarantee an optimal solution [16]. Therefore the optimal capacitor placement should be viewed as an integer-programming problem, and discrete capacitors are considered in this paper. As a result, the possible solutions will become a very large number even for a medium-sized distribution system and makes the solution searching process become a heavy burden.

In this paper, Capacitor Placement and Sizing is done by Loss Sensitivity Factors and Plant Growth Simulation Algorithm (PGSA) respectively. The loss sensitivity factor is able to predict which bus will have the biggest loss reduction when a capacitor is placed. Therefore, these sensitive buses can serve as candidate locations for the capacitor placement. PGSA is used for estimation of required level of shunt capacitive compensation to improve the voltage profile of the system. The proposed method is tested on 9, 34 and 85 bus radial distribution systems and results are very promising.

The advantages with the Plant Growth Simulation algorithm (PGSA) is that it treats the objective function and constraints separately, which averts the trouble to determine the barrier factors and makes the increase/decrease of constraints convenient, and that it does not need any external parameters such as crossover rate, mutation rate, etc. It adopts a guiding search direction that changes dynamically as the change of the objective function.

The remaining part of the paper is organized as follows: Section II gives the problem formulation; Section III sensitivity analysis and loss factors; Sections IV gives brief description of the plant growth simulation algorithm; Section

V develops the test results and Section VI gives conclusions.

II. PROBLEM FORMULATION

The objective of capacitor placement in the distribution system is to minimize the annual cost of the system, subjected to certain operating constraints and load pattern. For simplicity, the operation and maintenance cost of the capacitor placed in the distribution system is not taken into consideration. The three-phase system is considered as balanced and loads are assumed as time invariant.

Mathematically, the objective function of the problem is described as:

$$\min f = \min(\text{COST}) \quad (1)$$

where COST is the objective function which includes the cost of power loss and the capacitor placement.

The voltage magnitude at each bus must be maintained within its limits and is expressed as:

$$V_{\min} \leq |V_i| \leq V_{\max} \quad (2)$$

where $|V_i|$ is the voltage magnitude of bus i , V_{\min} and V_{\max} are bus minimum and maximum voltage limits, respectively.

The power flows are computed by the following set of simplified recursive equations derived from the single-line diagram depicted in Fig. 1.




Fig. 1 Single-line diagram of a main feeder

$$P_{i+1} = P_i - P_{Li+1} - R_{i,i+1} \cdot \frac{(P_i^2 + Q_i^2)}{|V_i|^2} \quad (3)$$

$$Q_{i+1} = Q_i - Q_{Li+1} - X_{i,i+1} \cdot \frac{(P_i^2 + Q_i^2)}{|V_i|^2} \quad (4)$$

$$|V_{i+1}|^2 = |V_i|^2 - 2(R_{i,i+1} \cdot P_i + X_{i,i+1} \cdot Q_i) + (R_{i,i+1}^2 + X_{i,i+1}^2) \cdot \frac{(P_i^2 + Q_i^2)}{|V_i|^2} \quad (5)$$

where P_i and Q_i are the real and reactive powers flowing out of bus i , and P_{Li} and Q_{Li} are the real and reactive load powers at bus i . The resistance and reactance of the line section between buses i and $i+1$ are denoted by $R_{i,i+1}$ and $X_{i,i+1}$,

respectively.

The power loss of the line section connecting buses i and $i+1$ may be computed as

$$P_{Loss}(i, i+1) = R_{i,i+1} \cdot \frac{(P_i^2 + Q_i^2)}{|V_i|^2} \quad (6)$$

The total power loss of the feeder, $P_{T,Loss}$, may then be determined by summing up the losses of all line sections of the feeder, which is given as

$$P_{T,Loss} = \sum_{i=0}^{n-1} P_{Loss}(i, i+1) \quad (7)$$

Considering the practical capacitors, there exists a finite number of standard sizes which are integer multiples of the smallest size Q_0^C . Besides, the cost per kVAr varies from one size to another.

In general, capacitors of larger size have lower unit prices. The available capacitor size is usually limited to

$$Q_{\max}^C = LQ_0^C \quad (8)$$

where L is an integer. Therefore, for each installation location, there are L capacitor sizes $\{Q_0^C, 2Q_0^C, 3Q_0^C, \dots, LQ_0^C\}$ available. Given the annual installation cost for each compensated bus, the total cost due to capacitor placement and power loss change is written as

$$\text{COST} = K_p P_{T,Loss} + \sum_{i=1}^n (K_{cf} + K_i^c Q_i^c) \quad (9)$$

where n is number of candidate locations for capacitor placement, K_p is the equivalent annual cost per unit of power loss in $\$/(\text{kW}\cdot\text{year})$; K_{cf} is the fixed cost for the capacitor placement. The constant K_i^c is the annual capacitor installation cost, and, $i = 1, 2, \dots, n$ are the indices of the buses selected for compensation. The bus reactive compensation power is limited to

$$Q_i^C \leq \sum_{i=1}^n Q_{Li} \quad (10)$$


where Q_i^C and Q_{Li} are the reactive power compensated at bus i and the reactive load power at bus i , respectively.

III. SENSITIVITY ANALYSIS AND LOSS SENSITIVITY FACTORS

The candidate nodes for the placement of capacitors are

determined using the loss sensitivity factors. The estimation of these candidate nodes basically helps in reduction of the search space for the optimization procedure.

Consider a distribution line with an impedance $R+jX$ and a load of $P_{eff} + jQ_{eff}$ connected between 'p' and 'q' buses as given below.



Active power loss in the k^{th} line is given by, $[I_k^2] * R[k]$ which can be expressed as,

$$P_{line\ loss} [q] = \frac{(P_{eff}^2 [q] + Q_{eff}^2 [q])R[k]}{(V[q])^2} \quad (11)$$

Similarly the reactive power loss in the k^{th} line is given by

$$Q_{line\ loss} [q] = \frac{(P_{eff}^2 [q] + Q_{eff}^2 [q])X[k]}{(V[q])^2} \quad (12)$$

Where, $P_{eff}[q]$ = Total effective active power supplied beyond the node 'q'.

$Q_{eff}[q]$ = Total effective reactive power supplied beyond the node 'q'.

Now, both the Loss Sensitivity Factors can be obtained as shown below:

$$\frac{\partial P_{line\ loss}}{\partial Q_{eff}} = \frac{(2 * Q_{eff} [q] * R[k])}{(V[q])^2} \quad (13)$$

$$\frac{\partial Q_{line\ loss}}{\partial Q_{eff}} = \frac{(2 * Q_{eff} [q] * X[k])}{(V[q])^2} \quad (14)$$

Candidate Node Selection using Loss Sensitivity Factors:

The Loss Sensitivity Factors ($\partial P_{line\ loss} / \partial Q_{eff}$) are calculated from the base case load flows and the values are arranged in descending order for all the lines of the given system. A vector bus position 'bpos[i]' is used to store the respective 'end' buses of the lines arranged in descending order of the values ($\partial P_{line\ loss} / \partial Q_{eff}$). The descending order of ($\partial P_{line\ loss} / \partial Q_{eff}$) elements of "bpos[i]" vector will decide the sequence in which the buses are to be considered for compensation. This sequence is purely governed by the ($\partial P_{line\ loss} / \partial Q_{eff}$) and hence the proposed 'Loss Sensitive Coefficient' factors become very powerful and useful in capacitor allocation or Placement. At these buses of 'bpos[i]' vector, normalized voltage magnitudes are calculated by

considering the base case voltage magnitudes given by (norm[i]=V[i]/0.95). Now for the buses whose norm[i] value is less than 1.01 are considered as the candidate buses requiring the Capacitor Placement. These candidate buses are stored in 'rank bus' vector. It is worth note that the 'Loss Sensitivity factors' decide the sequence in which buses are to be considered for compensation placement and the 'norm[i]' decides whether the buses needs Q-Compensation or not. If the voltage at a bus in the sequence list is healthy (i.e., norm[i]>1.01) such bus needs no compensation and that bus will not be listed in the 'rank bus' vector. The 'rank bus' vector offers the information about the possible potential or candidate buses for capacitor placement. The sizing of Capacitors at buses listed in the 'rank bus' vector is done by using Plant Growth Simulation Algorithm.

IV. PLANT GROWTH SIMULATION ALGORITHM

The plant growth simulation algorithm [15] is based on the plant growth process, where a plant grows a trunk from its root; some branches will grow from the nodes on the trunk; and then some new branches will grow from the nodes on the branches. Such process is repeated, until a plant is formed. Based on an analogy with the plant growth process, an algorithm can be specified where the system to be optimized first "grows" beginning at the root of a plant and then "grows" branches continually until the optimal solution is found.

By simulating the growth process of plant phototropism, a probability model is established. In the model, a function $g(Y)$ is introduced for describing the environment of the node Y on a plant. The smaller the value of $g(Y)$, the better the environment of the node for growing a new branch. The outline of the model is as follows: A plant grows a trunk M , from its root B_o . Assuming there are k nodes $B_{M1}, B_{M2}, B_{M3}, \dots, B_{Mk}$ that have better environment than the root on the trunk M , which means the function $g(Y)$ of the nodes and satisfy $g(B_{Mi}) < g(B_o)$ then morphactin concentrations $C_{M1}, C_{M2}, \dots, C_{Mk}$ of nodes $B_{M1}, B_{M2}, B_{M3}, \dots, B_{Mk}$ are calculated using

$$\begin{cases} C_{Mi} = \frac{g(B_o) - g(B_{Mi})}{\Delta_1} & (i = 1, 2, \dots, k) \\ \Delta_1 = \sum_{i=1}^k (g(B_o) - g(B_{Mi})) \end{cases} \quad (15)$$




Fig. 2 Morphactin concentration state space

The significance of equation (15) is that the morphactin concentration of a node is not only dependent on its environmental information but also depends on the

environmental information of the other nodes in the plant, which really describes the relationship between the morphactin concentration and the environment. From (15), we can derivate $\sum_{i=1}^k C_{Mi} = 1$, which means that the morphactin concentrations $C_{M1}, C_{M2}, \dots, C_{Mk}$ of nodes $B_{M1}, B_{M2}, B_{M3}, \dots, B_{Mk}$ form a state space shown in Fig. 2. Selecting a random number β in the interval $[0, 1]$, β is like ball thrown to the interval $[0, 1]$ and will drop into one of $C_{M1}, C_{M2}, \dots, C_{Mk}$ in Fig. 2, then the corresponding node that is called the preferential growth node will take priority of growing a new branch in the next step. In other words, B_{MT} will take priority of growing a new branch if the selected β satisfies

$$0 \leq \beta \leq \sum_{i=1}^T C_{Mi} \quad (T=1) \text{ or}$$

$$\sum_{i=1}^{T-1} C_{Mi} < \beta \leq \sum_{i=1}^T C_{Mi} \quad (T=2,3,\dots,k).$$

For example, if random number β drops into C_{M2} , which means $\sum_{i=1}^1 C_{Mi} < \beta \leq \sum_{i=1}^2 C_{Mi}$, then the node B_{M2} will grow a new branch m . Assuming there are q nodes $B_{m1}, B_{m2}, B_{m3}, \dots, B_{mq}$, which have a better environment than the root B_0 , on the branch m , and their corresponding morphactin concentrations are $C_{m1}, C_{m2}, \dots, C_{mq}$. Now, not only the morphactin concentrations of the nodes on branch m need to be calculated, but also the morphactin concentrations of the nodes except B_{M2} (the morphactin concentration of the node B_{M2} becomes zero after growing the branch m) on trunk M need to be recalculated after growing the branch m . The calculation can be done using (16), which is gained from (15) by adding the related terms of the nodes on branch m and abandoning the related terms of the node B_{M2}

$$\begin{cases} C_{Mi} = \frac{g(B_0) - g(B_{Mi})}{\Delta_1 + \Delta_2} & (i = 1, 3, \dots, k) \\ C_{mj} = \frac{g(B_0) - g(B_{mj})}{\Delta_1 + \Delta_2} & (j = 1, 2, \dots, q) \end{cases} \quad (16)$$

where

$$\Delta_1 = \sum_{i=1, i \neq 2}^k (g(B_0) - g(B_{Mi}))$$

$$\Delta_2 = \sum_{j=1}^q (g(B_0) - g(B_{mj})).$$

We can also derivate $\sum_{i=1, i \neq 2}^k C_{Mi} + \sum_{j=1}^q C_{mj} = 1$ from (16). Now, the morphactin concentrations of the nodes (except B_{M2}) on trunk M and branch m will form a new state space

(The shape is the same as Fig. 2, only the nodes are more than that in Fig. 2). A new preferential growth node, on which a new branch will grow in the next step, can be gained in a similar way as B_{M2} .

Such process is repeated until there is no new branch to grow, and then a plant is formed.

From the viewpoint of optimal mathematics, the nodes on a plant can express the possible solutions; $g(Y)$ can express the objective function; the length of the trunk and the branch can express the search domain of possible solutions; the root of a plant can express the initial solution; the preferential growth node corresponds to the basic point of the next searching process. In this way, the growth process of plant phototropism can be applied to solve the problem of integer programming.

A complete algorithm for the proposed method of capacitor placement is given below:

1. input the system data such as line and load details of the distribution system, constraints limits etc.;
2. form the search domain by giving the range of capacitor ratings (kVAr ratings) available which corresponds to the length of the trunk and the branch of a plant;
3. give the initial solution X_0 (X_0 is vector) which corresponds to the root of a plant, and calculate the initial value objective function (power loss);
4. let the initial value of the basic point X^b , which corresponds to the initial preferential growth node of a plant, and the initial value of optimization X^{best} equal to X_0 , and let F^{best} that is used to save the objective function value of the best solution X^{best} be equal to $f(X_0)$, namely, $X^b = X^{best} = X_0$ and $F^{best} = f(X_0)$;
5. identify the candidate buses for capacitor placement using Loss Sensitivity Factors;
6. initialize iteration count, $i=1$;
7. for $j=n$ to m (with step size 1), where m is the minimum available size and n is maximum available size;
8. search for new feasible solutions: place kVAr at sensitive nodes in a sequence starting from basic point $X^b = [X_1^b, X_2^b, \dots, X_i^b, \dots, X_n^b]$, where X^b corresponds to the initial kVAr;
9. for each solution X^b in step 8, calculate the nodes voltages of the buses;
10. if the node voltage constraints is satisfied go to step 10; otherwise abandon the possible solution X^b and goto step 12;
11. calculate powerloss $f(X^b)$ for each solution of X^b in step 8 and compare with $f(X_0)$. Save the feasible solutions if $f(X^b)$ less than $f(X_0)$;
12. Otherwise goto step 12;
13. if $i > N_{max}$ go to step 16; otherwise goto step 14;
14. calculate the probabilities C_1, C_2, \dots, C_k of feasible solutions X_1, X_2, \dots, X_k , by using equation (15), which corresponds to determining the morphactin concentration of the nodes of a plant;
15. calculate the accumulating probabilities $\sum C_1, \sum C_2, \dots, \sum C_k$ of the solutions X_1, X_2, \dots, X_k . Select a random number

- β from the interval $[0, 1]$, β must belong to one of the intervals $[0, \sum C_i]$, $(\sum C_i, \sum C_2]$, ..., $(\sum C_{k-1}, \sum C_k]$, the accumulating probability of which is equal to the upper limit of the corresponding interval, and it will be the new basic point X^b for the next iteration, which corresponds to the new preferential growth node of a plant for next step;
15. increment i by $i+1$ and return to step 6;
 16. output the results and stop.

The flow chart for the proposed method based on the algorithm is given in the fig. 3.




Fig. 3 Flow chart for proposed method

V. TEST RESULTS

The proposed method has been programmed using MATLAB and run on a Pentium IV, 3-GHz personal computer with 0.99 GB RAM. The effectiveness of the

proposed method for loss reduction by capacitor placement is tested on 9 bus, 34 bus and 85 bus radial distribution systems. The results obtained in these methods are explained in the following sections.

A. 9 - Bus system

The first test case for the proposed method is a 10-bus, single feeder, radial distribution system [16] shown in fig.4. This system has zero laterals. The rated line voltage of the system is 23 kV. The details of the feeder and the load characteristics are given in Table 1.




Fig. 4 A 9-Section feeder

TABLE I LOAD AND LINE DATA OF 9-BUS SYSTEM

Line No.	From Bus, i	To Bus, i+1	$R_{i,i+1}$ (Ω)	$X_{i,i+1}$ (Ω)	P_L (kW)	Q_L (kVAR)
1	0	1	0.1233	0.4127	1840	460
2	1	2	0.0140	0.6057	980	340
3	2	3	0.7463	1.2050	1790	446
4	3	4	0.6984	0.6084	1598	1840
5	4	5	1.9831	1.7276	1610	600
6	5	6	0.9053	0.7886	780	110
7	6	7	2.0552	1.1640	1150	60
8	7	8	4.7953	2.7160	980	130
9	8	9	5.3434	3.0264	1640	200

For this test feeder, K_p is selected to be 168 \$/(kW-year) [16]. Commercially available capacitors sizes with \$/kVAR are used in the analysis. Table 2 shows the example of such data.

TABLE II AVAILABLE THREE PHASE CAPACITOR SIZES AND COSTS

Size (kVAR)	150	300	450	600	900	1200
Cost (\$)	750	975	1140	1320	1650	2040

Only fixed capacitors are used in the analysis and the marginal cost of capacitors (K_c^i) [18] given in Table 3 are used to compute the total annual cost. The fixed cost of the capacitor, K_{cf} is selected as \$1000 [20] with a life expectancy of ten years (the maintenance and running costs are neglected).

The substation voltage (bus 1) is considered as 1.0 p.u. The limit of voltage magnitude is taken between 0.90 ~ 1.10 p.u. The method of sensitive analysis is used to select the candidate installation locations of the capacitors to reduce the search space. The buses are ordered according to their sensitivity value $(\partial P_{line\ loss} / \partial Q_{eff})$ (i.e., bus 6, 5, 9, 10, 8 and 7). Top four buses are selected as optimal candidate locations and then amount of kVAR to be injected in the selected buses is optimized by PGSA.

TABLE III POSSIBLE SIZES OF CAPACITORS AND SIZES IN \$/kVAR

j	1	2	3	4	5	6	7
Q_j^c	150	300	450	600	750	900	1050
\$/kVAr	0.500	0.350	0.253	0.220	0.276	0.183	0.228
j	8	9	10	11	12	13	14
Q_j^c	1200	1350	1500	1650	1800	1950	2100
\$/kVAr	0.170	0.207	0.201	0.193	0.187	0.211	0.176
j	15	16	17	18	19	20	21
Q_j^c	2250	2400	2550	2700	2850	3000	3150
\$/kVAr	0.197	0.170	0.189	0.187	0.183	0.180	0.195
j	22	23	24	25	26	27	--
Q_j^c	3300	3450	3600	3750	3900	4050	--
\$/kVAr	0.174	0.188	0.170	0.183	0.182	0.179	--

Using this method, the capacitors of rating 1200, 1200, 200, 407 kVAR are placed at the optimal candidate locations 6, 5, 9, and 10 respectively. The initial power loss is 783.77 kW and it is reduced to 694.93 kW after capacitor placement using the proposed method. The results of the proposed method are shown in Table 4. Table 4 also shows the comparison of results with Fuzzy reasoning [19] and Particle Swarm Optimization (PSO) [21]. The minimum and maximum voltages before capacitor placement are 0.8375 p.u (bus 10) and 0.9929 p.u (bus 2) and these are improved to 0.901 p.u (bus10) and 0.9991 p.u (bus2) after capacitors placement.

TABLE IV SIMULATION RESULTS OF 9-BUS SYSTEM

Items	Un-compensated	Compensated		
		Fuzzy reasoning [19]	PSO [21]	Proposed
Total losses (kW)	783.77	704.883	696.21	694.93
Loss reduction (%)	---	10.065	11.17	11.33
Optimal locations and Size in kVAR	---	4 1050 5 1050 6 1950 10 900	6 1174 5 1182 9 264 10 566	6 1200 5 1200 9 200 10 407
Total kVAr		4950	3186	3007
Annual Cost (\$/year)	131,674	119,420	118,582	118,340
Net Savings (\$/year)	---	12,255	13,091	13,334
%Saving	---	9.31	9.94	10.13

From Table 4, it is observed that the power loss obtained with the proposed method is less than the Fuzzy reasoning [19] and PSO [21]. The optimal candidate locations are the same with all methods but the total kVAr injected by the proposed method is less than the other two. The selection of the allowable consecutive iterative number N_{max} depends highly on the solved problem. The N_{max} value is tried from 2 to 25. All of the results converge to the same optimal solution with N_{max} greater than 4. The convergence characteristics of power loss of the PGSA in this test system are shown in fig. 5. It can be observed that the number of iterations taken is only four on this computer. The CPU time needed is only 0.6 seconds.




Fig. 5 Convergence curve of PGSA

B. 34 - Bus system

The second test case for the proposed method is a 34-bus radial distribution system [22]. This system has a main feeder and four laterals (sub-feeders). The single line diagram is shown in fig. 6. The line and load data of the feeders are taken from the reference [22]. The rated line voltage of the system is 11 kV.




Fig. 6 34 - bus distribution network configuration

Similar to test case 1, the sensitive analysis method is used to select the candidate installation locations of the capacitor to reduce the search space. The buses are ordered according to their sensitivity value as {19, 22, 20, 21, 23, 24, 25, 26, and 27}. Top three buses are selected as optimal candidate locations and the amount of kVAr injected are 1200, 639, and 200 kVAr respectively. The constants K_p , K_c^i , and K_{cf} are same as in test case 1. The power loss before and after capacitor placement are 221.67 and 161.07 kW. The minimum and maximum voltages before capacitor placement are 0.9417 p.u (bus 27) and 0.9941 p.u (bus 2) and are improved to 0.9731 p.u and 1.000 p.u after capacitor placement respectively at the buses 27 and 2. The N_{max} value is tried from 2 to 80. All of the results converge to the same optimal solution with N_{max} greater than 8. The results of the proposed method are compared with the results of PSO method [21] and Heuristic based method [22] and is shown in Table 5. The implementation shows that the sub-feeder connected to node 6 of main feeder only need the compensation. From the results shown in Table 5, it is observed that the optimal candidate installation locations are three for the proposed and PSO methods [21], but it is four for the Heuristic method [22]. The

power loss and net annual savings obtained with proposed method are less than PSO methods and Heuristic based. The CPU time needed by the proposed method is 11 sec.

TABLE V SIMULATION RESULTS OF 34-BUS SYSTEM

Items	Un-compensated	Compensated		
		Heuristic based [19]	PSO [21]	Proposed
Total losses (kW)	221.67	168.47	168.8	161.07
Loss reduction (%)	---	23.999	23.850	27.337
Optimal locations and Size in kVAR	---	26 1400 11 750 17 300 4 250	19 781 22 803 20 479 -- ---	19 1200 22 639 20 200 -- ---
Total kVAr		2700	2063	2039
Annual Cost (\$/year)	37,241	33,182	29,936	28,484
Net Saving (\$/year)	--	4,089	7,306	8,756

C. 85-Bus system

The third test case is 85-bus radial distribution system which is same as in Das *et al* [23]. The line data and feeder characteristics are taken from reference [23]. Based on sensitivity analysis buses 8, 58, and 7 are selected as optimal candidate locations for the capacitor placement. Using proposed PGSA, the amount of kVAr injected are 1200, 908, and 200 kVAr at the above buses. The constants in the objective function are same as test case 1. The N_{max} value tried from 2 to 80 and all of the results converge to the same optimal solution with N_{max} greater than 8. The minimum and maximum voltages before compensation are 0.8877 and 0.9952 p.u and are improved to 0.96571 and 0.9991 p.u respectively. The power loss power loss before and after compensation and net savings are shown in Table 6.

TABLE VI SIMULATION RESULTS OF 85-BUS SYSTEM

Items	Un-compensated	Compensated	
		PSO [21]	Proposed
Total losses (kW)	315.714	163.32	161.4
Loss reduction (%)	---	48.27	48.88
Optimal locations and Size in kVAR	---	8 796 58 453 7 324 27 901	8 1200 58 908 7 200 -- ---
Total kVAr		2473	2308
Annual Cost (\$/year)	53,040	29,051	28,585
Net Saving (\$/year)	---	23,990	24,455

The Table 6 also shows the comparison of results with the PSO method [21]. From the results it is observed that the power loss after compensation and net annual savings are almost the same, but optimal candidate locations with the proposed method is less than the PSO method. The CPU time needed by the proposed method is 20.4 sec.

VI. CONCLUSION

A new and efficient approach that employs loss sensitivity factors and PGSA for capacitor placement in the distribution system has been proposed. The loss sensitivity factors are used to determine the candidate locations of the buses

required for compensation. The PGSA is used to estimate the required level of shunt capacitive compensation at the optimal candidate locations to enhance the voltage profile the system and reduce the active power loss. The simulation results based on 9, 34, 85-bus systems have produced the best solutions that have been found using a number of approaches available in the literature. The advantages of the proposed method are: 1) it handles the objective function and the constraints separately, avoiding the trouble to determine the barrier factors; 2) the proposed approach does not require any external parameters; 3) the proposed approach has a guiding search direction that continuously changes as the change of the objective function. This method places the capacitors at less number of locations with optimum size and offers much net annual saving in initial investment.

REFERENCES

- [1] Y. H. Song, G. S. Wang, A. T. Johns and P.Y. Wang, "Distribution network reconfiguration for loss reduction using Fuzzy controlled evolutionary programming," *IEEE Trans. Gener., trans., Distri.*, Vol. 144, No.4, July 1997.
- [2] J. V. Schmill, "Optimum Size and Location of Shunt Capacitors on Distribution Feeders," *IEEE Transactions on Power Apparatus and Systems*, vol. 84, pp. 825-832, September 1965.
- [3] H. Dura "Optimum Number Size of Shunt Capacitors in Radial Distribution Feeders: A Dynamic Programming Approach", *IEEE Trans. Power Apparatus and Systems*, Vol. 87, pp. 1769-1774, Sep 1968.
- [4] J. J. Grainger and S. H. Lee, "Optimum Size and Location of Shunt Capacitors for Reduction of Losses on Distribution Feeders," *IEEE Trans. on Power Apparatus and Systems*, Vol. 100, No. 3, pp. 1105-1118, March 1981.
- [5] J.J. Grainger and S. Civanlar, "Volt/var control on Distribution systems with lateral branches using shunt capacitors as Voltage regulators-part I, II and III," *IEEE Trans. Power Apparatus and systems*, vol. 104, No. 11, pp. 3278-3297, Nov. 1985.
- [6] M. E Baran and F. F. Wu, "Optimal Sizing of Capacitors Placed on a Radial Distribution System", *IEEE Trans. Power Delivery*, vol. No.1, pp. 1105-1117, Jan. 1989.
- [7] M. E. Baran and F. F. Wu, "Optimal Capacitor Placement on radial distribution system," *IEEE Trans. Power Delivery*, vol. 4, No.1, pp. 725-734, Jan. 1989.
- [8] Sundharajan and A. Pahwa, "Optimal selection of capacitors for radial distribution systems using genetic algorithm," *IEEE Trans. Power Systems*, vol. 9, No.3, pp.1499-1507, Aug. 1994.
- [9] H. N. Ng, M. M. A. Salama and A. Y. Chikhani, "Capacitor Allocation by Approximate Reasoning: Fuzzy Capacitor Placement," *IEEE Trans. Power Delivery*, vol. 15, no.1, pp. 393-398, Jan. 2000.
- [10] H.C.Chin, "Optimal Shunt Capacitor Allocation by Fuzzy Dynamic Programming," *Electric Power Systems Research*, pp.133-139, Nov. 1995.
- [11] N. I. Santoso, O. T. Tan, "Neural- Net Based Real- Time Control of Capacitors Installed on Distribution Systems," *IEEE Trans. Power Delivery*, vol. PAS-5, No.1, pp. 266-272, Jan. 1990.
- [12] M. Kaplan, "Optimization of Number, Location, Size, Control Type and Control Setting Shunt Capacitors on Radial Distribution Feeder", *IEEE Trans. on Power Apparatus and System*, Vol.103, No.9, pp. 2659-63, Sep 84.
- [13] Chun Wang and Hao Zhong Cheng, "Reactive power optimization by plant growth simulation algorithm," *IEEE Trans. on Power Systems*, Vol.23, No.1, pp. 119-126, Feb. 2008.
- [14] Ji-Pyng Chiou, Chung-Fu Chang and Ching-Tzong Su, "Capacitor placement in large scale distribution system using variable scaling hybrid differential evolution," *Electric Power and Energy Systems*, vol. 28, pp.739-745, 2006.
- [15] Chun Wang, H. Z. Cheng and L. Z. Yao, "Optimization of network reconfiguration in large distribution systems using plant growth simulation algorithm," *DRPT 2008 Conference*, Nanjing, China, pp. 771-774, 6-9, April 2008.

- [16] Baghzouz. Y and Ertem S, "Shunt capacitor sizing for radial distribution feeders with distorted substation voltages," *IEEE Trans Power Delivery*, Vol. 5, pp.650-57, 1990.
- [17] J. B. Bunch, R. D. Miller, and J. E. Wheeler, "Distribution system integrated voltage and reactive power control," *IEEE Trans. Power Apparatus and Systems*, vol. 101, no. 2, pp. 284-289, Feb. 1982.
- [18] S. F. Mekhamer *et al*, "New heuristic strategies for reactive power compensation of radial distribution feeders," *IEEE Trans Power Delivery*, Vol. 17, No. 4, pp.1128-1135, October 2002.
- [19] Su C. T and Tsai C. C, "A new fuzzy reasoning approach to optimum capacitor allocation for primary distribution systems," *Proc IEEE on Industrial Technology Conf*, 1996; pp. 237-41.
- [20] D. Das, "Reactive power compensation for radial distribution networks using genetic algorithms," *Electric Power and Energy Systems*, vol. 24, pp.573-581, 2002.
- [21] Prakash K. and Sydulu M, "Particle swarm optimization based capacitor placement on radial distribution systems," *IEEE Power Engineering Society general meeting 2007*. pp. 1-5.
- [22] M.Chis, M. M. A. Salama and S. Jayaram, "Capacitor Placement in distribution system using heuristic search strategies," *IEE Proc-Gener, Transm, Distrib*, vol, 144, No.3, pp. 225-230, May 1997.
- [23] Das *et al*, "Simple and efficient method for load flow solution of radial distribution network," *Electric Power and Energy Systems*, vol. 17, No.5, pp.335-346, 1995.
- [24] H. D. Chiang, J. C.Wang, O. Cockings, and H. D. Shin, "Optimal capacitor placements in distribution systems: Part1 & Part II", *IEEE Trans. Power Delivery*, vol. 5, pp. 634-649, Apr. 1990.
- [25] M. Jaeger and P. H. De Reffye, "Basic concepts of computer simulation of plant growth," *Journal of Bioscience (India)*, Vol. 17, No. 3, pp. 275-291, September 1992.

R. Srinivasa Rao is a research scholar in Jawaharlal Nehru Technological University, Hyderabad, INDIA. His areas of interest include electric power distribution systems and power systems operation and control.

S.V.L Narasimham is Professor of Computer Science and Engineering Department, Jawaharlal Nehru Technological University, Hyderabad, INDIA. His areas of interests include real time power system operation and control, ANN, Fuzzy logic and Genetic Algorithm applications to Power Systems.