

1 **Combined Sewer Overflows: A critical review on best practice and innovative solutions to**
2 **mitigate impacts on environment and human health**

3 **Alice Botturi¹, E. Gozde Ozbayram^{2*}, Katharina Tondera³, Nathalie I. Gilbert⁴, Pascale**
4 **Rouault⁵, Nicolas Caradot⁵, Oriol Gutierrez⁶, Saba Daneshgar¹, Nicola Frison¹, Çağrı**
5 **Akyol⁷, Alessia Foglia⁷, Anna Laura Eusebi^{7*}, Francesco Fatone⁷**

6 ¹ Department of Biotechnology, University of Verona, 37134, Verona, Italy

7 ² Faculty of Aquatic Sciences, Istanbul University, 34134, Istanbul, Turkey

8 ³ IMT Atlantique, GEPEA, UBL, F-44307 Nantes, France

9 ⁴ Thames21, London, UK

10 ⁵ Kompetenzzentrum Wasser Berlin (KWB), Berlin, Germany

11 ⁶ Catalan Institute for Water Research, ICRA Scientific and Technological Park of the University
12 of Girona, Emili Grahit 101, 17003 Girona, Spain

13 ⁷ Department of Science and Engineering of Materials, Environment and Urban Planning-
14 SIMAU, Faculty of Engineering, Polytechnic University of Marche, 60121, Ancona, Italy

15 *** Corresponding author (A.L. EUSEBI)**

16 Department of Science and Engineering of Materials, Environment and Urban Planning-SIMAU,
17 Faculty of Engineering, Polytechnic University of Marche, 60121, Ancona, Italy

18 E-mail: a.l.eusebi@univpm.it, Phone: +39 071 2204911 Fax: +39 071 2204729

19 ***Corresponding author (E.G. OZBAYRAM)**

20 Faculty of Aquatic Sciences, Istanbul University, 34134, Istanbul, Turkey

21 E-mail: gozde.ozbayram@istanbul.edu.tr, Phone: +90554 734 6496

22 **Abstract**

23 Combined sewer overflows (CSOs) are of major environmental concern for impacted surface
24 waterbodies. In the last decades, major storm events have become increasingly regular in some
25 areas, and meteorological scenarios predict a further rise in their frequency. Consequently,
26 control and treatment of CSOs with respect to best practice examples, innovative treatment
27 solutions and management of sewer systems is an inevitable necessity. As a result, the number of
28 publications concerning quality, quantity and type of treatments has recently increased. This
29 review therefore aims to provide a critical overview on the effects, control and treatment of CSOs
30 in terms of impact on the environment and public health, strict measures addressed by
31 regulations, and the various treatment alternatives including natural and compact treatments.
32 Drawing together the previous studies, an innovative treatment and control guideline is also
33 proposed for the better management practices.

34

35

36 **Keywords:** Combined sewer overflows; nature based solutions; sewer system; urban water
37 management; water quality

38

39 **Abbreviations**

BFU	Ballasted Flocculation Unit
BOD ₅	Biochemical Oxygen Demand
BWD	Bathing Water Directive
COD	Chemical Oxygen Demand
CSO	Combined Sewer Overflow
CSS	Combined Sewer System
CW	Constructed Wetland
EPA	United States Environmental Protection Agency
GAC	Granular Activated Carbon
NBS	Nature based solutions
NPDES	National Pollutant Discharge Elimination System
OCC	Optimum Coagulant Concentrations
PAA	Peracetic Acid
PFA	Performic Acid
RSF	Retention Soil Filter
SSO	Sanitary Sewer Overflow
SUDS	Sustainable Urban Drainage System
TKN	Total Kjeldahl Nitrogen
TSS	Total Suspended Solid
UVT	UV Transmittance
UWWTD	Urban Waste Water Treatment Directive
WFD	Water Framework Directive

WWTP	Wastewater Treatment Plant
------	----------------------------

40

41 **1. Introduction**

42 The European Water Framework Directive (WFD, 2000) is the key policy driver in the water
43 sector focusing on management strategies for improving water quality and protection of the
44 receiving bodies from wastewater effluent discharges. It emphasizes the control of diffuse
45 pollution as a major factor in enabling good ecological status in all waterbodies of member states.

46 Wastewater and storm water collection, as well as their management, are crucial services
47 protecting public health and the environment, thus appropriate receiving systems facilitate urban
48 development. Additionally, countries also develop national regulations to sustain environmental
49 protection and to better manage the sewage systems.

50 In Europe, there are two major system types to collect and transport wastewater: the separate
51 system and combined system and modified versions thereof. In the separate system, the waste
52 water and storm water are transported in two separate pipelines (Figure 1a). The sewage from
53 households and industry is carried to wastewater treatment plants (WWTPs) and the storm water
54 is discharged into the nearest waterbody, usually only with physical pre-treatment. Although
55 runoff from urban surfaces may collect contaminants along the way (such as pathogens,
56 hydrocarbons, grit, sediment, chemicals and heavy metals), this discharge does not generally
57 require an environmental permit and it is usually consented by environmental regulators (Jotte,
58 Raspati, & Azrague, 2017).

59 In the combined sewer system (CSS), sewage and storm water are carried in one unified sewer
60 network to the centralized WWTP. Under dry weather conditions, the CSS only collects
61 municipal and industrial wastewater, but this is mixed with surface runoff under wet weather
62 conditions.

63 In modified sewer systems, rainwater is treated according to its pollution: infiltration of

64 minimally contaminated roof runoff, transport of storm water from low trafficked roads, streets
65 and pavements by open drains or the direct use for landscaping purposes is possible.

66 However, all sewer infrastructure is limited in its capacity for water intake and transport. Usually,
67 CSSs are unable to cope with the flows experienced during heavy rain events, so a relief
68 mechanism is inserted in the wastewater network which is a combined sewer overflow
69 infrastructure. This directs excess flows, comprising a mixture of untreated raw sewage and storm
70 water, to the receiving waterbodies. These structures are used to maintain the flowrates in the
71 network and protect properties from potential flooding (Bailey, Harris, Keedwell, Djordjevic, &
72 Kapelan, 2016).

73 Up to date, limited information has been published internationally concerning the extent and
74 occurrence of CSOs and discharge points. It is estimated that there are 2.2 million km of existing
75 sewerage systems in Europe, of which approx. 70% of the total network is combined sewers.
76 Moreover, there are approx. 650.000 CSOs and their impact on the receiving waterbody is an
77 increasing concern across Europe (EurEau, 2016). Some information can be obtained from
78 reports submitted to the European Union by member states. E.g. in 2012, Germany submitted a
79 request to extend the deadline of fulfilling the goals of the Water Framework Directive (reaching
80 a “good” ecological and chemical status of 80% of surface waterbodies by 2015) until 2027. In a
81 summary of the 2012 report to the European Commission (BMU, 2013), the authors describe that
82 10% of the key measures required reach the good status pertain to sewer systems and municipal
83 wastewater treatment plants. From the total number of these key measures mentioned in the
84 report, approximately 28% of them concern storm water in combined and separate sewer systems
85 and only 12% of them has a connection to the sewer system in general (UBA, 2012). Since this
86 report does not mention costs or the kind of measures taken to reach the EU targets, it still

87 remains unclear which role measures in the CSS play in relation to others.

88 The American Society of Civil Engineers estimated that the infrastructure for CSO control may
89 cost around \$45 billion, which is the largest necessity in the water/wastewater sector for the
90 country (Ruggaber & Talley, 2005). Today, in the USA there are 746 communities with CSSs
91 containing a total of 9,348 CSO outfalls that are identified and regulated by 828 National
92 Pollutant Discharge Elimination System (NPDES) permits. CSSs are found in 32 states and nine
93 EPA (Environmental Protection Agency) Regions. CSO communities are regionally
94 concentrated in older communities in the Northeast and Great Lakes regions. The EPA estimates
95 that approx. $3.9 \cdot 10^9$ m³ of untreated combined sewage is released as CSOs each year in the
96 United States (US-EPA, 2004).

97 Since CSOs result from a mixture of raw sewage and storm water, they possess a serious threat of
98 microbial pathogens (Al Aukidy & Verlicchi, 2017), micropollutants from personal care products
99 (Heinz et al., 2009), hormones Phillips et al., 2012), pharmaceutical and illicit drugs (Munro et
100 al., 2019), pesticides (Gasperi et al., 2012; Launay, Dittmer, & Steinmetz, 2016), suspended
101 solids, heavy metals, nutrients and microplastics in surface waterbodies (Al Aukidy & Verlicchi,
102 2017; Kistemann, Schmidt, & Flemming, 2016; Madoux-Humery et al., 2015; Masi, Rizzo,
103 Bresciani, & Conte, 2017; Munro et al., 2019; Suárez & Puertas, 2005; Tanaka & Takada, 2016;
104 Tondera, Koenen, & Pinnekamp, 2013; Xu et al., 2018). Meteorological and climate change
105 predictions indicate an expected rise in the frequency and intensity of storm events with the
106 implication that sewer system capacity will be exceeded more regularly. Furthermore, increased
107 base flow in sewers due to trends for increasing urbanization and population growth in many
108 cities worldwide means sewers fill up faster, which increases the likelihood of overflows during
109 smaller rain events. Expansion of urban areas also leads to an increase of impermeable surfaces

110 within catchments and faster surface water runoff, which also influences the frequency of CSOs
111 (Schertzinger et al. 2018).

112 Publications on treatment and control alternatives for CSOs are limited in number. More studies
113 should focus on best practice and innovative solutions for treatment and management of sewer
114 systems and recently there has been an increase in literature concerning the quality, quantity and
115 type of treatments (Masi et al., 2017; Rizzo et al., 2018; Ruppelt, Tondera, Vorenhout, Van der
116 Weken, & Pinnekamp, 2019; Tondera, 2017). Since sustainable city approach requires reducing
117 impacts of wastewaters in aquatic environments, integrated strategies should be evaluated within
118 this context. Additionally, smart network monitoring and smart data infrastructures (US EPA,
119 2018) are currently under development and application. These infrastructures are implemented in
120 connection with a supervisory control and data acquisition (SCADA) system and are mainly
121 focused on real-time monitoring of flow rates (physically or with alternative methods) and
122 effluent levels in CSO's with the aim of assessing potential flooding and pollution incidents and
123 to support real-time or quasi real-time decision making about actions to be taken. Research and
124 innovation play an important role in the implementation and improvement of new technologies
125 and approaches in this field. Changes of frequency and intensity of rain events increase the
126 pressure on meeting the requirements stated in the EU regulations (e.g. Water Framework
127 Directive, Bathing Water Directive) and national legislations; thus, to integrate the reduction
128 measures, several projects were founded within this scope. The EU 7th Framework Program for
129 Research and Innovation funded more than 140 research and innovation projects related to this
130 topic in the period 2007-2013, and other projects are being supported by Horizon 2020
131 Innovation funding. For example, one aim of the INTCATCH H2020 Project (<http://intcatch.eu/>),
132 is technological innovation and integration in smart water monitoring in the treatment of CSOs

133 before their discharge into a waterbody. A pilot plant was installed and operated for about two
134 years on Lake Garda, Italy, to demonstrate the concept of technological innovation and public
135 participation in the integrated and smart management of water infrastructures and basins.

136 Taken together, the attempt of this review is to develop better understanding on CSOs by
137 exploring the impact and mass load in terms of quantity and quality, treatments possibilities, both
138 as conventional and more innovative options, guidelines to management and actual policy and
139 future recommendations.

140 **2. The characteristics of combined sewer overflows**

141 Climatic factors such as quantity and intensity of precipitation are key factors determining the
142 severity of CSO discharges. The characteristics of combined sewage are dependent on rainfall
143 intensities and pollutant concentration and loads affected by wet and dry weather conditions
144 (Sandoval, Torres, Pawlowsky-Reusing, Riechel, & Caradot, 2013). Moreover, during
145 transportation in the sewer system, the physical, chemical and biological characteristics of
146 wastewater changes (Nielsen, Raunkjær, Norsker, Jensen, & Hvitved-Jacobsen, 1992).

147 The relationship between rainfall, flood and overflow frequencies on water quality in CSO
148 discharges are nonlinear (Willems, 2012). Climate change also has a major impact on CSO
149 volumes for the regions where heavy rainfall events occur more frequently. As such, CSO
150 discharges represent a great challenge to meeting required water quality standards in locations
151 with CSSs. How CSOs impact the water quality of the receiving bodies should be evaluated in an
152 integrated manner considering the flows, concentration and season in which the impact is more
153 destructive – in Europe this is usually during low flow regimes during summer months (Willems,
154 2012). As this is also a period of increased recreational activities in surface waterbodies
155 (Kistemann et al., 2016), severe health ramifications can be linked to CSO discharges (McBride,

156 Stott, Miller, Bambic, & Wuertz, 2013). Monitoring studies indicate that the frequency of CSOs
157 has increased in recent years. Whereas 9 CSO events were observed in 2012 in Lodz, the third
158 largest city in Poland, the number increased to 23 in 2014 which exceed the number permitted by
159 the legislation (10 times per year, Brzezińska et al., 2016) (Table 1). Similarly, CSO frequency
160 and volume also increased by varying amounts in England (Willems, 2012). It is clear from the
161 table that low number of events were analysed compared to the number of CSOs registered in the
162 study area. In another study, Al Aukidy and Verlicchi, (2017) reported 20 CSO events within 3
163 months in the Po Valley, Italy. The total overflow volume ranged between 18-16.299 m³, the
164 volume increased over years. Heinz et al. (2009) indicated that 9–10 overflow events occur in
165 Gallusquelle region in Germany annually with an average discharge of approximately 23,000 m³.
166 In the River Thames, London, approx. 39 million tons of untreated sewage enters the river
167 annually from approx. 57 different CSO locations (Munro et al. 2019). Madoux-Humery et al.
168 (2016) carried out their study in Québec (Canada) where the annual precipitation falling as
169 rainfall is 625 mm/year and average cumulative precipitation falling as snow of approximately
170 2000 mm/year. They observed 2258 CSO events during the 2009-2011 period. Soriano and Rubió
171 (2019) stated that there are 35 overflow points located along the Ebro river in which many of
172 these overflow points have two to four discharge points, overall there are 72 overflow points in
173 Ebro river.

174 An overview of pollutant ranges in combined sewage from CSO discharges is given in Table 2.
175 The water quality varies according to factors such as location, rainfall duration, season etc.

176 **Table 1.** The combined sewer overflow monitoring

Area	Monitoring Strategy	N° of events in the study area	N° of events analyzed	Period of study	Rain amount (mm)	Overflow discharged volume (m ³)	Reference
Lodz, Poland	Sewer flowmeters located in the cathment	9 – 28/year	60	3 years		3.600- 49.822/year	Brzezińska, 2016
Po Valley, Italy	the CSO outfalls are located within the lifting pump stations	-	41	3 months (2014)	740/year	18-30383/event	Al Aukidy and Verlicchi, 2017
Gallusquelle, Germany	-	10/year	5	5 months (2005)	-	23.000 (5 events)	Heinz et al., 2009
Québec, Canada	Overflow markers, continuous data recorders and automatic data recorders	160/year (from 2009-2012)	-	-	-	-	Jalliffier-Verne et al., 2015
Stuttgart, Germany	Flowmeter	-	7	3 months (2014)	-	-	Launay et al., 2016
Québec, Canada	-	2258 (from 2009-2011)	5	-	625/year	92-19.530 (5 events)	Madoux-Humery et al., 2016
Vermont, USA	-	37 (from December 2007-November 2008)	-	1 year (2007-2008)	20-410/day	-	Phillips et al., 2012
Spain	-	-	46	-	-	2752-41.566/event	Suarez and Puertas, 2005
Berlin, Germany	179 CSO discharge points	37/year (from 2000-2007)	-	-	-	7x10 ⁶ /year	Weyrauch et al., 2010
La Garriga, Spain	14 CSO infrastructure with low-cost temperature sensors	36-49 (in 11 month)	-	1 year (2011-2012)	0.4-51.4/episode	-	Montserrat et al., 2015
Paris, France	Dry weather: daily	-	-	-	20.1/rainfall event	3.2x10 ⁶ /year	Gasperi et al.,

	samples for the 4 upstream sites. Wet weather: 4 of the 45 CSO sampled						2008
The Aire and Calder catchments, West Yorkshire, UK	Samples from WWTP, CSO and receiving water	-	5	-	-	-	Kay et al., 2017
City of Santiago de Compostela, Spain	-	-	925	4 years (1995-1999)	1600/year	-	Diaz-Fierros et al., 2002
Gorla Maggiore, Italy	69 CSO events	69 CSO events	69	1 year (2014-2015)	-	87-579/event	Masi et al., 2017

178 **Table 2.** The characteristics of combined sewer overflows

Study site	Monitoring strategy	TSS (mg/L)	BOD ₅ (mg/L)	COD (mg/L)	TN (mg/L)	N-NH ₄ (mg/L)	TP (mg/L)	Reference
Slovakia	8 CSO stations	430	175	445	16.8	6.21	2.63	Sztruhár et al., 2002
Gorla Maggiore, Italy	68 CSO events	-	-	176-612	-	3.8-28	-	Masi et al., 2017
Boudonville retention basin, Nancy, France	During rain events, CSO samples every 5-10 min	182.29-869.6	-	-	-	-	-	Samrani et al., 2008
Paris, France	Dry weather: daily samples for the 4 upstream sites. Wet weather: 4 of the 45 CSO sampled	150-700	-	-	-	-	-	Gasperi et al., 2008
Paris, France	4 CSO stations	135-353	36-180	136-446	-	3.3-9.3	1.2-5.4	Gasperi et al., 2012
General characteristics	-	270-550	60-220	260-480	-	-	-	Metcalf and Eddy, 1991
Harlem River, Bronx side, New York, The USA	50 CSO stations	-	-	-	-	1.3-2.7	0.5-3	Wang, 2014
North-Rhine Westphalia, Germany	>20 retention soil filters for CSO treatment	1-1123	-	15-918	-	-	0.1-16.1	Tondera, 2017
Shanghai, China (combined)	-	91-529	111-178	243-484	-	7.6-17.2	-	Li et al., 2010
Germany	-	174.5	60	141	12.6	1.94	1.25	Brombach et al., 2005
Two cities in Korea	from June 1995 to November 1997	99.0-215.7	33.7-81.5	118.5-223.5	-	-	-	Lee & Bang, 2000
	-	1-4420	3.9-696	-	-	-	0.1-20.8	EPA, 2004
The United States	-	237-635	43-95	120-560	2.9-4.8	-	-	Ellis and Jenkins, 2005
Canada	-	190	-	-	8.3	-	1.4	Ellis and Jenkins, 2005
United Kingdom	-	425	90	260-507	8.3	-	10	Ellis and Jenkins, 2005
Europe	-	105-721	39.9-200	148-530	2.1-14.4	-	2.4-4.0	Ellis and Jenkins, 2005

Santiago de Compostela, Spain	Monitoring over a 40-month period	160-411	70.5- 171	134- 540	-	5.2- 12.8	0.5-4.6	Diaz-Fierros et al., 2002
Louisville, Atlanta	-	14-227	-	40-107	-	-	-	Arnone and Walling, 2006

179

180 **3. Water quality impacts of CSO discharges**

181 The pollutants released with CSO discharges can have detrimental impacts on aquatic
182 environments and public health. The pollutants in the untreated wastewater can increase the
183 organic content of receiving water bodies and oxygen depletion occurs with biodegradation,
184 promoting eutrophication. In a comprehensive study carried out by Viviano et al. (2017), it was
185 reported that more than 50% of the total phosphorous loads in the Lambro River resulted from
186 CSO discharges during heavy rain events. Thermal pollution may also occur where the
187 temperature of the CSO is different to the receiving water. Moreover, as a consequence of
188 increased turbidity, photosynthesis is inhibited/reduced (Riechel et al., 2016). In warm seasons,
189 low flows can limit dilution effects and, therefore, increase the problem (Montserrat, Gutierrez,
190 Poch, & Corominas, 2013). On the other hand, the concentrations of wastewater contaminants
191 such as total solids, COD, TKN, and P_{tot} can decrease due to the dilution caused by high
192 precipitation. The study carried out by Gasperi, et al. (2012) showed that the parameters can be
193 decreased almost one-third of the dry season (Table 2). On the other hand, a high variation
194 between maximum and minimum values for the parameters were determined in various studies
195 (El Samrani, Lartiges, & Villi eras, 2008; Li, Tan, & Zhu, 2010; Tondera, 2017; U.S.EPA, 2004)
196 and the highest values were reported by EPA (2004) in which TSS, BOD_5 , and TP were
197 determined as 4420 mg/L, 696 mg/L, and 20.8 mg/L. The variation could be attributed to the
198 precipitation volume, duration, location, etc. and confirmed the high stochastic nature of CSO
199 events Masi et al. (2017).

200 Emerging contaminants, such as pharmaceuticals, hormones and substances from personal care
201 products, can be introduced into aquatic environments via CSO discharges (Del R o et al., 2013;
202 Montserrat et al., 2013; Passerat et al., 2011)). These contaminants may also be mobilized from

203 sediments during storm events and end up in the water (Del Río et al., 2013). The runoff from
204 urban surfaces transports additional loads of heavy metals, polycyclic aromatic hydrocarbons and
205 a variety of other micropollutants such as pesticides (Gasperi et al., 2014; Phillips & Chalmers,
206 2009). Metals contamination is another important issue in CSO discharges, which can accumulate
207 in the sediment and affect the aquatic ecosystem, for example by inhibiting reproduction in
208 sensitive macroinvertebrates (Schertzing, Ruchter, & Sures, 2018). A correlation between
209 metals concentration in the sediment and the number of CSOs were determined by Hnat'uková
210 (2011).

211 Recent studies revealed that, even though CSO discharges represent only a small proportion of
212 the total annual wastewater discharge, these overflows contribute to 30-95% of the annual load
213 for different pollutants including caffeine, ibuprofen, polycyclic aromatic hydrocarbons (PAHs),
214 phenolic xenoestrogens, hormones, and urban pesticides (Launay et al., 2016; J. P. Phillips et al.,
215 2012). Furthermore, Phillips et al. (2012) stated that micropollutant concentrations could be up to
216 10 times higher in CSO discharges than that of the treated wastewater. Despite the short duration
217 of CSO discharges, they introduce, high loads of micropollutants into waterbodies (Musolff et
218 al., 2009). Moreover, the concentrations of PAHs in CSO discharges were found 2000 times
219 greater than Environmental Quality Standards (Birch, Mikkelsen, Jensen, & Holten Lützhøft,
220 2011). Gasperi, et al. (2012) evaluated the concentrations of priority pollutants as well as
221 wastewater quality parameters for CSO discharges, wastewater, and storm runoff. Whereas
222 runoff is the major source for pesticides and dissolved metals (e.g. Zn) in CSO discharges,
223 wastewater is the main contributor to volatile organic compounds. On the other hand,
224 hydrophobic organic pollutants (e.g. PAHs, APnEOs) and particulate-bound metals (e.g. Pb and
225 Cu) are mostly caused by in-sewer deposit erosion in the CSO discharges. Although wastewater

226 effluents and CSO discharges are the main contributors for endocrine-disrupting compounds and
227 personal care products in receiving water bodies, the concentrations depend on the removal rates
228 in wastewater treatment plants, stormwater dilution factor, and the quantity of wastewater
229 bypassed the treatment plant (Ryu, Oh, Snyder, & Yoon, 2014). Studies suggest some substances
230 suitable as markers for CSOs, especially those which are biologically degraded in WWTPs or are
231 specific to stormwater runoff. In combined sewer networks, caffeine can be proposed as a tracer
232 for CSO discharges (Buerge et al., (2006). Similarly, Fono and Sedlak (2005) introduced
233 propranolol, a pharmaceutical component, as a tracer for anthropogenic discharges.

234 CSO discharges introduce infectious pathogens originating from human faces and organic waste
235 in the sewage, as well as from animal feces in run-off originating from wildlife (e.g. birds) or
236 domestic animals (especially dogs) (Schaes et al., 2005). They can contain antibiotic resistant
237 bacteria (Young, Juhl, & O'Mullan, 2013).

238 Monitoring programs usually focus on indicator organisms, such as *E. coli* and intestinal
239 enterococci, which are e.g. relevant for the EU Bathing Water Directive, or thermo-tolerant
240 coliforms (WHO, 2008). They are chosen to indicate specific pollution, e.g. by fecal
241 contamination. Ideally, this should enable one to conclude that a health risk is present. Some
242 studies have investigated and detected further bacterial pathogens such as *Campylobacter*,
243 *Salmonella*, *Aeromonas spp.*, *P. aeruginosa*; enteric viruses such as Adenovirus and Norovirus,
244 and human polyomavirus as well as protozoan parasites such as *Giardia lamblia* and
245 *Cryptosporidium* (Christoffels, Mertens, Kistemann, & Schreiber, 2014; McGinnis et al., 2018;
246 Tondera et al., 2015).

247 Direct measurements in CSO discharges regarding *E. coli* concentrations are rare; more often,
248 polluted river water after overflow events is sampled instead. In the few published investigations

249 with direct measurements, the median concentrations of *E. coli* at the outlet of overflow or CSO
250 retention tanks range from 10^4 to 10^6 MPN or CFU/100 mL (Stott, Tondera, Blecken, &
251 Schreiber, 2018).

252 If surface waters are used for recreational purposes, these microbial contamination result in risks
253 of infections with gastrointestinal illnesses, pneumonia, bronchitis, and respiratory infections
254 (U.S.EPA, 2004). McBride et al. (2013) revealed that the highest risks for swimmers derive from
255 noro- and rotaviruses in such contaminated waters. Pond (2005) gives a detailed overview on
256 infections and sequelae caused by these pathogens, some of which are chronic. The author
257 associates the discharge of CSOs with these diseases and recommends closing recreational areas
258 after heavy storm events and sewage treatment in general as a management strategy against
259 possible infections. Accordingly, Tondera et al. (2016b) modelled the overall impact of CSO
260 discharges on microbial contaminations in the Ruhr River relative to other sources, e.g. from
261 WWTP effluent or diffuse pollution. The authors showed that in the river, which passes through a
262 densely populated area in Germany, CSO discharges had the highest impact on elevated
263 microbial concentrations up to two days after rainfall events. Moreover, Jalliffier-Verne et al.
264 (2016) stated that high *E.coli* concentrations at raw water collection points for drinking water
265 production correlate with the discharged concentrations from CSOs, the location of overflows,
266 dispersion processes in the surface waterbody, and the season. In a study carried out by Riechel et
267 al. (2019), the authors used a tracer approach using wastewater volume as a proxy for pathogen
268 emissions to assess the relationship between different CSO outlets and bathing water quality for
269 Berlin, Germany. According to their results, wastewater including only 5% of the CSO volume
270 contributes >99% of the pathogen loadings to the receiving environment. Wastewater volume
271 was also of relevance for determination of point sources for the hygienic impairment of the
272 receiving environment. In another study by the same group (Seis, Zamzow, Caradot, & Rouault,

273 2018), they proposed a methodology which demonstrated the shortcomings of current long-term
274 classification as well as the potential for improvement by applying the proposed approach
275 regarding to the microbial safety. However, USEPA’s BEACH Program conducted an annual
276 survey of the nation’s swimming beaches. During the 2002 swimming season, CSOs and SSOs
277 were responsible for only 1 and 6 percent, respectively, of reported advisories and closings
278 (USEPA, 2004). Therefore, results are controversial and call for proper smart monitoring and
279 case-by-case analyses.

280 **4. Policy, legislation, governance and regulation to address the challenges**

281 The necessity of controlling CSO pollution under the urban wastewater treatment directive
282 (UWWTD; OJEC 1991) and water framework directive (WFD; OJEC 2000) was stated by the
283 European Union. Discharges of CSOs may affect the achievement of “good status” of
284 waterbodies as required by the European Water Framework Directive. The scientific community
285 and the water sector operators are raising awareness of the environmental problems relating to
286 CSOs and are promoting initiatives for reduce their impact and improving the quality of surface
287 water (EurEau, 2016).

288 Since 1998, there have been significant changes in legislation with the implementation of the
289 water directives; and water quality and ecological standards have been revised. New issues have
290 arisen with an urgent need of adaptation and mitigation measures in the upgrading of urban
291 drainage systems. In the European legislation relating to CSOs, it is possible to distinguish
292 between Directives aimed at protecting receiving waters and Directives to control CSO
293 discharges (Morgan, Xiao, & McNabola, 2017). The Urban Waste Water Treatment Directive
294 91/271/EEC (UWWTD) highlights that the collecting systems shall be constructed and managed
295 in accordance with limiting the quantity of pollution entering receiving waters due to storm water

296 overflows. In addition, the UWWTD requires reporting of wastewater sewerage treatment
297 performance and a system of pre-authorization for all wastewater discharges, including CSOs.
298 The ongoing evaluation of the UWWTD has highlighted the importance of better managing
299 CSOs. The Bathing Water Directive 2006/7/EC (BWD) and the Habitats Directive 92/43/EEC are
300 limited to assess the bathing waters affected by CSOs as “subject to short-term pollution”. In the
301 EU Regulation No. 166/2006 (2006) “concerning the establishment of a European Pollutant
302 Release and Transfer Register”, EU member states are obligated to report pollutant loads,
303 specified in Annex II, to water. The threshold values are also specified in this regulation. Thus,
304 the pollutant loads from CSO discharges should also be estimated. However, this is very
305 challenging since CSO structures are not designed for monitoring purposes.

306 CSO discharges have been identified as an important problem for European countries. Germany,
307 UK and other countries have started to establish CSO policies and actions before Water
308 Framework Directive (Malgat, 2013). Sixteen EU member states have national standards that
309 regulate storm water overflows, eleven of them have guidance documents that directly address
310 storm water overflows (EurEau, 2016). Common approaches in standards and guidance are:

- 311 - Limit on the number of overflows (e.g. Belgium, Poland, Portugal);
- 312 - Requirements for dilution (e.g. Bulgaria, Czech Republic, Estonia);
- 313 - Other approaches seen: max total volume, or max number of days of overflows (e.g.
314 Germany).

315 The permitted number of overflows per year proposed by CSO regulation guidelines differs
316 according to each member country and ranges from 2-3 in Denmark and the Netherlands, 15-20
317 in the Galician region in Spain (Table 3, Montserrat et al., 2015) and 10 in Poland (Brzezińska et
318 al., 2016).

Table 3. Regulations issued CSOs

Country	Regulation/Legislation/Guideline	Issue
Italy	Regulation Number 917/2017	Number of overflows per year
Denmark	Danish Nature Agency, 2011:55	Number of overflows per year (2-3)
Netherlands		Number of overflows per year (2-3)
Spain	Royal Order RD 1290/2012	Number of overflows per year (15-20)
UK	The Urban Wastewater Treatment Regulations 1994, Regulation 6 (2)	Number of overflows per year (15-20)
Canada	MDDELCC, 2014	New developments will not result increase in the frequency of overflows
Japan	Enforcement Ordinance of Sewerage Law (2003)	BOD ₅ parameter
Australia	Environment Protection Authority, a Code of practice	Implementation of overflow abatement program
France	Local Authorities General Code 2015 Order	Monitoring must be ensured by the operator, municipality and the different water policy services

320 In the UK the requirements for solids separation depend on the number of overflows per year.

321 The Urban Wastewater Treatment Regulation (6 (2), 1994), states that primary treatment must be
322 provided within CSO structures, in which the biological oxygen demand, determined over 5 days,
323 (BOD₅) of the incoming wastewater is reduced by at least 20% before discharge and the total
324 suspended solids reduced by at least 50% (Morris, 1999). The third periodic Asset Management
325 Plan review (AMP3: 2000–2005) specified a timetable for water companies to reduce the number
326 of unsatisfactory intermittent discharges caused by CSOs (McSweeney et al., 2009). In 2012, a
327 comprehensive framework for CSO improvement has been developed through the urban pollution
328 management program to assess the impact of CSO discharges on receiving water quality and to
329 develop water quality standards for the protection of aquatic life from intermittent pollution
330 caused by CSO discharges (Morgan et al., 2017). These criteria also form the basis of CSO
331 assessment in Ireland, as set out in the Procedures and Criteria in relation to Storm Water
332 Overflows. On the other hand, in Italy, a list of performance indicators to describe the technical
333 quality of the water utility management and operation were introduced in 2017 by the Italian

334 Regulatory Authority for Energy, Networks and Environment (Regulation Number 917/2017).
335 The section dedicated to the sewer system includes two restrictions; firstly, the adequacy of the
336 CSO stations and secondly, the number of overflows allowed in one year in each 100 km of
337 sewage system. Moreover, in Spain, the Royal Order RD 1290/2012 requires that all CSO
338 discharging points for places exceeding 2000 equivalent inhabitants be defined (Montserrat et al.,
339 2013). In France, it is just stated that CSOs spillages must not exceed 2% of the total average
340 annual volume for 5 years (Tabuchi, 2013) and according to the “Local Authorities General Code
341 2015 Order” monitoring must be ensured by the operator, municipality and the different water
342 policy services. However, in Germany, several guideline describe the design and construction of
343 CSO retention tanks at points with critical discharge (ATV-128, 1992; DWA, 2013b, 2013a).
344 Capacities depend on factors like the catchment area, population density, historical rainfall
345 patterns and the proportion of impervious surface areas. The percentage of wastewater in a
346 catchment that can be discharged via overflows is based on ten-year rainfall patterns and
347 determined by the sensitivity of the receiving waterbody. In 1994, the United States
348 Environmental Protection Agency issued the combined sewer overflow control policy in the
349 National Pollutant Discharge Elimination System program (NPDES). Within the scope of the
350 policy, site-specific permits were developed for all CSS considering cost/performance in relation
351 to the size of the individual systems. Additionally, a list of nine minimum measures were
352 determined for CSOs in order to develop and adopt long term control plans (U.S. EPA, 2001;
353 U.S.EPA, 2004). They include programs for control measures during installation and pollution
354 prevention, pre-treatment applications, maximization of the storage in collection system and flow
355 directed to the WWTP, monitoring, as well as public communication. In Canada, although there is
356 no federal legislation for CSOs control, some provinces, like Quebec, adopted specific rules to
357 restrict CSOs (MDDELCC, 2014). To be in accordance with the Strategy for the Management of

358 Municipal Wastewater Effluent, municipalities and developers have to demonstrate that new
359 developments will not result in an increase in the frequency of CSO (Mailhot, Talbot, &
360 Lavallée, 2015). According to the Canada-wide Strategy for the Management of Municipal
361 Wastewater Effluent, CSO discharges are not entirely prohibited, but are allowed in exceptional
362 circumstances, such as during snow-melt in spring time (Jalliffier-Verne et al., 2016). Differently,
363 in Japan, in 2003, an amendment of “Enforcement Ordinance of Sewerage Law” related to CSO
364 discharges abatement was issued defining the BOD₅ concentration in the effluent overflow (< 40
365 mg/L), allowing a provisional limit of 70 mg/L applicable until structure standards start to be
366 applied. Small and midsize municipalities were obligated to implement improvements by 2013,
367 large municipalities by 2023. Environment Protection Authority of South Australia issued a code
368 of practice for wastewater overflow management giving a roadmap to the operators to comply
369 with their environmental obligations. The water utility is obligated to implement an overflow
370 abatement program, which encompasses an emergency response plan and short- and long-term
371 measures to prevent or reduce the re-occurrence of overflows. However, in South Africa the
372 policy related to runoff water disposal asserts that: “Urban stormwater discharged to the marine
373 environment should not have any negative impact on the Environmental Quality Objectives of the
374 receiving environment”, it does not provide specification on treatment-at-source or land-based
375 treatment, which are considered specific to disposal of stormwater runoff.

376 Overall, different directives have been developed worldwide, which are mainly focused on the
377 affirmation of the negative effects of the CSO events and allowed a number of overflows per year.
378 Generally, the policymakers are revising and deriving the regulations to enforce authorities to take
379 pre-cautions and control CSO discharges. Although they pointed out the adverse impacts, in many
380 countries no specific limits for water parameters have not been set to limit pollution from CSO

381 discharges. This aspect is mainly related to the great variability in terms of quality and quantity of
 382 CSO characterization in the different sewer systems, previously described in the Section 3.
 383 Moreover, wide sampling campaigns and monitoring methods have to be implemented in order to
 384 quantify the hydraulic and the characterization conditions to support the legislation improvements.
 385 Finally, specific treatment technologies and control measures can be integrated into the regulations.

386 **5. Innovative methods for CSO determination**

387 Hydraulic conditions are the main factor to determine the proper method for monitoring CSOs.

388 Table 4 displays various methods used to estimate CSO volumes.

389 **Table 4.** CSOs measurement methods (adopted from Maté Marín et al., 2018).

Position	Technique	Features	Main drawbacks
Overflow channel	Stage-discharge relation methods	Pre-designed device	Need for specific hydraulic conditions
	Stage-discharge relation methods	On-site calibration	Site-dependent
	Velocity based methods	-	Representativeness
Main channel (upstream & downstream from the CSO)	Stage-discharge relation methods	Pre-designed device	Need for specific hydraulic conditions
	Stage-discharge relation methods	On-site calibration	Site-dependent
	Velocity based methods	-	Representativeness
	-	-	Double equipment
	-	-	Indirect measurement
CSO chamber	Stage-discharge relation methods	Classical geometry	Need for specific hydraulic conditions
	Stage-discharge relation methods	On-site calibration	Site-dependent

390 Sensors and probes are also applied for monitoring purposes in most of the high income
 391 countries, such as conductivity meters to detect occurrence and determine duration, level sensors
 392 with moderate and/or higher cost, advanced sensors (eg UV-VIS) for also determining water
 393 quality. Where budget is limited, level sensors can be coupled with overflow equations to
 394 measure CSO volume. On the other hand, a level and a velocity sensor combined with

395 flowmeters generate the most accurate/reliable data but require more investment cost and higher
396 maintenance (Montserrat et al., 2013).

397 The costs of data storage and high capacity computer systems are still an issue in CSO
398 monitoring. Moreover, in heavy rain events, huge quantities of data must be processed and
399 evaluated for every alarm situation in order to take immediate action (Bailey et al., 2016). The
400 other point is the location of the CSO control system. The characteristics of the land can make the
401 connection to the network difficult.

402 A low-cost method was introduced by Montserrat et al. (2013) to detect the occurrence and
403 duration of CSO events. The proposed method depends on the temperature changes between the
404 sewer gas phase and the overflowing mixture of wastewater and storm water. Using temperature
405 sensors for CSO detection has several advantages such as minimum capital cost, easy installation,
406 requirement of minimum technical knowledge for integration, tolerance to extreme
407 environmental conditions and minimum maintenance. The authors also validated their systems
408 and achieved detection greater than 80% of the total CSO occurrences, which showed that
409 temperature differentiation during seasonal changes does not have a negative impact on
410 effectiveness. However, physical features of the weir affect the detection performance. Later
411 research, published in 2018, increased the robustness of the method proposed in Montserrat et al.
412 (2013) by adding a second temperature sensor, improving the detection accuracy by
413 implementing an algorithm that accounted for the response time of the system and automatically
414 calculated the duration of CSO events (Hofer et al., 2018). As a result, in a 7-month test phase, all
415 20 CSO events were recognised without false detections.

416 Another group from France, recently developed a system called the DSM-flux (Device for Storm
417 water and combined sewer flows Monitoring and the control of pollutant fluxes) to determine and

418 control both the quantity and quality of CSO discharges (Maté Marín et al., 2018). The validated
419 system can measure overflow volumes and pollutant concentration, decrease particulate
420 pollutants from sedimentation and the erosive potential of overflows to the receiving waters. The
421 advantages of installation of the DSM-flux system are: - direct measurement at the overflow
422 channel, - installation downstream from the existing CSO structure, -requirement of only one
423 level measurement for determination of discharge values, - not affected by inlet hydraulic
424 conditions, - reduced particulate pollutants and erosive potential of CSO discharges.

425 ***5.1. Smart CSO monitoring and control***

426 Currently smart network monitoring and smart data infrastructures (US EPA, 2018) are under
427 development and application. These infrastructures are implemented in connection with a
428 supervisory control and data acquisition (SCADA) system and are mainly focused on real-time
429 monitoring of flow rates (physically or with alternative methods) and effluent levels of CSO's
430 with the aim of assessing potential flooding and pollution incidents. The final objective is to
431 support decisions in real-time or quasi real-time about actions to be taken. For instance, SPRINT
432 226 a European project focused on the implementation of real-time sewer system control for
433 eight European cities: Copenhagen (Denmark), Mantova (Italy), Verona (Italy), Genoa(Italy),
434 Berlin (Germany), Vitoria-Gasteiz (Spain), Bolton (United Kingdom), and Goteborg (Sweden)
435 (Entem, Lahoud, Yde, & Bendsen, 1998). The project showed decent real-time control
436 performance for overflow events of the sewer system in terms of prediction and generation of
437 strategies to be taken into consideration (Entem et al., 1998). Another study (Seggelke et al.,
438 2013) focused on real-time control of a CSS in a city in Germany with the aim of monitoring
439 frequency of overflow events and investigating how to reduce them. In addition, Carbone et al.,
440 2014 investigated a real-time control solution for an urban drainage network in Italy. It used an

441 innovative and smart series of gates that automatically adjusted themselves in order to optimize
442 the storage capacity of a sewer system during rainfall events. Moreover, in the INTCATCH
443 project, as an innovative approach to monitor water quality, autonomous and radio controlled
444 boats are developed and demonstrated in key catchments such as Lake Garda, Lake Yliki
445 (Warner, Nödler, Farinelli, Blum, & Licha, 2018). The results revealed that monitoring the
446 routine parameters can give an overview of the current status of the water body, as well as
447 contribute to reducing the monitoring cost. Moreover, real-time monitoring of site-specific
448 indicator allows determining the pollutant source which helps to derive proper catchment
449 management strategy (Warner et al., 2018). The applications of smart data infrastructure systems can be
450 optimized by two different methods. Whereas the system improvements refer to increasing weirs, optimizing the
451 efficiency curves or location of CSO control, the real-time control systems manage the operation of wastewater
452 networks and facilities in real time (US EPA, 2018). Grey (such as large concrete tanks or tunnels)
453 and green strategies (such as bioretention facilities, green roofs, porous pavements, and
454 stormwater planters) can be applied to control CSOs (De Sousa, Montalto, & Spatari, 2012) and
455 hybrid system of grey and green methods more advantageous than grey method-only in terms of
456 economy, environment and society (Gong et al., 2019). The control strategies can be optimized
457 by hydrological model simulations supported with scenario analyses (Chen et al., 2019). In the
458 USA, different approaches are integrated in different states to control and manage CSOs. In
459 Philadelphia, the Water Department has a goal to reduce overflows (7.9 billion gallons of
460 overflow water) by 2036. For this purpose, smart data technology was integrated into existing
461 stormwater retention basins to monitor basin water level and precipitation, and maximize the
462 performance of the basin by real-time active control to selectively discharge from the basin
463 during optimal times. On the other hand, 10 high frequency cleanout sites with remote field
464 monitoring units were integrated in the San Antonio Water System (SAWS) in which day-to-day

465 level trend changes can be detected by an analytical software giving data for potentially
466 important changes in water levels. In the pilot locations, there were no sewer overflows in
467 May/June 2016 with when nearly 16 inches of rain overwhelmed the SAWS. The real-time
468 control system was adopted in Louisville in 1990s and actively used since 2006. The system
469 prevents more than 1 billion gallons of CSO volume annually. In Indiana, there are 152 sensors
470 located through the city of South Bend to maximize the capacity and performance of the city's
471 collection system, which helped to reduce total CSO volume by roughly 70 percent, or about 1
472 billion gallons per year during the period 2008-2014. Moreover, in Greater Cincinnati, there are
473 more than 200 CSO points, causing a discharge over 11 billion gallons of sewage into the Ohio
474 River and its tributaries annually. 164 overflow points were integrated within the frame of the
475 smart sewers network to date and sensors were installed through the watershed (USEPA, 2018).
476 The monitoring technology should be pursued in the catchment base, and economical analysis
477 should be carefully proceed to decide to integrate the best smart strategy.

478 ***5.2. Innovative treatment alternatives***

479 Different strategies are developed to reduce the impacts of CSOs, such as increasing storage
480 capacity, detention/retention facilities, as well as sewer separation to fulfill the requirements of
481 the related regulations (Figure 2). However, converting CSS into a separated system can be
482 prohibitive due to cost and it does not always guarantee pollution reduction (Li et al., 2010). One
483 of the many goals of this review is to gather the latest information on treatment technologies,
484 grouped as natural and technological treatment, and their performances in treating CSOs.
485 Treatment alternatives are summarized in Table 5.

Table 5. Studies with different treatment alternatives for CSOs

Treatment	Location	System	Purpose	Target	Reference
Natural Treatment	Gorla Maggiore, Italy	Vertical flow subsurface beds (VF) as first stage and a free water surface bed (FWS) as second stage	Flow reduction	Flow reduction: 86.2%	Rizzo et al. (2018)
	Germany	Retention soil filters (RSFs)	CPOD, TSS and P	COD removal: 49% TSS removal: 38% Phosphorous removal: 34%	Tondera et al. (2017)
	Gorla Maggiore, Italy	Vertical flow subsurface beds (VF) as first stage and a free water surface bed (FWS) as second stage	COD and NH ₄ ⁺	COD removal: 87% NH ₄ ⁺ removal: 94%	Masi et al. (2017)
	Tettngang, Germany	RSFs	Micropollutants and pathogenic/antibiotic resistant bacteria	COD removal: 80 ± 10% E. coli removal: 2.7 log-units Enterococci removal: 2.2 log-units	Scheurer et al. (2015)
	Carrión de los Céspedes, Spain	Vertical flow CW + horizontal flow CW + Free water surface CW	TSS and disinfection	TSS removal: 90 ± 8% disinfection efficiency :4.7 logarithmic units CFU/100 mL for E. coli	Ávila et al. (2013)
	Pilot –scale experiment	Activated soil filter	Biocides and biocide metabolites removal	Dry weather conditions: Removal rates: 80-100% High flow conditions: Triazines: 50-70% Phebylureas: 16-100% DCOIT: 99-100% BIT: 72-96% IPBC: 43%	(Bester et al., 2011)
	Pilot–scale experiment	Activated soil filter	Organic micro-pollutant removal	Lipophilic compounds removal: 64-99% Persistent hydrophilic compounds removal: 0-95% depending on the	(Bester & Schäfer, 2009)

		operation period			
Technological treatment	Boudonville, France	Coagulation with ferric chloride solution (CLARFER), aluminum salts (WAC HB)	TSS and heavy metals	Turbidity removal: >86%	El Samrani et al. (2008)
	Seine Aval plant, France	Ballasted flocculation unit	TSS, POC, COD, P	TSS removal: 86.7% -80.2% POC removal: 84.8% -77.5% COD removal: 75.2% -76.8% P _{tot} removal: 86.4% - 88.4% Hydrophilic compound removal: 20% - 50%	Gasperi et al. (2012)
	Germany	Adsorption: Biochar	Specific pollutants	Acetaminophen removal: 94.1% Naproxen removal: 97.7 %	Jung et al. (2015)
	Simulated CSO with real wastewater	Activated soil filter (Bio filter)	TOC and micro pollutants	Hydrophilic markers: 81-98% Lipophilic markers: 30-99% TCPP: 64% TOC removal: >50%	Bester and Schäfer (2009)
	Kærby, Denmark	PAX dosing point before the HydroSeparator followed by a dosing point for PAA + CW	TSS, P, disinfection	Turbidity removal: 89.8% Phosphate removal: 26.6% Enterococcus removal: 1.3-3.5 log	Chhetri et al. (2016)
	Synthetic CSO	The adsorption and photo-reduction-a composite catalyst of TiO ₂ and Graphene	Zn ²⁺	Zn ²⁺ removal: 20.3 ± 0.04% increase	Kumordzi et al. (2016)
	North Rhine-Westphalia, Germany	Performic acid	Disinfection	<i>Aeromonas</i> spp. reduction: 1.8 log <i>E. coli</i> . reduction: 3.1 log Somatic coliphages reduction: 2.7 log	Tondera et al. (2016)
	Synthetic sanitary sewer overflow	Biofilter	BOD ₅ and TSS	BOD ₅ removal: 84 ± 9% TSS removal: >90%	Tao et al. (2010)
	Synthetic CSO	Disinfection by PFA and acid PAA	Disinfection	<i>E.coli</i> reduction: ~3 log units <i>Enterococcus</i> reduction: ~3 log	Chhetri et al. (2014)
	Synthetic CSO	Disinfection by PAA	Disinfection	Full disinfection at pH 8.5	McFadden et al.

	and hypochlorite			(2017)
Ruhr, Germany, simulated CSO	UV disinfection and ozonation	Disinfection	<i>E.coli</i> reduction: 2.2-3.5 log Coliform bacteria reduction: 1.7-3.3 log	Tondera et al. (2015)
	UV disinfection with coagulation	UV transmission	Increase on UVT: 78%	Gibson et al. (2016)
Lake Garda, Italy	A dynamic rotating belt filter, adsorption on granular activated carbon and UV disinfection	TSS, COD and <i>E. coli</i> removal	TSS removal: >90% COD removal: >69% <i>E. coli</i> removal: >99%	Botturi et al. (2020)

488 *5.2.1. Natural extensive treatment*

489 Green infrastructure and nature-based solutions (NBS) use natural processes to contribute to the
490 improved, sustainable management of water as well as enhancing natural capital and biodiversity.
491 Green infrastructure is recognized to deliver multiple benefits by combining continuous treatment
492 of CSOs with additional services in terms of flood protection, increased biodiversity, climate
493 change resilience and recreational activities.

494 There is growing recognition that green infrastructure are flexible, multi-purpose alternatives to
495 traditional, often costlier treatment solutions that can be applied in diverse wastewaters
496 (Vymazal, 2011) including treatment of residential, municipal and agricultural storm water and
497 wastewater and urban run-off. They are incorporated into and promoted in Europe by the
498 European Commission Strategy on Green Infrastructure (EC, 2013) and in the UK; an example is
499 the London Environment Strategy (GLA, 2018). Green infrastructure is therefore an increasingly
500 important possible solution for pollution mitigation. As well as being an environmentally friendly
501 alternative, green infrastructure are flexible in terms of size, cost-effective and have a discrete
502 layout (Fu, Goddard, Wang, & Hopton, 2019). Of the green infrastructure techniques, constructed
503 wetlands (CW) have a long history of wastewater treatment and have many applications for CSO
504 treatment (Levy, Smardon, Bays, & Meyer, 2014; Masi et al., 2017; Pálffy et al., 2018, 2016;
505 Rouff, Eaton, & Lanzirotti, 2013; Tondera, 2017). The largest number of constructed wetlands
506 for combined sewer overflow treatment (CSO-CW) exist in Germany, where the first large-scale
507 treatment plants were implemented in the early 1990. In North-Rhine Westphalia alone, a state
508 with approx. 18 million inhabitants, more than 150 facilities exist with a treatment capacity of
509 100 to 36,000 m³ (site currently under construction) per rainfall event. The newly released
510 national guideline (DWA, 2019) describes design, construction and maintenance of the system. In

511 principal, pre-settled combined sewage is distributed on a vegetated filter body with a sand layer
512 of 0.75 cm. A ponding zone allows temporary storage of up to 2 m³ per m² water and the outflow
513 is throttled and ideally does not open before full saturation of the filter body has been reached.
514 The filter material consists of engineered media ('technical sand', 0/2 mm). The required capacity
515 is based on ten-year rainfall simulations and the sensitivity of the surface waterbody.
516 Investigations of these systems, especially in the last 15 years, show a total suspended solid
517 (TSS) removal of >90%, chemical oxygen demand (COD) removal of >80%, a high nitrification
518 potential (ammonium removal of >60% depending on inflow concentrations and preceding dry
519 period), bacterial removal of 1 to 3 log₁₀, but also removal of certain micropollutants
520 (Christoffels et al., 2014; Scheurer et al., 2015; Tondera, 2017; Tondera et al., 2013; Tondera,
521 Ruppelt, Pinnekamp, Kistemann, & Schreiber, 2019). Phosphate and heavy metals can be
522 reduced until the overall sorption capacity of the filter body has been reached; an increase is
523 possible by adding adsorptive materials or implementing post-filter steps.
524 The layout has been adapted in research projects in France and Italy (Meyer et al., 2013). Masi et
525 al. (2017) describes the Italian approach implemented at Gorla Maggiore (Table 5). The system
526 was designed to treat the first flush of the overflow via vertical-flow wetlands, whereas the later
527 occurring, higher diluted overflow is bypassed into a free water surface wetland. During the study
528 period, 69 CSO events happened and the system successfully reduced the COD concentration by
529 87% and NH₄ concentration by 93%. As additional benefit, the construction mitigates flood risk.
530 Rizzo et al. (2018) describes the Italian approach and shows that the system reduced the effects of
531 CSOs in the river by smoothing peak loads and contributing to improved water quality.
532 Similarly, Ávila et al. (2013) demonstrated the function of a pilot-scale treatment system
533 consisting of a vertical subsurface flow, a horizontal subsurface flow and a free water surface
534 constructed wetland for the treatment of effluent from a combined sewer and results showed

535 efficient performance in terms of organic carbon and TSS removal under dry weather conditions.
536 As expected, during the storm events there were a prompt increase in carbon and TSS load for a
537 short period followed by a dilution effect.

538 *5.2.2. Technological compact treatment*

539 Minimizing the negative impact of CSOs in the receiving waters can be achieved by in-line
540 treatment methods such as settling without additives, which is the most commonly applied
541 method, and chemical coagulation before discharge. Coagulation and flocculation are an effective
542 method to remove organic materials with organic/inorganic polymers as coagulants and
543 flocculants to get better sedimentation. In a study carried out by El Samrani et al. (2008), effects
544 of different commercial coagulants - namely, ferric chloride solution (CLARFER) and aluminum
545 salts (WAC HB) - were evaluated on turbidity and heavy metal removal from samples collected
546 during rainy weather at the inlet of Boudonville retention basin. The results showed that both
547 coagulants provided excellent removal of heavy metals; indeed; the concentrations of Cu, Zn and
548 Pb in the treated water complied with the water legislation.

549 Regarding flocculation treating CSOs, Gasperi et al. (2012) examined the performance of a full-
550 scale ballasted flocculation unit (BFU) implemented at the bypass of the wastewater treatment
551 plant located downstream of Paris on the Seine River. Ferric chloride (FeCl_3) and anionic
552 polymer were respectively used as coagulant and flocculant according to the turbidity levels
553 entering BFU, and high surface area was achieved by microsand to enhance flocculation, assist
554 flock formation and act as ballast, which aids rapid settlement. The performance of the system
555 was evaluated during the wet period, in which the bypassed combined sewage was treated only
556 with BFU and bio-filtration in order to remove nitrogen, before discharge. Significant removal
557 rates (>80%) were achieved for the compounds with a strong hydrophobic character ($\log K_{ow} >$

558 5.5) and removal rates of 50-80% were achieved for intermediate hydrophobic compounds ($4 <$
559 $\log K_{ow} < 5.5$). On the other hand, low hydrophobic compounds ($\log K_{ow} < 4$) were poorly
560 ($<20\%$) to weakly removed ($<50\%$). The authors concluded that it is a promising process to treat
561 CSO waters in order to remove various compounds.

562 Another possibility to remove very small particles or dissolved substances especially is by
563 adsorption. Although (Jung et al., 2015) investigated positive removal of micropollutants such as
564 acetaminophen and naproxen (94.1 and 97.7 %, respectively) from artificial combined sewage
565 with biochar in a lab scale study, there is no application on a large scale yet, since removing the
566 adsorbent from the wastewater matrix is difficult. Easier is the combination of a sand filter or
567 vertical-flow constructed wetland containing an activated layer; such as investigated by Bester &
568 Schäfer (2009). They evaluated the performance of an activated soil filter (bio filter) in order to
569 eliminate diverse xenobiotics from combined sewage, storm water and wastewater. The results
570 indicated that the removal efficiency of organic micropollutants depends on the application of an
571 organic layer in the filter, enabling higher removal efficiency. In a comprehensive study of
572 sanitary sewer overflow treatment with fixed media biofilters, results showed that, all bioreactors
573 can remove TSS, ammonia and phosphorous effectively (Tao, Mancl, & Tuovinen, 2010).
574 Moreover, BOD₅ reduction efficiency of $84 \pm 9\%$ can be reached with sand bioreactors. In
575 another study Kumordzi et al. (2016) focused on to remove the most abundant heavy metal,
576 namely Zn^{2+} , in simulated CSOs by a composite catalyst of TiO_2 and Graphene under various
577 process conditions such as pH, light intensity, catalyst loading and light source in a lab-scale
578 system. The adsorption and photo-reduction of Zn^{2+} enhanced with TiO_2 -G under the solar
579 spectrum. On the other hand, adsorption is not the best solution in case of high clogging risk and
580 water volume.

581 Rotating belt filter is another option for CSO treatment in terms of their minimal footprint and
582 also easier implementation. (Gutierrez, 2015).

583 Within the scope of INTCATCH Horizon2020 Innovation funded European project, a demo
584 plant, with the aim of treating CSOs before their discharge into Garda Lake, was installed at Villa
585 Bagatta. Additional aims considered the concept of technological innovation and public
586 participation in integrated and smart management of water infrastructure and basins (Figure 3).

587 The pilot plant has a compact modular design, composed of three main sections; rotating belt
588 filtration (RBF), filtration on granular activated carbon (GAC) and disinfection by UV treatment
589 (Figure 4). Despite the fact that the processes used in this project used for decades for wastewater
590 treatment, they have not been applied specifically for the treatment of CSO discharges.

591 The plant can treat 54 m³/h. The Rotating Dynamic Filter (Salsnes Filter, SF1000) accomplished
592 the sieving of the CSOs through a mesh size of 350 µm and the retained solids are thickened
593 using an embedded screw-press unit, achieving a total solid concentration of 20-35%. The outlet
594 CSOs is stored in an existing concrete open tank where it may be pumped up to 3.6 m³/h to the
595 GAC filtration system. Following the GAC system, is an ultraviolet disinfection unit with 4
596 modules (Trojan Technologies, UV3400K) installed in the open channel. Electrical conductivity,
597 pH, and multiple parameters simultaneously derived by UV/Vis optical spectrometry (Intelligent
598 Spectral Analyser (ISA)) are installed to monitor the system. Data are gathered and transmitted to
599 cloud computing which is also integrating sustainability evaluation and assessment tools in order
600 to provide eco-efficiency indicators of the treatment and management system. The plant reached
601 satisfactory removal efficiencies for TSS (90%), COD (69%) and *E. coli* (%99). However, further
602 treatment is required for efficient nutrient removal in which TN and TP removal of around 41%
603 and 19%, respectively (Botturi et al., 2020). The innovations of this project are its modular
604 structure, compactness, rapid treatment and resilience of the system which enables to re-shape of

605 the configuration according to the treatment requirements.

606 To sustain the safety of the water quality of receiving water bodies used for recreational
607 purposes, microbial loads from CSOs should be reduced. Since quality and quantity of CSOs are
608 very variable, it a challenge to find suitable disinfection technologies which can be operated
609 spontaneously for a short period at full capacity. The most commonly applied disinfection
610 methods for the treatment of WWTP effluent are using chlorine compounds, ozone and ultra-
611 violet (UV). However, these are not ideal for CSO treatment due to the high concentrations of
612 solids and dissolved organic compounds: using chlorine compounds can lead to the formation of
613 toxic, mutagenic and carcinogenic chlorinate by-products (Bayo, Angosto, & Gómez-López,
614 2009; Nurizzo, Antonelli, Profaizer, & Romele, 2005).

615 Undesirable by-products can also be the result when using ozone. Tondera et al. (2015) evaluated
616 the effects of ozonation on diluted wastewater in a pilot scale application. Although the reduction
617 of pathogenic bacteria, viruses, and protozoan parasites were promising and more effective than
618 UV irradiation for the tested conditions, the operation of an ozone generator under these
619 conditions is difficult to manage and both installation and operation is costly.

620 Suspended solids and turbidity in CSOs are also limiting parameters on the disinfecting effects of
621 UV radiation (Tondera et al., 2015). In another study, Gibson et al. (2016) evaluated the effects
622 of chemical pre-treatment of CSOs for subsequent UV disinfection. When applying 20 mg/L
623 alum, the UV light transmission of the raw CSO increased from 30 to 60% after settling. The
624 high charge density cationic polymer improved the removal of turbidity but did not affect UV
625 transmittance (UVT) and TSS. The use of alum (metal coagulants) can achieve a UVT of 78%,
626 while the use of cationic polymers reached a value of 60%. Pre-treatment to remove particles via
627 CSO–CWs, as described above, not only increases the removal of microbial loads, but also

628 allows reduction of dissolved parameters. In addition, no chemical addition is required, but space
629 availability and installation costs are critical.

630 Alternative treatment with peroxy acids was investigated in several recent studies. Peracetic acid
631 (PAA) requires a reaction time of several hours (Chhetri et al., 2014). The influence of particles
632 on the removal efficiency gave controversial results: While Chhetri et al. (2016) found that
633 bacterial reduction was more mostly efficient with a pre-treatment by particle separator and an
634 additional coagulation with poly-aluminum-chloride, McFadden et al. (2017) could not find an
635 effect of particle removal on the efficiency of CSO treatment with PAA.

636 As an alternative to PAA, performic acid (PFA) requires only a short contact time Under real
637 scale conditions, Chhetri et al. (2015) showed a reduction of 2.0 log₁₀ of *Escherichia coli* and 1.3
638 log₁₀ of intestinal enterococci (contact time of 20 min, 8 mg l⁻¹ min⁻¹ reduced approximately),
639 and Tondera et al. (2016) proved additional reduction of coliform bacteria, *Aeromonas spp.* and
640 *P. aeruginosa* with a log₁₀ reduction between 1.8 and 2.9 (contact time of max. 30 min, 12 to 24
641 mg l⁻¹ min⁻¹). Additionally, a reduction of somatic coliphages with 2.7 ± 1.7 log₁₀ could be
642 shown. Another advantage of using PFA is that the commercially available reaction chamber
643 providing PFA seems to be tolerant to long standstills, which can occur during dry seasons
644 without CSOs.

645 **6. Economics**

646 Municipalities should invest in infrastructures to monitor, control and treat CSOs to meet
647 regulatory obligations of the receiving water bodies. It should be noted that the private companies
648 can also involve in the controlling of sewerage systems besides the government. Since
649 legislations are encouraged to apply better management strategies for CSO discharges, there are
650 no strict regulations. Thus, CSO discharge management is still an issue.

651 Real time control systems seem a cost effective alternative since they only require additional
652 implementations to the existing systems. The design step is crucial to select the right equipment
653 with the proper communication system and software, which may lead to significant capital
654 investment costs. In real time control systems, cleaning equipment needs to be integrated into the
655 instrumentation to prevent, fouling of the sensors. While, these integrations increase the capital
656 costs, they have an advantage in the long term of reduced maintenance costs (Campisano, Cabot
657 Ple, Muschalla, Pleau, & Vanrolleghem, 2013). Colas et al., (2004) summarized the benefits of
658 real time controlling on CSOs for different locations. In Paris, the capital cost of CSO controlling
659 was reduced by almost 25% by application of real-time control to the system. In Louisville, the
660 municipality has reduced the cost of CSO long-term control program by \$150 million by
661 integrating a real-time controlling system. In another application in Quebec, \$90 million was
662 saved in the capital cost to the Quebec City CSO Control Program in terms of reducing the
663 number and the size of some facilities. In Berlin €90 million was invested to reduce CSO's, in
664 which the cheapest measures are real time controlling inside the CS. On the other hand,
665 construction of retention basins cost 1000€/m³. An external basin has been tested in Berlin's
666 River Spree since 2011 but at the end costs were not lower than for underground structures. In
667 Ancona and Falconara Marittima (Italy) € 22 million have been planned to be invested for CSO
668 management.

669 Different technologies and approaches can be integrated and/or applied for CSO controlling.
670 During the decision, the optimum method should be evaluated based on the physical properties of
671 the interface, applicability of the technology, operational & maintenance costs, cost-benefit ratio.

672 **7. Conclusions and further research needs**

673 CSO discharge is still a major environmental threat that need to be better monitored to provide

674 data-driven decision support towards water infrastructure upgrading. Although, the negative
675 impacts of CSO discharges on aquatic environments are defined extensively, strict limitations are
676 still needed to be set in the national regulations to force water managers taking necessary actions.
677 To date, several cost-efficiency real-time monitoring systems are available and innovation
678 projects are even using cloud and IoT platforms to better engage stakeholders and citizens and
679 raise awareness about the CSO management importance. A combination of NBS and compact
680 treatment system coupling smart monitoring with green and gray eco-innovative solutions should
681 be planned at catchment scale, depending on the best technical, environmental and economic
682 sustainability. Modular structures of these systems enable to set up different configurations
683 according to the treatment requirements and field features. Moreover, extensive research is
684 needed to validate actual integrated actions at catchment scale, integrating novel low-cost
685 sensors, innovative treatment technologies, digital platforms and eco-efficiency assessment.
686 Further researches and monitoring experiences will support the development of future concrete
687 guidelines and strategies to manage the CSOs and to mitigate their impacts on the environment.

688 **Conflict of interest**

689 The authors have declared no conflict of interest.

690 **Acknowledgements**

691 The authors acknowledge the European Union's Horizon2020 research and innovation
692 programme for co-funding INTCATCH innovation action under grant agreement No.689341.

693 **References**

694 Al Aukidy, M., & Verlicchi, P. (2017). Contributions of combined sewer overflows and treated
695 effluents to the bacterial load released into a coastal area. *Science of the Total Environment*,

696 607–608, 483–496. <https://doi.org/10.1016/j.scitotenv.2017.07.050>

697 ATV-128. (1992). Standards for the Dimensioning and Design of Stormwater Structures in
698 Combined Sewers.

699 Ávila, C., Salas, J. J., Martín, I., Aragón, C., & García, J. (2013). Integrated treatment of
700 combined sewer wastewater and stormwater in a hybrid constructed wetland system in
701 southern Spain and its further reuse. *Ecological Engineering*, 50, 13–20.
702 <https://doi.org/10.1016/j.ecoleng.2012.08.009>

703 Bailey, J., Harris, E., Keedwell, E., Djordjevic, S., & Kapelan, Z. (2016). The Use of Telemetry
704 Data for the Identification of Issues at Combined Sewer Overflows. *Procedia Engineering*,
705 154, 1201–1208. <https://doi.org/10.1016/j.proeng.2016.07.524>

706 Bayo, J., Angosto, J. M., & Gómez-López, M. D. (2009). Ecotoxicological screening of
707 reclaimed disinfected wastewater by *Vibrio fischeri* bioassay after a chlorination-
708 dechlorination process. *Journal of Hazardous Materials*, 172(1), 166–171.
709 <https://doi.org/10.1016/j.jhazmat.2009.06.157>

710 Bester, K., Banzhaf, S., Burkhardt, M., Janzen, N., Niederstrasser, B., & Scheytt, T. (2011).
711 Activated soil filters for removal of biocides from contaminated run-off and waste-waters.
712 *Chemosphere*, 85(8), 1233–1240. <https://doi.org/10.1016/j.chemosphere.2011.07.017>

713 Bester, K., & Schäfer, D. (2009). Activated soil filters (bio filters) for the elimination of
714 xenobiotics (micro-pollutants) from storm- and waste waters. *Water Research*, 43(10),
715 2639–2646. <https://doi.org/10.1016/j.watres.2009.03.026>

716 Birch, H., Mikkelsen, P. S., Jensen, J. K., & Holten Lützhøft, H. C. (2011). Micropollutants in
717 stormwater runoff and combined sewer overflow in the Copenhagen area, Denmark. *Water*

718 *Science and Technology*, 64(2), 485–493. <https://doi.org/10.2166/wst.2011.687>

719 Botturi, A., Daneshgar, S., Cordioli, A., Foglia, A., Eusebi, A. L., & Fatone, F. (2020). An
720 innovative compact system for advanced treatment of combined sewer overflows (CSOs)
721 discharged into large lakes : Pilot-scale validation. *Journal of Environmental Management*,
722 256(September 2019), 109937. <https://doi.org/10.1016/j.jenvman.2019.109937>

723 Brzezińska, A., Zawilski, M., & Sakson, G. (2016). Assessment of pollutant load emission from
724 combined sewer overflows based on the online monitoring. *Environmental Monitoring and*
725 *Assessment*, 188(9). <https://doi.org/10.1007/s10661-016-5461-6>

726 Buerge, I. J., Poiger, T., Müller, M. D., & Buser, H. R. (2006). Combined sewer overflows to
727 surface waters detected by the anthropogenic marker caffeine. *Environmental Science and*
728 *Technology*, 40(13), 4096–4102. <https://doi.org/10.1021/es052553l>

729 Campisano, A., Cabot Ple, J., Muschalla, D., Pleau, M., & Vanrolleghem, P. A. (2013). Potential
730 and limitations of modern equipment for real time control of urban wastewater systems.
731 *Urban Water Journal*, 10(5), 300–311. <https://doi.org/10.1080/1573062X.2013.763996>

732 Chen, J., Liu, Y., Gitau, M. W., Engel, B. A., Flanagan, D. C., & Harbor, J. M. (2019).
733 Evaluation of the effectiveness of green infrastructure on hydrology and water quality in a
734 combined sewer overflow community. *Science of the Total Environment*, 665, 69–79.
735 <https://doi.org/10.1016/j.scitotenv.2019.01.416>

736 Chhetri, R. K., Flagstad, R., Munch, E. S., Hørning, C., Berner, J., Kolte-Olsen, A., ... Andersen,
737 H. R. (2015). Full scale evaluation of combined sewer overflows disinfection using
738 performic acid in a sea-outfall pipe. *Chemical Engineering Journal*, 270, 133–139.
739 <https://doi.org/10.1016/j.cej.2015.01.136>

740 Chhetri, R. K., Thornberg, D., Berner, J., Gramstad, R., Öjstedt, U., Sharma, A. K., & Andersen,
741 H. R. (2014). Chemical disinfection of combined sewer overflow waters using performic
742 acid or peracetic acids. *Science of the Total Environment*, 490, 1065–1072.
743 <https://doi.org/10.1016/j.scitotenv.2014.05.079>

744 Christoffels, E., Mertens, F. M., Kistemann, T., & Schreiber, C. (2014). Retention of
745 pharmaceutical residues and microorganisms at the Altendorf retention soil filter. *Water*
746 *Science and Technology*, 70(9), 1503–1509. <https://doi.org/10.2166/wst.2014.404>

747 De Sousa, M. R. C., Montalto, F. A., & Spatari, S. (2012). Using Life Cycle Assessment to
748 Evaluate Green and Grey Combined Sewer Overflow Control Strategies. *Journal of*
749 *Industrial Ecology*, 16(6), 901–913. <https://doi.org/10.1111/j.1530-9290.2012.00534.x>

750 Del Río, H., Suárez, J., Puertas, J., & Ures, P. (2013). PPCPs wet weather mobilization in a
751 combined sewer in NW Spain. *Science of the Total Environment*, 449, 189–198.
752 <https://doi.org/10.1016/j.scitotenv.2013.01.049>

753 DWA. (2013a). *Arbeitsblatt DWA-A 166: Bauwerke der zentralen 2 Regenwasserbehandlung*
754 *und-rückhaltung - Konstruktive Gestaltung und 3 Ausrüstung*. Deutsche Vereinigung für
755 *Wasserwirtschaft, Abwasser und Abfall 4 e.V.* Hennef, Germany.

756 DWA. (2013b). *Merkblatt DWA-M 176: Hinweise zur konstruktiven Gestaltung und Ausrüstung*
757 *von Bauwerken der zentralen Regenwasserbehandlung und -rückhaltung*. Deutsche
758 *Vereinigung für Wasserwirtschaft, Abwasser und Abfall e.V.* Hennef, Germany.

759 EC. (2013). *European Commission Strategy on Green Infrastructure, Communication from the*
760 *Commission to the European Parliament, The Council, The European Economic and Social*
761 *Committee and Committee of the Regions*.

762 El Samrani, A. G., Lartiges, B. S., & Villiéras, F. (2008). Chemical coagulation of combined
763 sewer overflow: Heavy metal removal and treatment optimization. *Water Research*, 42(4–5),
764 951–960. <https://doi.org/10.1016/j.watres.2007.09.009>

765 Entem, S., Lahoud, A., Yde, L., & Bendsen, B. (1998). Real time control of the sewer system of
766 boulogne billancourt - a contribution to improving the water quality of the seine. *Water*
767 *Science and Technology*, 37(1). [https://doi.org/10.1016/S0273-1223\(97\)00785-3](https://doi.org/10.1016/S0273-1223(97)00785-3)

768 EU. (2006). *Regulation (EC) No 166/2006 of the European Parliament and of the Council of 18*
769 *January 2006 Concerning the Establishment of a European Pollutant Release and Transfer*
770 *Register and Amending Council Directives 91/689/EEC and 96/61/EC, 166/2006.*

771 EurEau. (2016). Overflows from collecting systems, 32(May), 1–6. Retrieved from
772 www.eureau.org

773 Fono, L. J., & Sedlak, D. L. (2005). Use of the chiral pharmaceutical propranolol to identify
774 sewage discharges into surface waters. *Environmental Science and Technology*, 39(23),
775 9244–9252. <https://doi.org/10.1021/es047965t>

776 Fu, X., Goddard, H., Wang, X., & Hopton, M. E. (2019). Development of a scenario-based
777 stormwater management planning support system for reducing combined sewer overflows
778 (CSOs). *Journal of Environmental Management*, 236(August 2018), 571–580.
779 <https://doi.org/10.1016/j.jenvman.2018.12.089>

780 Gasperi, J, Sebastian, C., Ruban, V., Delamain, M., Percot, S., Wiest, L., & Mirande, C. (2014).
781 Micropollutants in urban stormwater : occurrence , concentrations , and atmospheric
782 contributions for a wide range of contaminants in three French catchments. *Environmental*
783 *Science and Pollution Research*, 21(8), 5267–5281. <https://doi.org/10.1007/s11356-013->

784 2396-0

785 Gasperi, Johnny, Laborie, B., & Rocher, V. (2012). Treatment of combined sewer overflows by
786 ballasted flocculation: Removal study of a large broad spectrum of pollutants. *Chemical*
787 *Engineering Journal*, 211–212(2012), 293–301. <https://doi.org/10.1016/j.cej.2012.09.025>

788 Gasperi, Johnny, Zgheib, S., Cladière, M., Rocher, V., Moilleron, R., & Chebbo, G. (2012).
789 Priority pollutants in urban stormwater: Part 2 - Case of combined sewers. *Water Research*,
790 46(20), 6693–6703. <https://doi.org/10.1016/j.watres.2011.09.041>

791 Gibson, J., Farnood, R., & Seto, P. (2016). Chemical pretreatment of combined sewer overflows
792 for improved UV disinfection. *Water Science and Technology*, 73(2), 375–381.
793 <https://doi.org/10.2166/wst.2015.447>

794 Gong, Y., Chen, Y., Yu, L., Li, J., Pan, X., Shen, Z., ... Qiu, Q. (2019). Effectiveness analysis of
795 systematic combined sewer overflow control schemes in the sponge city pilot area of
796 Beijing. *International Journal of Environmental Research and Public Health*, 16(9), 1–18.
797 <https://doi.org/10.3390/ijerph16091503>

798 Gutierrez, M. (2015). Continuous Rotating Belt Filtration for Primary Treatment and Combined
799 Sewer Overflows, (January), 58–62.

800 Heinz, B., Birk, S., Liedl, R., Geyer, T., Straub, K. L., Andresen, J., ... Kappler, A. (2009). Water
801 quality deterioration at a karst spring (Gallusquelle, Germany) due to combined sewer
802 overflow: Evidence of bacterial and micro-pollutant contamination. *Environmental Geology*,
803 57(4), 797–808. <https://doi.org/10.1007/s00254-008-1359-0>

804 Hnat'uková, P. (2011). Geochemical distribution and mobility of heavy metals in sediments of
805 urban streams affected by combined sewer overflows. *Journal of Hydrology and*

806 *Hydromechanics*, 59(2), 85–94. <https://doi.org/10.2478/v10098-011-0007-7>

807 Hofer, T., Montserrat, A., Gruber, G., Gamerith, V., Corominas, L., & Muschalla, D. (2018). A
808 robust and accurate surrogate method for monitoring the frequency and duration of
809 combined sewer overflows. *Environmental Monitoring and Assessment*, 190(4).
810 <https://doi.org/10.1007/s10661-018-6589-3>

811 Jalliffier-Verne, I., Heniche, M., Madoux-Humery, A. S., Galarneau, M., Servais, P., Prévost, M.,
812 & Dorner, S. (2016). Cumulative effects of fecal contamination from combined sewer
813 overflows: Management for source water protection. *Journal of Environmental*
814 *Management*, 174, 62–70. <https://doi.org/10.1016/j.jenvman.2016.03.002>

815 Jotte, L., Raspati, G., & Azrague, K. (2017). *Report Review of Stormwater Management*.

816 Jung, C., Oh, J., & Yoon, Y. (2015). Removal of acetaminophen and naproxen by combined
817 coagulation and adsorption using biochar: influence of combined sewer overflow
818 components. *Environmental Science and Pollution Research*, 22(13), 10058–10069.
819 <https://doi.org/10.1007/s11356-015-4191-6>

820 Kistemann, T., Schmidt, A., & Flemming, H. C. (2016). Post-industrial river water quality—Fit
821 for bathing again? *International Journal of Hygiene and Environmental Health*, 219(7),
822 629–642. <https://doi.org/10.1016/j.ijheh.2016.07.007>

823 Kumordzi, G., Malekshoar, G., Yanful, E. K., & Ray, A. K. (2016). Solar photocatalytic
824 degradation of Zn²⁺ using graphene based TiO₂. *Separation and Purification Technology*,
825 168, 294–301. <https://doi.org/10.1016/j.seppur.2016.05.040>

826 Launay, M. A., Dittmer, U., & Steinmetz, H. (2016). Organic micropollutants discharged by
827 combined sewer overflows – Characterisation of pollutant sources and stormwater-related

828 processes. *Water Research*, 104, 82–92. <https://doi.org/10.1016/j.watres.2016.07.068>

829 Levy, Z. F., Smardon, R. C., Bays, J. S., & Meyer, D. (2014). A point source of a different color:
830 Identifying a gap in united states regulatory policy for “green” CSO treatment using
831 constructed wetlands. *Sustainability (Switzerland)*, 6(5), 2392–2412.
832 <https://doi.org/10.3390/su6052392>

833 Li, T., Tan, Q., & Zhu, S. (2010). Characteristics of combined sewer overflows in Shanghai and
834 selection of drainage systems. *Water and Environment Journal*, 24(1), 74–82.
835 <https://doi.org/10.1111/j.1747-6593.2008.00141.x>

836 Madoux-Humery, A.-S., Dorner, S. M., Sauvé, S., Aboulfadl, K., Galarneau, M., Servais, P., &
837 Prévost, M. (2015). Temporal analysis of E. coli, TSS and wastewater micropollutant loads
838 from combined sewer overflows: implications for management. *Environmental Science:
839 Processes & Impacts*, 17(5), 965–974. <https://doi.org/10.1039/C5EM00093A>

840 Madoux-Humery, A. S., Dorner, S., Sauvé, S., Aboulfadl, K., Galarneau, M., Servais, P., &
841 Prévost, M. (2016). The effects of combined sewer overflow events on riverine sources of
842 drinking water. *Water Research*, 92, 218–227. <https://doi.org/10.1016/j.watres.2015.12.033>

843 Mailhot, A., Talbot, G., & Lavallée, B. (2015). Relationships between rainfall and Combined
844 Sewer Overflow (CSO) occurrences. *Journal of Hydrology*, 523, 602–609.
845 <https://doi.org/10.1016/j.jhydrol.2015.01.063>

846 Masi, F., Rizzo, A., Bresciani, R., & Conte, G. (2017). Constructed wetlands for combined sewer
847 overflow treatment: Ecosystem services at Gorla Maggiore, Italy. *Ecological Engineering*,
848 98, 427–438. <https://doi.org/10.1016/j.ecoleng.2016.03.043>

849 Maté Marín, A., Rivière, N., & Lipeme Kouyi, G. (2018). DSM-flux: A new technology for

850 reliable Combined Sewer Overflow discharge monitoring with low uncertainties. *Journal of*
851 *Environmental Management*, 215, 273–282. <https://doi.org/10.1016/j.jenvman.2018.03.043>

852 McBride, G. B., Stott, R., Miller, W., Bambic, D., & Wuertz, S. (2013). Discharge-based QMRA
853 for estimation of public health risks from exposure to stormwater-borne pathogens in
854 recreational waters in the United States. *Water Research*, 47(14), 5282–5297.
855 <https://doi.org/10.1016/j.watres.2013.06.001>

856 McFadden, M., Loconsole, J., Schockling, A. J., Nerenberg, R., & Pavissich, J. P. (2017).
857 Comparing peracetic acid and hypochlorite for disinfection of combined sewer overflows:
858 Effects of suspended-solids and pH. *Science of the Total Environment*, 599–600, 533–539.
859 <https://doi.org/10.1016/j.scitotenv.2017.04.179>

860 McGinnis, S., Spencer, S., Firnstahl, A., Stokdyk, J., Borchardt, M., McCarthy, D. T., & Murphy,
861 H. M. (2018). Human Bacteroides and total coliforms as indicators of recent combined
862 sewer overflows and rain events in urban creeks. *Science of the Total Environment*, 630,
863 967–976. <https://doi.org/10.1016/j.scitotenv.2018.02.108>

864 McSweeney, C., Kang, S., Gagen, E., Davis, C., Morrison, M., & Denman, S. (2009). Recent
865 developments in nucleic acid based techniques for use in rumen manipulation. *Revista*
866 *Brasileira de Zootecnia*, 38, 341–351. Retrieved from [http://orton.catie.ac.cr/cgi-](http://orton.catie.ac.cr/cgi-bin/wxis.exe/?IsisScript=SCBR.xis&method=post&formato=2&cantidad=1&expresion=mfn=025288)
867 [bin/wxis.exe/?IsisScript=SCBR.xis&method=post&formato=2&cantidad=1&](http://orton.catie.ac.cr/cgi-bin/wxis.exe/?IsisScript=SCBR.xis&method=post&formato=2&cantidad=1&expresion=mfn=025288)
868 [amp;expresion=mfn=025288](http://orton.catie.ac.cr/cgi-bin/wxis.exe/?IsisScript=SCBR.xis&method=post&formato=2&cantidad=1&expresion=mfn=025288)

869 Meyer, D., Molle, P., Esser, D., Troesch, S., Masi, F., & Dittmer, U. (2013). Constructed
870 wetlands for combined sewer overflow treatment-comparison of German, French and Italian
871 approaches. *Water (Switzerland)*, 5(1), 1–12. <https://doi.org/10.3390/w5010001>

- 872 Montserrat, A., Bosch, L., Kiser, M. A., Poch, M., & Corominas, L. (2015). Using data from
873 monitoring combined sewer overflows to assess, improve, and maintain combined sewer
874 systems. *Science of the Total Environment*. <https://doi.org/10.1016/j.scitotenv.2014.10.087>
- 875 Montserrat, A., Gutierrez, O., Poch, M., & Corominas, L. (2013). Field validation of a new low-
876 cost method for determining occurrence and duration of combined sewer overflows. *Science*
877 *of the Total Environment*, 463–464, 904–912.
878 <https://doi.org/10.1016/j.scitotenv.2013.06.010>
- 879 Morgan, D., Xiao, L., & McNabola, A. (2017). Evaluation of combined sewer overflow
880 assessment methods: case study of Cork City, Ireland. *Water and Environment Journal*,
881 31(2), 202–208. <https://doi.org/10.1111/wej.12239>
- 882 Morris, G. (1999). *Regulatory requirements: the EA view. Developments in Storm Sewage*
883 *Management: Meeting the Challenge of AMP3. CIWEM Conf.* Wakefield, UK.
- 884 Munro, K., Martins, C. P. B., Loewenthal, M., Comber, S., Cowan, D. A., Pereira, L., & Barron,
885 L. P. (2019). Evaluation of combined sewer overflow impacts on short-term pharmaceutical
886 and illicit drug occurrence in a heavily urbanised tidal river catchment (London, UK).
887 *Science of The Total Environment*, 657, 1099–1111.
888 <https://doi.org/10.1016/j.scitotenv.2018.12.108>
- 889 Musolff, A., Leschik, S., Möder, M., Strauch, G., Reinstorf, F., & Schirmer, M. (2009). Temporal
890 and spatial patterns of micropollutants in urban receiving waters. *Environmental Pollution*,
891 157(11), 3069–3077. <https://doi.org/10.1016/j.envpol.2009.05.037>
- 892 Nielsen, P. H., Raunkjær, K., Norsker, N. H., Jensen, N. A., & Hvitved-Jacobsen, T. (1992).
893 Transformation of Wastewater in Sewer Systems – A Review. *Water Science and*

894 *Technology*, 25(6), 17–31. <https://doi.org/10.2166/wst.1992.0111>

895 Nurizzo, C., Antonelli, M., Profaizer, M., & Romele, L. (2005). By-products in surface and
896 reclaimed water disinfected with various agents. *Desalination*, 176(1-3 SPEC. ISS.), 241–
897 253. <https://doi.org/10.1016/j.desal.2004.11.012>

898 Pálffy, T. G., Meyer, D., Troesch, S., Gourdon, R., Olivier, L., & Molle, P. (2018). A single-
899 output model for the dynamic design of constructed wetlands treating combined sewer
900 overflow. *Environmental Modelling and Software*, 102, 49–72.
901 <https://doi.org/10.1016/j.envsoft.2017.12.023>

902 Pálffy, T. G., Molle, P., Langergraber, G., Troesch, S., Gourdon, R., & Meyer, D. (2016).
903 Simulation of constructed wetlands treating combined sewer overflow using
904 HYDRUS/CW2D. *Ecological Engineering*, 87, 340–347.
905 <https://doi.org/10.1016/j.ecoleng.2015.11.048>

906 Passerat, J., Ouattara, N. K., Mouchel, J. M., Vincent Rocher, & Servais, P. (2011). Impact of an
907 intense combined sewer overflow event on the microbiological water quality of the Seine
908 River. *Water Research*, 45(2), 893–903. <https://doi.org/10.1016/j.watres.2010.09.024>

909 Phillips, J. P., Chalmers, T. A., Gray, L. J., Kolpin, W. D., Foreman, T. W., & Wall, R. G.
910 (2012). Combined Sewer Overflows: An Environmental Source of Hormones and
911 Wastewater Micropollutants. *Environmental Science & Technology*, 46(10), 5336–5343.
912 <https://doi.org/10.1021/es3001294>

913 Phillips, P., & Chalmers, A. (2009). Wastewater effluent, combined sewer overflows, and other
914 sources of organic compounds to Lake Champlain. *Journal of the American Water*
915 *Resources Association*, 45(1), 45–57. <https://doi.org/10.1111/j.1752-1688.2008.00288.x>

- 916 Pond, K. (2005). *Water recreation and disease: Plausibility of associated infections: Acute*
917 *effects, sequelae and mortality*. IWA Publishing.
- 918 Riechel, M., Matzinger, A., Pawlowsky-Reusing, E., Sonnenberg, H., Uldack, M., Heinzmann,
919 B., ... Rouault, P. (2016). Impacts of combined sewer overflows on a large urban river –
920 Understanding the effect of different management strategies. *Water Research, 105*, 264–
921 273. <https://doi.org/10.1016/j.watres.2016.08.017>
- 922 Riechel, M., Seis, W., Matzinger, A., Pawlowsky-Reusing, E., & Rouault, P. (2019). Relevance
923 of Different CSO Outlets for Bathing Water Quality in a River System. In G. Mannina (Ed.)
924 (pp. 859–863). Springer. https://doi.org/10.1007/978-3-319-99867-1_148
- 925 Rizzo, A., Bresciani, R., Masi, F., Boano, F., Revelli, R., & Ridolfi, L. (2018). Flood reduction as
926 an ecosystem service of constructed wetlands for combined sewer overflow. *Journal of*
927 *Hydrology, 560*, 150–159. <https://doi.org/10.1016/j.jhydrol.2018.03.020>
- 928 Rouff, A. A., Eaton, T. T., & Lanzirotti, A. (2013). Heavy metal distribution in an urban wetland
929 impacted by combined sewer overflow. *Chemosphere, 93*(9), 2159–2164.
930 <https://doi.org/10.1016/j.chemosphere.2013.07.077>
- 931 Ruggaber, T. P., & Talley, J. W. (2005). Detection and Control of Combined Sewer Overflow
932 Events Using Embedded Sensor Network Technology, 1–12.
933 [https://doi.org/10.1061/40792\(173\)306](https://doi.org/10.1061/40792(173)306)
- 934 Ruppelt, J. P., Tondera, K., Vorenhout, M., Van der Weken, L., & Pinnekamp, J. (2019). Redox
935 potential as a method to evaluate the performance of retention soil filters treating combined
936 sewer overflows. *Science of the Total Environment, 650*, 1628–1639.
937 <https://doi.org/10.1016/j.scitotenv.2018.09.043>

- 938 Ryu, J., Oh, J., Snyder, S. A., & Yoon, Y. (2014). Determination of micropollutants in combined
939 sewer overflows and their removal in a wastewater treatment plant (Seoul, South Korea).
940 *Environmental Monitoring and Assessment*, 186(5), 3239–3251.
941 <https://doi.org/10.1007/s10661-013-3613-5>
- 942 Sandoval, S., Torres, A., Pawlowsky-Reusing, E., Riechel, M., & Caradot, N. (2013). The
943 evaluation of rainfall influence on combined sewer overflows characteristics: The Berlin
944 case study. *Water Science and Technology*, 68(12), 2683–2690.
945 <https://doi.org/10.2166/wst.2013.524>
- 946 Schares, G., Pantchev, N., Barutzki, D., Heydorn, A. O., Bauer, C., & Conraths, F. J. (2005).
947 Oocysts of *Neospora caninum*, *Hammondia heydorni*, *Toxoplasma gondii* and *Hammondia*
948 *hammondi* in faeces collected from dogs in Germany. *International Journal for*
949 *Parasitology*, 35(14), 1525–1537. <https://doi.org/10.1016/j.ijpara.2005.08.008>
- 950 Schertzinger, G., Ruchter, N., & Sures, B. (2018). Metal accumulation in sediments and
951 amphipods downstream of combined sewer overflows. *Science of the Total Environment*,
952 616–617, 1199–1207. <https://doi.org/10.1016/j.scitotenv.2017.10.199>
- 953 Scheurer, M., Heß, S., Lüddeke, F., Sacher, F., Güde, H., Löffler, H., & Gallert, C. (2015).
954 Removal of micropollutants, facultative pathogenic and antibiotic resistant bacteria in a full-
955 scale retention soil filter receiving combined sewer overflow. *Environmental Sciences:*
956 *Processes and Impacts*, 17(1), 186–196. <https://doi.org/10.1039/c4em00494a>
- 957 Seis, W., Zamzow, M., Caradot, N., & Rouault, P. (2018). On the implementation of reliable
958 early warning systems at European bathing waters using multivariate Bayesian regression
959 modelling. *Water Research*, 143, 301–312. <https://doi.org/10.1016/j.watres.2018.06.057>

- 960 Soriano, L., & Rubi6, J. (2019). Impacts of Combined Sewer Overflows on surface water bodies.
961 The case study of the Ebro River in Zaragoza city. *Journal of Cleaner Production*, 226, 1–5.
962 <https://doi.org/10.1016/j.jclepro.2019.04.033>
- 963 Stott, R., Tondera, K., Blecken, G.-T., & Schreiber, C. (2018). Microbial Loads and Removal
964 Efficiency Under Varying Flows. In K. Tondera, G.-T. Blecken, F. Chazarenc, & C. C.
965 Tanner (Eds.) (pp. 57–74). Cham: Springer International Publishing.
966 https://doi.org/10.1007/978-3-319-70013-7_4
- 967 Su6rez, J., & Puertas, J. (2005). Determination of COD, BOD, and suspended solids loads during
968 combined sewer overflow (CSO) events in some combined catchments in Spain. *Ecological*
969 *Engineering*, 24(3), 201–219. <https://doi.org/10.1016/j.ecoleng.2004.11.005>
- 970 Tabuchi, J. . SIAAP’s stormwater management policy” Impacts of combined sewer overflows on
971 urban waters: Challenges and solutions for European cities Amsterdam (2013).
- 972 Tanaka, K., & Takada, H. (2016). Microplastic fragments and microbeads in digestive tracts of
973 planktivorous fish from urban coastal waters. *Scientific Reports*, 6(March), 1–8.
974 <https://doi.org/10.1038/srep34351>
- 975 Tao, J., Mancl, K. M., & Tuovinen, O. H. (2010). Attenuation of pollutants in sanitary sewer
976 overflow: Comparative evaluation of treatment with fixed media bioreactors. *Bioresource*
977 *Technology*, 101(6), 1781–1786. <https://doi.org/10.1016/j.biortech.2009.10.038>
- 978 Tondera, K. (2017). Evaluating the performance of constructed wetlands for the treatment of
979 combined sewer overflows. *Ecological Engineering*, (October), 1–7.
980 <https://doi.org/10.1016/j.ecoleng.2017.10.009>
- 981 Tondera, K., Klaer, K., Gebhardt, J., Wingender, J., Koch, C., Horstkott, M., ... Pinnekamp, J.

982 (2015). Reducing pathogens in combined sewer overflows using ozonation or UV
983 irradiation. *International Journal of Hygiene and Environmental Health*, 218(8), 731–741.
984 <https://doi.org/10.1016/j.ijheh.2015.09.002>

985 Tondera, K., Klaer, K., Roder, S., Brueckner, I., Strathmann, M., Kistemann, T., ... Pinnekamp,
986 J. (2016). Developing an easy-to-apply model for identifying relevant pathogen pathways
987 into surface waters used for recreational purposes. *International Journal of Hygiene and*
988 *Environmental Health*, 219(7), 662–670. <https://doi.org/10.1016/j.ijheh.2015.11.005>

989 Tondera, K., Koenen, S., & Pinnekamp, J. (2013). Survey monitoring results on the reduction of
990 micropollutants, bacteria, bacteriophages and TSS in retention soil filters. *Water Science*
991 *and Technology*, 68(5), 1004–1012. <https://doi.org/10.2166/wst.2013.340>

992 Tondera, K., Ruppelt, J. P., Pinnekamp, J., Kistemann, T., & Schreiber, C. (2019). Reduction of
993 micropollutants and bacteria in a constructed wetland for combined sewer overflow
994 treatment after 7 and 10 years of operation. *Science of the Total Environment*, 651, 917–927.
995 <https://doi.org/10.1016/j.scitotenv.2018.09.174>

996 U.S. EPA. (2001). Report to Congress Implementation and Enforcement of the Combined Sewer
997 Overflow Control Policy, (December).

998 U.S.EPA. (2004). Report to Congress on Impacts and Control of Combined Sewer Overflows and
999 Sanitary Sewer Overflows Fact Sheet. *Washington D.C.*, 1–2.
1000 <https://doi.org/10.1227/01.NEU.0000028680.51299.00>

1001 UBA. (2012). Die Wasserrahmenrichtlinie Eine Zwischenbilanz zur Umsetzung der
1002 Maßnahmenprogramme.

1003 USEPA. (2018). Smart Data Infrastructure for Wet Weather Control and Decision Support EPA

1004 830- B-17-004, 2018.

1005 Viviano, G., Valsecchi, S., Polesello, S., Capodaglio, A., Tartari, G., & Salerno, F. (2017).
1006 Combined Use of Caffeine and Turbidity to Evaluate the Impact of CSOs on River Water
1007 Quality. *Water, Air, and Soil Pollution*, 228(9). <https://doi.org/10.1007/s11270-017-3505-3>

1008 Vymazal, J. (2011). Constructed Wetlands for Wastewater Treatment: Five Decades of
1009 Experience †. *Environmental Science & Technology*, 45(1), 61–69.
1010 <https://doi.org/10.1021/es101403q>

1011 Warner, W., Nödler, K., Farinelli, A., Blum, J., & Licha, T. (2018). Integrated approach for
1012 innovative monitoring strategies of reservoirs and lakes. *Environmental Engineering and
1013 Management Journal*, 17(10), 2497–2505. <https://doi.org/10.30638/eemj.2018.248>

1014 WHO. (2008). Guidelines for drinking-water quality.

1015 Willems, P. (2012). Impacts of Climate Change on Rainfall Extremes and Urban Drainage
1016 Systems. *Water Intelligence Online*, 11(1), 16–28. <https://doi.org/10.2166/9781780401263>

1017 Xu, Z., Wu, J., Li, H., Chen, Y., Xu, J., Xiong, L., & Zhang, J. (2018). Characterizing heavy
1018 metals in combined sewer overflows and its influence on microbial diversity. *Science of the
1019 Total Environment*, 625, 1272–1282. <https://doi.org/10.1016/j.scitotenv.2017.12.338>

1020 Young, S., Juhl, A., & O'Mullan, G. D. (2013). Antibiotic-resistant bacteria in the Hudson River
1021 Estuary linked to wet weather sewage contamination. *Journal of Water and Health*, 11(2),
1022 297–310. <https://doi.org/10.2166/wh.2013.131>


1023

1024

1025 **Figure captions**

1026 **Fig. 1.** A) Separate sewer system, B) Combined sewer system, C) Combined sewer overflow

1027 (adopted from Al Aukidy et al., 2017).




1- Wastewater sewer 2- Stormwater sewer 3- Wastewater treatment plant (WWTP)
4- Combined sewer system (CSS) 5- Combined sewer overflow (CSO)

1028

1029

1030 **Fig. 2.** Management strategies for combined sewer overflow (adopted from Levy et al., 2014).



1031

1032


1033 **Fig. 3.** Location of the INTCATCH pilot plant in Lazise, Villa Bagatta



1034

1035

1036 **Fig. 4.** Flow diagram of pilot plant in Villa Bagatta – INTCATCH (Botturi et al., 2020)



1037