



Studies on CFD Analysis and Optimization in Vapour Absorption Refrigeration System- A Review

BrajendraManjhi^{a*}

^a*Mechanical Engineering Department, NIT Tiruchirappalli, Tamil Nadu, India.*

^{*}*Corresponding Author Email and Phone Number: brajendramanjhi339@gmail.com, +918252229992*

Article received: 14/03/2022, Article Revised: 23/04/2022, Article Accepted: 26/04/2022

© 2022 THE AUTHORS. This is an open access article distributed under the [Creative Commons Attribution License 4.0 \(CC-BY\)](#), which permits unrestricted use, distribution, and reproduction in any medium, provided the original work is properly cited.

ABSTRACT

Many academics have spent decades trying to identify the right settings and approaches to minimize its drawback. The behavior of the absorber was evaluated using a parametric analysis. A multi-objective Genetic Algorithm was used to improve the shape of PCM. For finding capacity of fluid, ANSYS model is used. To examine vaporescence and moisture content, CFD is used for generating the capacity of fluid and assorted different phase flux version. Exergoeconomic review and improvement, thermal distribution transfer in an absorber, changes in designing parameters are all covered in this study for reductions of yearly running costs and thermal efficiency destruction. There was also a discussion about the Vapour Absorption Refrigeration System's advancements.

Keywords:PCM, ANSYS FVM, Thermo-economic, CFD modelling, Multi Objective Genetic Algorithm

1. INTRODUCTION

In the recent scenario The VARS was developed because the VCRS consumed a lot of power and was neither feasible or cheap in areas where power was scarce or expensive. Vapour absorption refrigeration systems are ideal for areas where heat energy is abundant and inexpensive. Coolants wetness that leads to the growth of acids in airtight compressors as well as different complex materials, provide growth in deterioration of metals, copper coating, and chemical destruction to the insulating material. To remove moisture from the refrigerant, a dryer is utilized. It's also referred to as a dehydrator or a drier. As a result, several academics are working on improving the VARS's efficiency by using computational fluid dynamics and appropriate optimization approaches by changing the appropriate

equipment. If the temperature of the coolant that's evaporating is higher and it will give more value of the COP. As a result of which the temperature of heat rejection will be low.

Several researches have been carried out on the absorption cycles till now, comprising of energy and exergy economic, thermo-economic, and their analysis. These researchers used the first law which deals with the energy as basis for the evaluation of the result.

Absorption technology, which uses low degradation of ozone along with the minimum value of global warming prospective substances, appears as a good alternative for the VCRS in terms of green technologies.

2. EARLIER STUDY OF VAPOUR ABSORPTION REFRIGERATION SYSTEM

Lima et al. [1] The model's study was based on equations that describe energy and momentum conversions, as well as correlations that define the heat transfer characteristics in the shape under consideration. As per the research results, approximately 10 percentage significantly raise with in mass ratio of NH_3 first at absorber's entry side produce a variation of almost 17.9% at the outlet side, whilst the around 10 percent fall in the mass ratio of NH_3 at the entry produces together almost 29.8% rise in the quantity of ammonia that is available at the outside, among other outcomes that can be seen in the process.

Ghorbani et al. [2] The model equations were solved using an FDM approach and the enthalpic technique. The system's response for different types of factors such as the number of tubes, their diameter, and PCM content is investigated. Finally, most optimum layout for the PCM was discovered by using the MATLAB programming that solved the mathematical type of programme like matrix with the help of different tools that available in toolbox. According to an environmental aspect, this is also a fantastic way to cut expenditure and CO_2 emissions.

Mohammed et al. [3] To explore the quantity converted from liquid to vapour and vice versa of a substance (like acetone) in a longitudinal circular pipe, they used the Ansys Software that uses FVM method for generating capacity of fluid and combination of multiphase fluid dynamics simulations. In circumstances where the input temperature exceeds saturation, a large temperature variance in between entrance and wall temperatures results in improved condensation and evaporation performance.

Wen et al. [4] uses the concept of rate of diffusion related to concentration of slope and the transmission of penetrating mass. This is necessary to differentiate the complete and thorough hydrological parameters with observed data in order to fully establishment of the simulation in both fluid dynamics and transmits characteristics. Improved laser-based

diagnostics will be necessary to obtain the sheet depth, speeds field, or other information regarding the flow of fluid. Among those who have contributed to this work are Zhai et al. [5] who stated that heat flux and fall in pressure of a PHE absorbing material with water/ dry mater intake methane and daily methane production were researched using the conventional H₂O/LiBr as a reference point. Finally, Pareto charts had been created during design optimization to demonstrate the exchange between coolant capacity and process COP.

According to Azhar et al. [6] the improper ignition processes were already calibrated for different energy source temperature ranges that's related to the major generator temperature. For direct ignition systems, the proportion of exergy loss at the time of combustion required for energy references has been optimised. The concentration of LiBr salt will be optimized to fit the temperature rise for each generator in the appropriate cycles.

Yang et al. [7] used a non-dominant type genetic mathematical technique to solve a versatile optimization framework that incorporates three argument functions: heat output, yearly overall cost, and (NSGA-II). The supreme ideal solution achieves a 13.17 percent increase for the thermal performance also a 13.49 percent reduce in Eco-indicator (sixteen) at an 8.94 percentage price hike in a year. According to the Wei et al. [8] in the designing of the CAHR system, the conservations of mass and exergy of base fluid are considered. Four parameters are adjusted with COP in imagination: Ammonia/water mass ratio, turbine discharge pressure, produced temperature, and ratio of compression. Thermal performance surpasses a double-effect absorption system.

Chen et al. [9] who suggested cascade system that can produce water supply and three quality flows of cooled water at various temperature settings. The experimental cascade system achieves a highest COP_c of 0.55 provided the refrigeration capacity proportion of the ABC to the ADC is kept at 2.1, whilst optimized ABC-ADC cascade arrangement attain a utmost COP_c of 66 percentage. In the field of recent research Misra et al. [10] attempted to reduce the total price of the used product by modifying the values of the system's functional operational parameters, which can be done by adjusting thermoeconomic cost. At the last, an equivalent best operating configuration shows that variations in the set point of the decision factors are independent of the fuel cost variations.

Bhardwaj et al. [11] exterior thermal tanks with finite heat capacity, as well as exterior and interior irremediability, which are both typical in real absorption cooling system, were analyzed. The best COP is obtained by optimizing the refrigeration load by a specific thermal input rate in the engine. It has the ability to help with the knowledge of both thermodynamics with respect to time and the creation of methodical and quantitative

research. In the year of 2022 Zhou et al. [12] suggested that In a TS diagram, the proposed system against the existing ORC, which employs identical radiant heat in the turbine exit pressure and gross electricity production, and these two entities are then illustrated and compared. The data indicate that the R123-based approach achieved 53.13 KW (GEP) which is 28.3 percentage more, and has a 37.18 percent exergy performance.

Nagraj et al. [13] stated that Genetic algo, Particle swarm escalation and teaching learning established development all are used to achieve economic cost goals. For both basic and modified VARS, Genetic algo calculates the lowest yearly cost, whereas particle swarm escalation reflects its least exergy demolition, and teaching learning established development reflects the minimal total production cost of plant. The IGD value of particle swarm escalation is lower than others two optimization method, indicating that particle swarm

escalation method Pareto front solutions are more converged. Zapata et al. [14] discussed that when its impact of mixture flow rate and chilled water temp are taken into account, the CFD model can accurately forecast the absorption rate in ammonia/Lithium nitrate lateral dual conduit heat-transfer bubble coolant. The analysis showed that further very small refinement and sizing of the meshing elements (on which experiment is going on) may be required to improve CFD prediction performance when analysing features such as absorption flow rate and solution heat transfer coefficient are taken into the consideration.

Hosseinnia et al. [15] represent the occurring of absorbance operation inside descending drops without any heat addition or heat rejection. Furthermore, the quantity of supercooling in proportion to the optimum temperature and concentration is affected by that of the absorber operating pressure. The supercooling value rises approximately 13.8 K and the collected mass becomes two times with a factor of 2.5 due to the increasing of the pressure intensity from 1.32 kPa to 2.8 kPa at a fixed quantity of 60 weight percent of LiBr and 303.15 K temp.

3. CONCLUSION

As a consequence of the literature review stated above, the following are the different areas that will be covered in this study.

- In the generator, it's critical to keep the refrigerant vapour and the absorbent solution completely separate.
- MATLAB's genetic algorithm toolbox was taken into consideration for find the optimum design of the PCM.

- The process pressure loss of absorber had a substantial consequence on the cycle COP, whilst the mild design pressure loss inside the desorber had very less impression on the cycle effectiveness.
- The contrast between system's cost of fuel supply in accordance with the less exergy degradation and system's total investment in form of total heat-transfer surface area compute the system's overall yearly cost.
- The number of moles of LiBr will be optimised to match the temps in all of the essential cycles' generators.

Acknowledgement/Funding Acknowledgement

The author(s) received no financial support for the research, authorship, and/or publication of this article.

Declaration of Competing Interest

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

REFERENCES

- [1] A.A.S. Lima, A.A.V. Ochoa, J.A.P. Da Costa, J.R. Henríquez. CFD simulation of heat and mass transfer in an absorber that uses the pair ammonia/water as a working fluid, *International Journal of Refrigeration* 98 (2019) 514–525.
- [2] B.Ghorbani, F. Kowsary, S. Ebrahimi, K. Vijayaraghavan. CFD modeling and optimization of a latent heat storage unit for running a solar assisted single effect Li-Br absorption chiller using multi-objective genetic algorithm, *Sustainable Cities and Society* 34 (2017) 321–334.
- [3] H.I. Mohammed, D. Giddings, G.S. Walker. CFD multiphase modelling of the acetone condensation and evaporation process in a horizontal circular tube, *International Journal of Heat and Mass Transfer* 134 (2019) 1159–1170.
- [4] T. Wen, L. Lu, Y. Luo. Review on the fundamentals and investigations of falling film dehumidification/absorption refrigeration based on CFD technology, *International Journal of Heat and Mass Transfer* 171 (2021) 121042.
- [5] C. Zhai, Z. Sui, W. Wu. Geometry optimization of plate heat exchangers as absorbers in compact absorption refrigeration systems using H₂O/ionic liquids, *Applied Thermal Engineering* 186 (2021) 116554.
- [6] Md. Azhar, M.A. Siddiqui. Exergy analysis of single to triple effect lithium bromide-water vapour absorption cycles and optimization of the operating parameters, *Energy Conversion and Management* 180 (2019) 1225–1246.
- [7] P. Yang, M. Yuan, Z. Liu, N. Xie, Y. Liu, S. Yang. Multi- objective optimization and life cycle assessment of a cascade system integrating LiBr/H₂O absorption refrigeration with transcritical CO₂ power cycle, *Energy Conversion and Management* 244 (2021) 114453.
- [8] C. Wei, X. Hao, B. Tianjiao, Z. Bin, H. Yan. Numerical investigation and optimization of a proposed heat-driven compression/absorption hybrid refrigeration system combined with a power cycle, *Energy* 246 (2022) 123199.
- [9] W.D. Chen, K.J. Chua. Energy performance analysis and optimization of a coupled adsorption and absorption cascade refrigeration system, *Applied Energy* 301 (2021) 117518.
- [10] R.D. Misra, P.K. Sahoo, A. Gupta. Thermoeconomic evaluation and optimization of a double-effect H₂O/LiBr vapour-absorption refrigeration system, *International Journal of Refrigeration* 28 (2005) 331–343.
- [11] P.K Bhardwaj, S.C Kaushik, S. Jain. Finite time optimization of an endoreversible and irreversible vapour absorption refrigeration system, *Energy Conversion and Management* 44 (2003) 1131–1144.
- [12] T. Zhou, J. Liu, J. Ren, S. Yang. Conceptual design, modelling and optimization of an integrated system by combining Organic Rankine Cycle and absorption refrigeration cycle for efficient energy

- recovery, Journal of the Taiwan Institute of Chemical Engineers 133 (2022) 104276.
- [13] S.M. Nagraj, R. Kommadath, P. Kotecha, R. Anandalakshmi. Multi-objective optimization of vapor absorption refrigeration system for the minimization of annual operating cost and exergy destruction, Journal of Building Engineering 49 (2022) 103925.
- [14] A. Zapata, C. Amaris, A. Sagastume, A. Rodríguez. CFD modelling of the ammonia vapour absorption in a tubular bubble absorber with $\text{NH}_3/\text{LiNO}_3$, Case Studies in Thermal Engineering 27 (2021) 101311.
- [15] S.M. Hosseinnia, M. Naghashzadegan, R. Kouhikamali. CFD simulation of adiabatic water vapor absorption in large drops of water–LiBr solution, Applied Thermal Engineering 102 (2016) 17–29.